City of Cambridge, Water Department

250 Fresh Pond Parkway, Cambridge, MA 02138
Monthly Water Quantity and Quality Report
September 2010

Edward Dowling,
Laboratory Manager
Water Operations
edowling@cambridgema.gov
(617) 349-4780

Richard Lagerholm
Water Quality Supervisor
-Watershed
Water Operations
rlagerholm@cambridgema.gov

David Kaplan
Watershed Technician
Watershed Division
dkaplan@cambridgema.gov

Krystyna McInally
Water Quality Supervisor
-Treatment
Water Operations
kmcinally@cambridgema.gov

James Rita
Production Manager
Water Operations
jrita@cambridgema.gov

The data contained in this report is for informational purposes only subject to verification and not intended for regulatory compliance.





Water Supply

The Cambridge water supply system consists of three source water reservoirs and their tributaries located in Lexington, Waltham, Lincoln, Weston, and Cambridge. The reservoir system is a series of reservoirs. Hobbs Brook Reservoir (or upper reservoir) flows into Stony Brook Reservoir (middle reservoir) which flows to the terminal reservoir, Fresh Pond, located in Cambridge, via the Stony Brook conduit. The largest of the reservoirs, Hobbs Brook, reaches its maximum elevation at 181.3 feet above sea level, its maximum depth at approximately 25 feet, and at full capacity, holds approximately 2.5 billion gallons of water. Stony Brook Reservoir reaches its maximum elevation at 80.6 feet above sea level, its deepest point is at approximately 35 feet, and at full capacity, it contains roughly 455 million gallons of water-revised 2009. Fresh Pond Reservoir reaches its maximum elevation at 17 feet above sea level, its maximum depth at 50 feet, and at full capacity, holds roughly 1.5 billion gallons. The water is then purified at the Walter Sullivan Water Treatment Plant and pumped to Payson Park Reservoir, which is two 16 million gallon drinking water clearwells located in Belmont at a maximum elevation of 181 feet, where it is further disinfected with chloramines and distributed to the city by gravity.

While the Watershed's primary storage reservoir is Hobbs Brook, in the winter and spring months it is largely unused. Due to its vast size, and relatively small watershed, Hobbs Brook is slow to fill up. This winter hiatus is necessary for Hobbs to regain the water transferred in the summer months. Conversely, Stony Brook is relatively small compared to its large watershed and fills much faster than Hobbs Brook. Due to this condition, water from Stony Brook is transferred during the winter months. During times of high water flow, excess water is diverted into the Charles River at Stony Brook.

Current Conditions: (10/04/10)
The reservoir system is at 65% capacity. The reservoir system is currently at 101% of historical capacity for this time of year. Hobbs Brook Reservoir current storage volume is 1308 Million Gallons (MG) or 48% capacity. Stony Brook Reservoir has a current storage volume is 316 MG or 68% capacity and is filling with water coming from the Hobbs Brook watershed. Fresh Pond Reservoirs current storage volume is 1,434 MG or 93% capacity. The average daily demand is 15.4 Million Gallons per Day (MGD). Days of supply remaining without recharge: 131 or 4.4 months.

Reservoir storage levels







Reservoir Water Specific Conductance







Water Demand

-Cambridge City Population: 101,355

Million Gallons (MG) - Gallons per Minute (GPM)

Maximum instantaneous demand:
09/02/10 at 08:02 am: 16,132 GPM

Minimum instantaneous demand:
09/28/10 at 2:45 am: 6,451 GPM

Average daily water demand for 2010 (to date):	13.70 MG
Average daily water demand 2009:	13.00 MG
Average daily water demand September 2010:	15.44 MG
Average daily water demand September 2009:	14.29 MG
Monthly Water Demand September 2010:	463.1 MG
Monthly Water Demand September 2009:	428.7 MG
Total water produced for 2010(to date):	3,731 MG
Total water produced for 2009:	4,748 MG







Source Water Quality

Hobbs Brook Reservoir at intake

E-Coli Bacteria-	Average: 4 CFU/100mL
TOC	Average: 3.95 mg/L
UV 254	Average: 0.113 A/cm
Alkalinity (as $CaCO_3$):	Average: 22 mg/L
Sodium:	Average: 103 mg/L
Chloride	Average: 154 mg/L
Bromide:	Average: 0.086 mg/L
Turbidity-	Average: 1.40 NTU
Conductivity-	Average: 598 umhos/cm
*p*H-	Average: 7.42

Stony Brook Reservoir at intake

E-Coli Bacteria-	Average: 4 CFU/100mL
TOC	Average: 3.78 mg/L
UV 254	Average: 0.121 A/cm
Alkalinity (as $CaCO_3$):	Average: 29.0 mg/L
Sodium	Average: 92 mg/L
Chloride	Average: 135 mg/L
Bromide	Average: 0.08 mg/L
Turbidity	Average: 2.1 NTU
Conductivity-	Average: 562 umhos/cm
*p*H-	Average: 7.26

Fresh Pond Reservoir at intake

E-Coli Bacteria-	Average: 8.0 CFU/100mL
TOC	Average: 3.00 mg/L
UV254	Average: 0.086 A/cm
SUVA	Average: 3.17
Sodium	Average: 79 mg/L
Chloride	Average: 121 mg/L
Bromide	Average: 0.068 mg/L
Alkalinity (as CaCO3)	Average: 30.0 mg/L
Turbidity-	Average: 0.50 NTU
Conductivity-	Average: 521 umhos/cm
*p*H-	Average: 7.46
Temperature:	Average: 23°C

Cryptosporidium and Giardia

As part of the Long Term 2 Enhanced Surface Water Treatment Rule monitoring Cambridge has collected 24 samples for *Cryptosporidium* and *Giardia* since February 2006. The monitoring is population based. Hence systems with populations >100,000 must collect 24 raw water samples over a two year period. The *Cryptosporidium* results are the basis for *bin assignment* on the Running Annual Average (RAA). Bin Classification: Systems with an RAA *Crypto* concentrations of <0.75 (Oo) cysts per liter are placed in Bin 1 for which no additional treatment is required. To date none of the samples have detected any *Cryptosporidiu*m and one sample out of 24 detected *Giardia* at 0.1 cysts/L.

Endocrine Disruptors, Pharmaceuticals, Personal Care Products

In response to the concern about the possibility of these unregulated compounds in municipal tap water, the Water Department monitors for 86 compounds and in March 2008 did not detect any in the tap water. Follow up sampling in September 2008 detected the following compounds in the tap water: Acetaminophen at 0.019 micrograms per liter (ug/L) and Nicotine at 0.007 ug/L, Monitoring will continue twice a year. March 2009: Cotinine at 0.001 ug/L. September 2009: No Detects, March 2010: 0.003 ug/L Atenolol



Turbidity

Turbidity is a measure of suspended and colloidal particles including clay, silt, and inorganic matter, algae, and microorganisms. Turbidity is determined by a technique involving the measurement of light scattered at right angles in a water sample. The more of the source light that is scattered the more (the higher) the turbidity. The units of measurement for turbidity are Nephelometric Turbidity Units (NTU's).



Finished Water Quality

Turbidity

The Surface Water Treatment Rule (SWTR) establishes performance goals for finished water turbidity. The pretreatment turbidity goal is to be less than 1 NTU. A conventional filtration plant is considered in compliance if the filtered water turbidity is less than 0.3 NTU in 95 % of its samples.

Turbidity is measured through the treatment process as a measure of treatment effectiveness. In the watershed and in the reservoirs turbidity may indicate the presence of silt from storm events or the presence of algae. In the pretreatment e.g. rapid mix, flocculation, and Dissolved Air Flotation (DAF)) portion of the plant turbidity is used indicator of process efficiency. Turbidity of the filter effluent is used both as a process efficiency and regulatory indicator of performance.

The effects of turbidity depend on the nature of the matter that causes the turbidity. High levels of particulate matter may have higher chlorine demand or may protect bacteria from the disinfectant effects of ozone and chlorine, thereby interfering with the disinfectant residual throughout the distribution system. The turbidity through the cycle of each filter run is an indicator of the overall effectiveness of the filter process.



Primary Disinfection - Ozone

The CWD provides disinfection to achieve the EPA requirement for 99.9% inactivation of Giardia cysts and 99.99% inactivation of viruses in drinking water. Instead of measuring or counting Giardia and viruses, compliance is determined by a system operational standard, the measurement of the disinfection process. EPA has established a set of criteria for each disinfectant (ozone, free chlorine, and chloramines).

They are stated as CT values where C is concentration and T is time. The concentration C of the disinfectant in the water over time T yields a measure of the effectiveness of disinfection, CT. The required CT varies with the disinfectant type, water temperature, pH, and other factors. CWD measures CT in three places, intermediate ozone, free residual chlorine in the clearwell, and chloramines through the Payson Park Reservoir. The goal is to meet the minimum CT requirements with the intermediate ozone system at a concentration of 1.5 mg/L (milligram per liter) Ozone. The CT credited from the other two sources provides redundancy to the system. The following two graphs show the combined ozone and free chlorine CT.





Secondary Disinfection - Chloramines

Regulations require a minimum of a 0.2 mg/L concentration of disinfectant throughout the distribution system. The higher values reflect the operational need for disinfection with free chlorine after the biological filters. A 15% solution of Sodium Hypochlorite is added at a concentration of 3.5 mg/L at the entrance the clearwell. The typical chlorine demand is approximately 1 mg/L this leaves a free residual chlorine concentration of 2.5 mg/L available for disinfection in the clearwell. It is this concentration of chlorine that's mixed with ammonia to create the level of chloramines measured as total residual chlorine using the HACH DPD Method.

Chloramination

The practice of adding ammonia to chlorinated water is called Chloramination. This process is recognized for taste and odor control to reduce the undesirable medicinal taste of chlorinated water. It was first used in Greenville, Tennessee in 1926. This process can contribute to taste and odor control problems if not properly controlled. The formation of di- and tri-chloramines species is minimized by controlling the chlorine and ammonia ratios (3 to 4:1). A 30 % solution of Ammonium Hydroxide is added at a concentration of 0.5 mg/L. CWD's target chlorine to ammonia ratio is 4.5:1

Distribution Chlorine Residual – mg/L





Corrosion Control – pH adjustment

The National Primary Drinking Water Regulations (NPDWR) - Lead and Copper Rule establishes limits to the amount of lead and copper that may be in drinking water at the consumers tap. The Action Level for Lead is 15 ug/L (micrograms per liter). CWD is in compliance with the 2008 round of reduced sampling. CWD's 90th percentile is 9 ug/L. The Action Level for Copper is 1300 ug/L. CWD's 90th percentile was 32ug/L. Cambridge meets the requirements by reducing corrosiveness of the water by adjusting the to pH 9 with a 50% solution of Sodium Hydroxide (as of 1/26/09) at a concentration of 22 mg/L. This combined with the natural occurring alkalinity, hardness and dissolved minerals in the water minimizes the leaching of lead and copper from service lines and home plumbing systems, the source of lead and copper at the consumer tap. The target for distribution system pH is 9.1. On 9/24/09 Finish Water pH Set point reduced to 8.8. The High Lift Pumps Seized due to Calcium Carbonate scaling. This scale forms when the water temperature is over 20^{o} C. Lowering Caustic addition at this time reduces this scaling.





Fluoridation

The Massachusetts Department of Health mandates that Drinking Water Systems fluoridate for the prevention of dental cavities. CWD adds a solution of 23% Hydrofluocylicic acid at a concentration of 1.0 mg/L. CWD targets the concentration at 1.1 mg/L. The Fluoride addition was stopped to determine the length of time the fluoride remains in the system. Estimated maximum water age is 12 days



Disinfection By-Products

The incidence of waterborne diseases has been greatly reduced since the widespread implementation of drinking water disinfection. While a measurable public health benefit has been achieved, other potential risks may have been introduced. The presence of chloroform and other trihalomethanes (THMs) in finished drinking water was first associated with the chlorination of drinking water in 1974. It was discovered that in, addition to killing microorganisms disinfectants react with organic and inorganic substances naturally present in the water to produce a variety of disinfection by-products (DBPs), which include THMs. The DBPs associated with chlorination are THMs, haloacetic acids, haloacetonitriles and halopicrins. Ozonation may result in bromate formation. Routine Bromate monitoring reveals none detected at <0.005 mg/L. Nitrosodimethylamine (NDMA) is a by product of chloramination. Sampling done over 4 quarters reveal no NDMA Detected at <0.005 ug/L



Total Organic Carbon(TOC) Survey

CWD - TOC Removal Performance Summary

Date	**a.** Raw	**b.** DAF Train 1	DAF Train #1 Percent removal efficiency **1-b/a*100**	**c.** DAF Train 2	DAF Train #2 Percent removal efficiency **1-c/a*100**	**d.** Filter Influent Train 1	Post-Ozone Train #1 Percent removal efficiency **1-d/b*100**	**e.** Filter Influent Train 2	Post-Ozone Train #2 Percent removal efficiency **1-e/c*100**	**f.** Finished Water	In/Out Percent Removal Efficiency **1-f/a*100**	Pretreatment Percent Removal Efficiency **((b+d)+(c+e))/2**	Filter Percent Removal Efficiency **(in/out -pretreat)**	Alum dose
	mg/L	mg/L	%	mg/L	%	mg/L	%	mg/L	%	mg/L	%	%	%	mg/L
9/29/2009	3.91	2.09	47	1.99	49	1.91	8.6	1.81	9.0	1.61	59	57	2.2	32
10/19/2009	3.87	2.22	43	2.08	46	2.15	3.2	1.79	13.9	1.58	59	53	6.2	29
11/30/2009	4.03	1.96	51	1.83	55	1.92	2.0	1.82	0.55	1.51	63	54	8.3	32
12/31/2009	4.04	2.21	45	2.06	49	2.00	9.5	2.09	-1.5	1.62	60	51	8.7	30
1/25/2010	4.07	2.13	48	2.16	47	2.05	3.8	2.12	1.9	1.63	60	50	9.8	31
2/25/2010	3.75	2.00	47	1.96	48	1.87	6.4	1.91	2.5	1.50	60	52	8.3	27
3/30/2010	3.10	1.37	56	1.43	54	1.47	-7.3	1.43	0.0	1.12	64	51	12.7	26
4/28/2010	3.03	1.48	51	1.38	54	1.37	7.4	1.36	1.4	1.08	64	57	7.1	27
5/13/2010	3.43	1.67	51	1.58	54	1.51	9.6	1.28	19.0	1.28	63	67	-4.2	27
6/15/2010	3.70	2.04	45	1.94	48	1.78	12.7	1.77	8.8	1.57	58	57	0.6	26
7/14/2010	3.23	1.76	46	1.70	47	1.47	16.5	1.38	18.8	1.36	58	64	-6.2	25
8/23/2010	2.95	1.67	43	1.57	47	1.33	20.4	1.29	17.8	1.23	58	64	-5.9	27
9/13/2010	2.87	1.58	45	1.50	48	1.37	13.3	1.25	16.7	1.16	60	61	-1.7	27
Average	**3.5**	**1.9**	**47.5**	**1.8**	**49.6**	**1.7**	**8.2**	**1.6**	**8.4**	**1.4**	**60.4**	**56.8**	**3.5**	**28.2**

Units: Milligrams per Liter(mg/L)

Percentages do not add up to 100%

TOC samples are grab samples taken accross the plant at a single time and not a single cohort of water

SUVA means the UV absorption at 254 nanometers (measured in 1/meters) divided by the dissolved organic carbon concentration (measured in mg/L).

Cambridge Water Department
Compliance Report for Enhanced Coagulation

Month	a. Treated TOC, mg/L	b. Source TOC, mg/L	c. Actual Removal(%) (1-a./b.)x100	Source Water Alkalinty	d. Required TOC Removal(%)	**Compliance** must be >1 e. c./d.
Oct-09	1.6	3.9	59	31.5	40	1.48
Nov-09	1.5	4.0	63	30.5	45	1.39
Dec-09	1.6	4.0	60	30.0	45	1.33
Jan-10	1.6	4.1	60	30.0	45	1.33
Feb-10	1.5	3.8	60	30.0	40	1.50
Mar-10	1.1	3.1	64	27.0	40	1.60
Apr-10	1.1	3.0	64	28.0	40	1.61
May-10	1.3	3.4	63	29.0	40	1.57
Jun-10	1.6	3.7	58	28.5	40	1.44
Jul-10	1.4	3.2	58	30.0	40	1.45
Aug-10	1.2	3.0	59	30.0	40	1.47
Sep-10	1.2	2.9	60	29.5	40	1.49
AVG last twelve mos.	1.4	3.5	60.5	29.5	41.3	1.5

If average last twelve months > 1.0, the system is in compliance.

		Alkalinity(mg/L) <60	60-120	>120
Raw	<2	No Action	No Action	No Action
Water	2 - 3.9	40%	30%	20%
TOC	4 - 7.9	45%	35%	25%
	>8	50%	40%	30%

Cambridge Water Department Laboratory

Massachusetts Certification Number M-MA149

		Monthly Average Chlorine Residual (mg/L)	Monthly minimum Chlorine Residual (mg/L)	Samples tested for Coliform	Total samples Coliform positive	Percent Total samples Coliform positive	Fecal Coliform positive	Public Notification required
2009	September	2.27	1.80	100	0	0	0	no
	October	2.30	1.78	100	0	0	0	no
	November	2.07	1.68	100	0	0	0	no
	December	2.00	1.60	100	0	0	0	no
2010	January	1.91	1.71	100	0	0	0	no
	February	2.01	1.97	100	0	0	0	no
	March	2.04	1.93	100	0	0	0	no
	April	2.07	1.91	100	0	0	0	no
	May	2.06	1.95	100	0	0	0	no
	June	2.01	1.70	114	0	0	0	no
	July	1.96	1.56	100	0	0	0	no
	August	1.97	0.86	100	0	0	0	no
	September	2.17	1.29	100	0	0	0	no

June 2010: Media batch was contaminated during prep.
Samples invalidated. Extra set of samples collected.

Massachusetts Water Resource Authority (MWRA) Toxic Reduction And Control (TRAC) program regulates discharge to the sewer system. The TRAC program classifies CWD as a Significant Industrial User (SIU) and has three permits for discharge: 0101 Residuals, 0102 Laboratory, and 0103 Truck Wash.

The EPA regulates discharge of clarified backwash water to Fresh Pond under the National Pollution Discharge Elimination System (NPDES) Act

Parameter	Daily Maximum Limit - **mg/L**	Monthly Residuals - 0101 09/07/10	Monthly Residuals - 0101 08/02/10	Semi-annual Lab Waste - 0102 01/04/10	Semi-annual Lab Waste - 0102 7/06/09	Semi-annual Truck Wash - 0103 01/04/10	Semi annual Truck Wash - 0103 07/06/09	Quarterly NPDES 2nd QTR 2010
Aluminum (NPDES)	Report Max. #	NR	NR	NR	NR	NR	NR	1.40
Cadmium	0.1	<0.002	<0.002	NR	NR	<0.005	<0.005	NR
Copper	**1.5**	0.058	0.18	<0.010	<0.010	0.026	0.028	NR
Chromium	**1**	0.007	0.020	NR	NR	0.006	<0.01	NR
Lead	**0.2**	<0.002	<0.002	<0.01	10	0.027	0.013	NR
Nickel	**1**	0.013	0.038	<0.025	<0.025	0.010	<0.025	NR
Silver	2	<0.003	<0.002	NR	NR	NR	NR	NR
Zinc	**1**	0.039	0.11	NR	NR	0.17	0.434	NR
Arsenic	0.5	0.014	0.026	NR	NR	NR	NR	NR
Selenium	**5**	0.022	<0.005	NR	NR	NR	NR	NR
Antimony	10	<0.010	<0.003	NR	NR	NR	NR	NR
Mercury	>0.001	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	NR
Total Residual Chlorine	Report Max.	NR	NR	NR	NR	NR	NR	0.07
Total Suspended Solids	<=3%	0.13%	0.47%	NR	NR	NR	NR	NR
TSS (NPDES)	50 (max)	NR	NR	NR	NR	NR	NR	9
PH (NPDES)	8.5 (max)	NR	NR	NR	NR	NR	NR	6.73
pH	5.5 - 10.5	6.51	6.51	7.52	7.56	8.02	7.66	NR
Cyanide	0.5	NR	NR	<0.005	<0.005	NR	NR	NR
Total Fats, Oil & Grease	<= 300	NR	NR	NR	NR	3.5	18	NR
Flow - Gallons/Day	1.0 MGD NPDES Reg.	131,670	46,800	88	32.5	22	50	0.51 MG
TTO (VOC)	Any analyte not to exceed 1 mg/L	NR	NR	NR	NR	All < 1mg/L	All < 1 mg/L	NR
TTO (ABN)	Any analyte not to exceed 1 mg/L	NR	NR	NR	NR	All < 1mg/L	All < 1mg/L	NR

NR= Not Required

CWD Monthly Water Quality Analysis

COMPARISON OF CAMBRIDGE TAP WATER							
With EPA & STATE STANDARDS							
PARAMETER	**Cambridge mg/L**	**Primary (Health Related) Maximum Contaminant Level(MCL) mg/L**	Secondary (Aesthetic Related) MCL mg/L	**PARAMETER**	**Cambridge mg/L**	**Primary (Health Related) Maximum Contaminant Level(MCL) mg/L**	Secondary (Aesthetic Related) MCL mg/L
Alkalinity (as $CaCO_3$)	**33.5**			**Magnesium**	4.2		
Aluminum	**0.013**		0.05-0.2	**UV254 A/cm**	0.026		
Arsenic	**<0.0005**	0.05		**Manganese**	0.006		0.05
Barium	**0.035**	2		**Mercury**	<0.0001	0.002	
Cadmium	**<0.0005**	0.005		**Nitrate (as Nitrogen)**	0.243		
Calcium	**20**						
Chloride	**136**		250	**pH**	8.90		
Chlorine, Free	**0.08**	4.0 MRDL+		**Selenium**	<0.0005	0.05	
Chlorine, Total	**2.66**	4.0 MRDL+		**Silver**	<0.00015		0.1
Chromium	**0.001**	0.1		**Sodium**	82		
Color	**0**		15 color units	**Specific Conductance, umhos/cm @25C**	572		
Copper	**0.003**	1.3		**Standard Plate Count**	0	500 C.F.U./1ml *	250
Dissolved Solids, Total	**343**		500	**Sulfate**	26		
Fluoride	**1.05**	4		**Total Coliform**	0	0 C.F.U./100ml	
Hardness (as CaCO3)	**50**			**Total Haloacetic acids**	5.3	60 ug/L (four quarter avg.)	
Iron	**0.04**		0.3	**Total Trihalomethanes**	8	80 ug/L (four quarter avg.)	
Saturation Index (SI)	**+0.23**			**Turbidity**	0.04	0.5 N.T.U filtered, 1.0	5
Lead	**0**	0.015		**Zinc**	<0.001		
+ MRDL = Maximum Residual Disinfectant Level				*** C.F.U./1ML = Colony Forming Units per 1 milliliter**			
Hardness in grains per gallon = 3				**CWD FINISHED WATER SAMPLE COLLECTED:09/01/10**			
NA = Not Analyzed				**Analyzed by Cambridge Lab.**			