



# City of Cambridge

## Purchasing Department

Cynthia H. Griffin  
*Purchasing Agent*

TO: ALL BIDDERS

FROM: CITY OF CAMBRIDGE


DATE: NOVEMBER 8, 2011

RE: FIRE ALARM SYSTEM REPAIR, INSTALLATION AND TESTING AS  
NEEDED FOR CITY AND SCHOOL BUILDINGS – FILE NO. 5623

---

Please find attached the Scheduled Testing and Inspections for City and School Buildings.

All other particulars remain unchanged.

  
\_\_\_\_\_  
CYNTHIA H. GRIFFIN  
PURCHASING AGENT

ADDENDUM NO. 5





# City of Cambridge

## Purchasing Department

Cynthia H. Griffin  
*Purchasing Agent*

TO: ALL BIDDERS

FROM: CITY OF CAMBRIDGE

DATE: NOVEMBER 8, 2011

RE: FIRE ALARM SYSTEM REPAIR, INSTALLATION AND TESTING AS  
NEEDED FOR CITY AND SCHOOL BUILDINGS – FILE NO. 5623

---

Please find attached the Scheduled Testing and Inspections for City and School Buildings.

All other particulars remain unchanged.

---

CYNTHIA H. GRIFFIN  
PURCHASING AGENT

ADDENDUM NO. 5



1) SCHEDULED TESTING & INSPECTION FOR YEAR ONE

BUILDING	SYSTEM TYPE	LOCATION	UNIT PRICE Per Test/Inspection
✓ 1. DPW Administration Building	Notifier/Honeywell NF-320	147 Hampshire St.	\$ _____
✓ 2. Coffon Building	Silentknight 5207	51 Inman Street	\$ _____
✓ 3. Lombardi Building	Firelite Sensiscan 1000	831 Mass. Ave.	\$ _____
<i>Robby</i> ✓ 4. City Hall	Simplex 4010	795 Mass. Ave.	\$ _____
✓ 5. City Wide Senior Center	Firelite MS9200 UD	806 Mass. Ave.	\$ _____
✓ 6. Area IV Youth Center	FCI BMFC-6	243 Harvard Street	\$ _____
✓ 7. Frisoli Youth Center	FCI FC-72	61 Willow Street	\$ _____
<del>8. Police Headquarters</del>	<del>ESL 1500</del>	<del>5 Western Avenue</del>	<del>\$ _____</del>
✓ 9. Moore Youth Center	Firelite Sensiscan 1000	<del>48</del> Gilmore Street	\$ _____
✓ 10. O'Neill Golf Course Clubhouse	EST LSS4/12	691 Huron Avenue	\$ _____
✓ 11. Emergency Communications	Notifier 500	489 Broadway	\$ _____
✓ 12. DPW Garage	Silentknight 5207	147 Hampshire St	\$ _____
✓ 13. O'Neill Golf Course Maint.	Edwards 5754B-2Z	Blanchard Road	\$ _____
✓ 14. City Hall Annex	MFA Mircom FX2000	344 Broadway	\$ _____
✓ 15. Danehy Park	Firelite Miniscan 424A	99 Sherman Street	\$ _____
○ 16. Sullivan Purification Facility	Simplex	250 Fresh Pond Pky	\$ _____
✓ 17. Engine 3	Silentknight 5207	175 Cambridge Street	\$ _____
✓ 18. Engine 4	FCI BMFC-6	2029 Mass Ave	\$ _____
✓ 19. Engine 6	Simplex 4001	176 River Street	\$ _____
✓ 20. Engine 8	Edwards EST-2	Garden Street	\$ _____
○ 21. Central Sq Library	FCI FC-73	45 Pearl Street	\$ _____
<del>22. School Department</del>	<del>Notifier 4800</del>	<del>15 Upton Street</del>	<del>\$ _____</del>
<del>23. School Department</del>	<del>Silentknight 5207</del>	<del>359 Broadway</del>	<del>\$ _____</del>
<del>24. Peabody School</del>	<del>Notifier 640</del>	<del>70 Rindge Ave</del>	<del>\$ _____</del>
<del>25. Baldwin School</del>	<del>Thorn Autocall</del>	<del>28 Sacramento Street</del>	<del>\$ _____</del>
<del>26. Morse School</del>	<del>Simplex</del>	<del>40 Granite Street</del>	<del>\$ _____</del>
<del>27. Tobin School</del>	<del>Simplex</del>	<del>197 Vassal Lane</del>	<del>\$ _____</del>
<del>28. Cambridgeport School</del>	<del>Simplex</del>	<del>89 Elm Street</del>	<del>\$ _____</del>
<del>29. Graham &amp; Parks School</del>	<del>Edwards</del>	<del>44 Linnaea Street</del>	<del>\$ _____</del>
<del>30. King School</del>	<del>Firelite 9600</del>	<del>100 Putnam Ave</del>	<del>\$ _____</del>
<del>31. Haggerty School</del>	<del>FCI 7100</del>	<del>110 Cushing Street</del>	<del>\$ _____</del>

Bidder's name \_\_\_\_\_

BUILDING	SYSTEM TYPE	LOCATION	UNIT PRICE Per Test/Inspection
32. War Memorial & Arts	FCI 7200	1640 Cambridge Street	\$ _____
33. Kennedy / Longfellow School	Simplex	158 Spring Street	\$ _____
34. School Department	FCI 7100	850 Cambridge Street	\$ _____
35. School Department	Notifier 4800	228 Windsor Street	\$ _____
36. High School	Autocall	450 Broadway	\$ _____
37. Municipal Garage	Edwards	51 First Street	\$ _____

TOTAL BUILDINGS \$ \_\_\_\_\_

**2) LABOR**

Regular Time (Monday – Friday 7:00 AM – 5:00 PM)

\$ \_\_\_\_\_ x 125 hours (estimated) = \$ \_\_\_\_\_

Overtime (Monday – Friday 5:00 PM – 7:00 AM, Saturdays, Sundays, Holidays)

\$ \_\_\_\_\_ x 30 hours (estimated) = \$ \_\_\_\_\_

TOTAL LABOR COST

\$ \_\_\_\_\_ (2)

(Add Regular Time Total + Overtime Total)

**3) MATERIALS MARKUP (%)**

Supplier's actual cost plus \_\_\_\_\_ % x \$5,000 = \$ \_\_\_\_\_ (3)  
 (i.e., for a materials markup of 10%, multiply \$5,000 x 1.20 to equal \$6,000.)

**PROPOSED CONTRACT PRICE**

The Proposed Contract Price shall be calculated as the sum of (1) Scheduled Test & Inspection for all City Buildings, (2) Total Labor Cost, and (3) Materials markup times \$5,000.

**PROPOSED CONTRACT PRICE** \$ \_\_\_\_\_

Bidder's name \_\_\_\_\_

LOCATION TESTED Public Works Garage ADDRESS 147 Hampshire St. #MEN REQ'D \_\_\_\_\_ PG 10F 2

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ FREQUENCY OF TESTING \_\_\_\_\_ SCHEDULED TESTING MONTHS \_\_\_\_\_ CODE 3

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_ TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_ FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES  NO  FIRE DEPARTMENT CONNECTION: YES  NO

DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_ RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

DIGITAL # \_\_\_\_\_ MCCUL.# \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION Side Entrance to Garage

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: \_\_\_\_\_ TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES  NO  SUPERVISED: YES  NO

TYPE	OTHER	ITEM	LOCATION
TYPE <u>Silent Knigh</u>	<u>5207</u>	<u>8 Zone</u>	<u>KEY #</u>
RESET PROCEDURE FOR CONTROL	VOLTS	ma	CONTROL BOX
	YES <input type="checkbox"/> NO <input type="checkbox"/>		METER READING
	KEY #		CHARGER-TIMER
	WET DRY		FUSE OR DISCONNECT
	GEL NONE		BATTERIES <u>Ultra Tech</u>
	YES <input type="checkbox"/> NO <input type="checkbox"/>		<u>VT 120 12001 79H</u>
	KEY #		EMERGENCY GENERATOR
	YES <input type="checkbox"/> NO <input type="checkbox"/>		DRILL SWITCH
	KEY #		REGISTER TIME SWITCH
	YES <input type="checkbox"/> NO <input type="checkbox"/>		REMOTE ANNUNCIATOR
	KEY #		REMOTE TROUBLE SIGNAL
TYPE	YES <input type="checkbox"/> NO <input type="checkbox"/>		CODED
MANUAL PULL STATION	MFGR		NON-CODED
			GLASS TYPE

OTHER	DEVICE	VOLTS	AMPS	MFGR	MOD #
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
FUSE OR DISCONNECT LOCATION	POWERED	IN-LINE	SINGLE STATION SMOKES		
	POWERED	IN-LINE	SYSTEM SMOKES		
			DUCT SMOKES		

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES  NO  TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_

CITY PSI HOUSE PSI AIR PSI \_\_\_\_\_ GATE TAMPERS: YES  NO

ELECTRIC BELL: YES  NO  WATERFLOW MOTOR GONG: YES  NO

SUPERVISORY PANEL LOCATION \_\_\_\_\_

DATA CARD \_\_\_\_\_



LOCATION TESTED 51 - IYMMY ADDRESS 51 IYMMY # MEN REQ'D 3  
 PG 1 OF 3

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ FREQUENCY OF TESTING \_\_\_\_\_ SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_ TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

GENERAL STATION CONNECTION: YES \_\_\_ NO \_\_\_ FIRE DEPARTMENT CONNECTION: YES  NO \_\_\_  
 DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_ MASTERBOX # 4251 RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION FRONT ENTRANCE

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: NO TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_

TYPE Silent Knight 6307 OTHER 6307 KEY # \_\_\_\_\_ CONTROL BOX \_\_\_\_\_ ITEM \_\_\_\_\_ LOCATION \_\_\_\_\_  
 RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ mA \_\_\_\_\_ METER READING \_\_\_\_\_

YES \_\_\_ NO \_\_\_ CHARGER-TIMER \_\_\_\_\_  
 KEY # \_\_\_\_\_ FUSE OR DISCONNECT \_\_\_\_\_  
 WET DRY \_\_\_\_\_ BATTERIES 5/25/11/10 Pz  
 GEL NONE \_\_\_\_\_ 12v 18 Amp/hr  
 YES \_\_\_ NO \_\_\_ EMERGENCY GENERATOR \_\_\_\_\_  
 KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REGISTER TIME SWITCH \_\_\_\_\_  
 KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

MANUAL PULL STATION M-FGR \_\_\_\_\_ CODED \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

OTHER	BELL	CHIME	DEVICE	VOLTS	AMPS	M-FGR	MOD #
HORN	BELL	CHIME	AUDIBLE SIGNAL				
LAMP #			VISUAL SIGNAL				
			DOOR HOLDER				
			COMBO SMOKE/DOOR HOLDER				
FUSE OR DISCONNECT LOCATION			SINGLE STATION SMOKES				
POWERED			SYSTEM SMOKES				
IN-LINE			DUCT SMOKES				
RESET PROCEDURES FOR SMOKES							

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_  
 SPRINKLERS WET DRY \_\_\_\_\_ RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_

CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ AIR PSI \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_  
 DATA CARD \_\_\_\_\_





LOCATION TESTED S-1 I AMAX

ADDRESS

S-1 I AMAX St.

ZONE	DESCRIPTION	YEAR	DATE																			
		NO	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
6	Police Station	5201	S																			
6	Police Station	5202	S																			
6	Police Station	5203	S																			
	Police Station	5204	S																			
	Police Station	5205	S																			
	Police Station	5206	S																			
	Police Station	5207	S																			
	Police Station	5208	S																			
	Police Station	5209	S																			
	Police Station	5210	S																			
	Police Station	5211	S																			
	Police Station	5212	S																			
	Police Station	5213	S																			
	Police Station	5214	S																			
	Police Station	5215	S																			
	Police Station	5216	S																			
	Police Station	5217	S																			
	Police Station	5218	S																			
	Police Station	5219	S																			
	Police Station	5220	S																			
	Police Station	5221	S																			
	Police Station	5222	S																			
	Police Station	5223	S																			
	Police Station	5224	S																			
	Police Station	5225	S																			
	Police Station	5226	S																			
	Police Station	5227	S																			
	Police Station	5228	S																			
	Police Station	5229	S																			
	Police Station	5230	S																			
	Police Station	5231	S																			
	Police Station	5232	S																			
	Police Station	5233	S																			
	Police Station	5234	S																			
	Police Station	5235	S																			
	Police Station	5236	S																			
	Police Station	5237	S																			
	Police Station	5238	S																			
	Police Station	5239	S																			
	Police Station	5240	S																			
	Police Station	5241	S																			
	Police Station	5242	S																			
	Police Station	5243	S																			

07 11 11  
10/18/2009



LOCATION: ED CITY HALL ADDRESS: 795 MASS AVE #MEN REC'D: 0 PG 1 OF 2

MAILING ADDRESS: \_\_\_\_\_ TYPE OF TEST: \_\_\_\_\_ FREQUENCY OF TESTING: \_\_\_\_\_ SCHEDULED TESTING MONTHS: \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST: \_\_\_\_\_ TEST PROCEDURE PER TERMS OF CONTRACT: \_\_\_\_\_ FIRE DEPARTMENT PROCEDURES FOR TESTING: \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_ FIRE DEPARTMENT CONNECTION: YES \_\_\_ NO \_\_\_

DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_ MASTERBOX # 4331 RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION MASS AVE + EDWARD PEDERSEN

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: No TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_

TYPE	OTHER	KEY #	ITEM	LOCATION
RESET PROCEDURE FOR CONTROL	OTHER	KEY # _____	CONTROL BOX	
		VOLTS _____	METER READING	
		YES ___ NO ___	CHARGER/TIMER	
		KEY # _____	FUSE OR DISCONNECT	
		WET DRY <u>X</u>	BATTERIES	<u>2</u>
		GEL NONE	EMERGENCY GENERATOR	<u>TP 1225 BY 05 AH</u>
		YES ___ NO ___	DRILL SWITCH	
		KEY # _____	REGISTER TIME SWITCH	
		YES ___ NO ___	REMOTE ANNUNCIATOR	
		KEY # _____	REMOTE TROUBLE SIGNAL	
		YES ___ NO ___		

MANUAL PULL STATION	MFGR	CODED	NON-CODED	GLASS TYPE

OTHER	DEVICE	VOLTS	AMPS	MFGR	MOD. #
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
FUSE OR DISCONNECT LOCATION	POWERED	IN-LINE	SINGLE STATION SMOKES		
	POWERED	IN-LINE	SYSTEM SMOKES		
			DUCT SMOKES		

RESET PROCEDURES FOR SMOKES: \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES: \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_

CITY PSI HOUSE PSI AIR PSI \_\_\_\_\_

ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_

SUPERVISORY PANEL LOCATION \_\_\_\_\_

WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_

GATE TAMPERS: YES \_\_\_ NO \_\_\_

DATA CARD



LOCATION TESTED *Area 4 Youth Center* ADDRESS *2413 Harvard St* PG 2 OF 2

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ #MEN REQ'D \_\_\_\_\_

FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_

SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_ FIRE DEPARTMENT CONNECTION: YES  NO \_\_\_

DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_ RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ MASTERBOX LOCATION *Front Entrance* \_\_\_\_\_

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: *NO* \_\_\_\_\_ TRIPS ZONE # \_\_\_\_\_

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO  \_\_\_\_\_

OTHER LOCATION \_\_\_\_\_

TYPE *FCI* *FC-72* KEY # *635* CONTROL BOX \_\_\_\_\_ ITEM \_\_\_\_\_

RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ METER READING \_\_\_\_\_

KEY # \_\_\_\_\_ CHARGER-TIMER \_\_\_\_\_

WET DRYX \_\_\_\_\_ FUSE OR DISCONNECT \_\_\_\_\_

GEL NONE \_\_\_\_\_ BATTERIES *05-191602 FA Panel* \_\_\_\_\_

YES \_\_\_ NO \_\_\_ EMERGENCY GENERATOR \_\_\_\_\_

KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_

YES \_\_\_ NO \_\_\_ REGISTER TIME SWITCH \_\_\_\_\_

KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_

YES \_\_\_ NO \_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

TYPE *Toggle Switch* \_\_\_\_\_

MANUAL PULL STATION MFGR *FCI* \_\_\_\_\_ NON-CODED  GLASS TYPE \_\_\_\_\_

OTHER *Key FCI Key* \_\_\_\_\_

HORN	BELL	CHIME	DEVICE	VOLTS	AMPS	MFGR	MOD #
			AUDIBLE SIGNAL	<i>24</i>		<i>Gentex Corp.</i>	<i>7500</i>
			VISUAL SIGNAL	<i>24</i>		<i>Gentex Corp</i>	<i>H5-24-7500S</i>
			DOOR HOLDER				
			COMBO SMOKE/DOOR HOLDER				
			SINGLE STATION SMOKES				
			SYSTEM SMOKES				
			DUCT SMOKES				

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS  WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_ AIR PSI \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_

CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_

SUPERVISORY PANEL LOCATION \_\_\_\_\_

DATA CARD \_\_\_\_\_



LOCATION TESTED

ADDRESS

PAGE

ZONE	DESCRIPTION	YEAR	DATE
Visual	Daycare Rm C	07	2/16/07
"	" Rm B	07	2/15/07
"	" Rm A	08	2/15/08
"	" Rm B	09	2/16/09
"	Infant Rm A	10	8/25/10
"	Game Rm	11	2/16/11

ZONE	DESCRIPTION	YEAR	DATE	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
Visual	Daycare Rm C	07	2/16/07	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
"	" Rm B	07	2/15/07	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
"	" Rm A	08	2/15/08	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
"	" Rm B	09	2/16/09	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
"	Infant Rm A	10	8/25/10	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S
"	Game Rm	11	2/16/11	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S

NT 8304261 TEST CARD

FOR SATISFACTORY TEST

FOR UNSATISFACTORY TEST & DESCRIBE IN REMARKS OR TROUBLE SLIP

FOR NO TEST, LEAVE BLANK & DESCRIBE IN REMARKS OR INFO SLIP



LOCATION TESTED

DESCRIPTION

YEAR  
DATE  
NO.

ADDRESS

07 07 16  
2/8 2/24 5/12 9/13 5/4

ZONE	DESCRIPTION	YEAR DATE NO.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	2nd Floor Port Rm	SD-30	S																			
	" "	SD-31	S																			
	3rd Floor Elevator	SD-32	S																			
	" "	SD-33	S																			
	3rd Floor Pan Room	SD 34	S																			
	3rd Floor Health Rm	SD 35	S																			
	" "	SD 36	S																			
	" "	SD 37	S																			
	" "	SD 38	S																			
	3rd Fl Council Aging	SD 39	S																			
	" "	SD 40	S																			
	3rd Fl Corridor	SD-41	S																			
	3rd Fl Entry Stair	SD 42	S																			
	3rd Floor Office	DS-96	S																			
	3rd Floor Med Rm	DS 47	S																			
	Basement Boiler Rm.	HD 11	S																			
	Basement Boiler Rm	HD 12	S																			
	Elevator Mech Rm	RR 11	S																			
	" "	RR 12	S																			
	MAIN Elevator	MM 13	S																			
	MAIN Elevator	MM 14	S																			
	MAIN Elevator	MM 15	S																			
	Garbage Storage Rm	MM 16	S																			
	Basement Elevator	MM 35	S																			
	Basement Elevator	MM 36	S																			
	Basement Elevator	MM 37	S																			
	1st Floor Anstl Spt	MM 28	S																			
	1st Floor Taper	MM 29	S																			
	1st Floor Taper	MM 30	S																			
	2nd Fl Taper	MM 31	S																			
	2nd Fl Elevator	MM 32	S																			
	3rd Fl Taper	MM 33	S																			
	501E Elevator	MM 34	S																			

FOR SATISFACTORY TEST

FOR UNSATISFACTORY TEST & DESCRIBE IN REMARKS OR

DOUBLE SLIP

FOR NO TEST, LEAVE BLANK & DESCRIBE IN REMARKS OR INFO SLIP





LOCATION TESTED 13D ADDRESS 881 Mass Ave PG. 01

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ #MEN REQ'D \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_ CODE 3  
 SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_ FIRE DEPARTMENT CONNECTION: YES ✓ NO \_\_\_

DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_ MASTERBOX # 13D RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION \_\_\_\_\_

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: \_\_\_\_\_ TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_

OTHER \_\_\_\_\_ LOCATION \_\_\_\_\_

TYPE Firelite SERIAL SEN 1000 KEY # \_\_\_\_\_ CONTROL BOX \_\_\_\_\_

RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ METER READING \_\_\_\_\_

8 zone 2 square YES \_\_\_ NO \_\_\_ CHARGER-TIMER \_\_\_\_\_

WET DRY \_\_\_\_\_ FUSE OR DISCONNECT \_\_\_\_\_

GEL NONE Mo. DS-12815 BATTERIES 4 \_\_\_\_\_

YES \_\_\_ NO \_\_\_ EMERGENCY GENERATOR \_\_\_\_\_

KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_

YES \_\_\_ NO \_\_\_ REGISTER TIME SWITCH \_\_\_\_\_

KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_

YES \_\_\_ NO \_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

TYPE \_\_\_\_\_ CODED \_\_\_\_\_

MANUAL PULL STATION MFG# \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

OTHER \_\_\_\_\_ DEVICE \_\_\_\_\_ VOLTS \_\_\_\_\_ AMPS \_\_\_\_\_ MFG# \_\_\_\_\_ MOD # \_\_\_\_\_

HORN Yes BELL \_\_\_\_\_ CHIME \_\_\_\_\_ AUDIBLE SIGNAL \_\_\_\_\_

LAMP # \_\_\_\_\_ VISUAL SIGNAL \_\_\_\_\_

DOOR HOLDER \_\_\_\_\_

COMBO SMOKE/DOOR HOLDER \_\_\_\_\_

SINGLE STATION SMOKES \_\_\_\_\_

SYSTEM SMOKES \_\_\_\_\_

DUCT SMOKES \_\_\_\_\_

POWERED IN-LINE \_\_\_\_\_

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_ AIR PSI \_\_\_\_\_

CITY PSI HOUSE PSI WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_

ELECTRIC BELL: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_

WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_

SUPERVISORY PANEL LOCATION \_\_\_\_\_

LOCATION TESTED

ADDRESS

ZONE DESCRIPTION

YEAR DATE NO.

06 07 10 11 5/12 5/14

ZONE	DESCRIPTION	YEAR	DATE	NO.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
HO22H	Basement	HS	001																						
HO22H	Basement	HS	003																						
HO22H	Basement EIL lobby	HS	004																						
HO22H	Basement Bathrm	HS	006																						
HO22H	Elevator lobby	HS	008																						
HO22H	Mech Rm	HS	009																						
HO22H	2nd Floor	HS	103																						
HO22H	Mech Rm	HS	106																						
HO22H	Loc Room	HS	109																						
HO22H	ESD Mech off	HS	111																						
HO22H	ESD "	HS	113																						
HO22H	ESD "	HS	115																						
HO22H	ESD Room Storage	HS	117																						
HO22H	2nd Fl Lobby	HS	202																						
HO22H	2nd Fl M/S Lobby	HS	204																						
HO22H	M/S Hall	HS	201																						
HO22H	Foresteel Lobby	HS	209																						
HO22H	Foresteel "	HS	211																						
HO22H	Foresteel "	HS	213																						
HO22H	M/S Lobby	HS	215																						
HO22H	Mech Rm 2nd FL	HS	302																						

INT 8304261 TEST CARD

FOR SATISFACTORY TEST

FOR UNSATISFACTORY TEST & DESCRIBE IN REMARKS OR PROBLE SLIP

FOR NO TEST, LEAVE BLANK & DESCRIBE IN REMARKS OR INFO SLIP

LOCATION TESTED

ISD

ADDRESS

831 Main Ave

PG. OF

ZONE	DESCRIPTION	YEAR DATE NO.	ADDRESS																		
			06	07	10	10	11	10	11	10	11	12	13	14	15	16	17	18	19	20	
5	Pull Station	Brick Door Hall	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
5	Smoke	Elevator Lobby	SD 002																		
5	Pull Station	Stairway	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
5	Smoke	Stairway	SD 007																		
5	Smoke	Reard Rm	SD 010																		
5	Smoke		SD 011																		
5	Smoke		SD 012																		
5	Smoke		SD 013																		
5	Smoke		SD 014																		
5	Smoke	Reard Rm	SD 015																		
2	Pull Station	Main Lobby	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	S	
2	All Station	Stairway	S 101																		
2	Smoke	Elevator Lobby	S 102																		
2	Smoke	Main Lobby	SD 104																		
2	Smoke		SD 105																		
2	Smoke	LIC Control	SD 108																		
2	Smoke		SD 110																		
2	Smoke	ISD office	SD 112																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		
2	Smoke	ISD office	SD 114																		









LOCATION TESTED Moore Youth Center ADDRESS 11 Gilmore St

MAILING ADDRESS \_\_\_\_\_  
 NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES  NO

DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_

TEL JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_

OTHER: Fire 1-1-10 1000 8 zones KEY # \_\_\_\_\_ ITEM \_\_\_\_\_  
 RESET PROCEDURE FOR CONTROL VOLTS \_\_\_\_\_ ma CONTROL BOX \_\_\_\_\_  
 YES \_\_\_\_\_ NO \_\_\_\_\_ METER READING \_\_\_\_\_  
 CHARGER-TIMER \_\_\_\_\_  
 FUSE OR DISCONNECT \_\_\_\_\_  
 BATTERIES NPT-12V \_\_\_\_\_  
 GEL NONE \_\_\_\_\_  
 YES \_\_\_\_\_ NO \_\_\_\_\_ EMERGENCY GENERATOR \_\_\_\_\_  
 KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_  
 YES \_\_\_\_\_ NO \_\_\_\_\_ REGISTER TIME SWITCH \_\_\_\_\_  
 KEY # N/A \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_  
 YES \_\_\_\_\_ NO \_\_\_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

FIRE DEPARTMENT CONNECTION: YES  NO   
 MASTERBOX # 3812 RADIOBOX # \_\_\_\_\_  
 LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_  
 MASTERBOX LOCATION By Front Entrance REVERSE \_\_\_\_\_  
 MICROSWITCH ON MASTERBOX: NO TRIPS ZONE # \_\_\_\_\_  
 FIRE DEPT DISCONNECT: YES \_\_\_\_\_ NO \_\_\_\_\_ SUPERVISED: YES \_\_\_\_\_ NO \_\_\_\_\_  
 LOCATION \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

OTHER: \_\_\_\_\_  
 HORN \_\_\_\_\_ BELL \_\_\_\_\_ CHIME \_\_\_\_\_ AUDIBLE SIGNAL \_\_\_\_\_  
 LAMP # \_\_\_\_\_ VISUAL SIGNAL \_\_\_\_\_  
 DOOR HOLDER \_\_\_\_\_  
 COMBO SMOKE/DOOR HOLDER \_\_\_\_\_  
 FUSE OR DISCONNECT LOCATION \_\_\_\_\_  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_ SINGLE STATION SMOKES \_\_\_\_\_  
 RESET PROCEDURES FOR SMOKES \_\_\_\_\_  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_ SYSTEM SMOKES \_\_\_\_\_  
 DUCT SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_  
 SPRINKLERS WET \_\_\_\_\_ DRY \_\_\_\_\_ RETARD: YES \_\_\_\_\_ NO \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ TIME TO ALARM \_\_\_\_\_  
 CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_\_\_ NO \_\_\_\_\_ AIR PSI \_\_\_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_\_\_ NO \_\_\_\_\_  
 WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 GATE TAMPERS: YES \_\_\_\_\_ NO \_\_\_\_\_  
 DATA CARD \_\_\_\_\_

NON-CODED 2 GLASS TYPE \_\_\_\_\_  
 MOD # \_\_\_\_\_

TYPE OF TEST \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_  
 SCHEDULED TESTING MONTHS \_\_\_\_\_  
 # MEN REQ'D \_\_\_\_\_  
 CODE 3 \_\_\_\_\_

PG 1 OF 1



LOCATION TESTED Frisol Youth Center ADDRESS 601 Willow St

MAILING ADDRESS \_\_\_\_\_  
 NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MULT/# \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ MCCUL # \_\_\_\_\_  
 TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ CS \_\_\_\_\_

FIRE DEPARTMENT CONNECTION: YES  NO \_\_\_  
 MASTERBOX # 2172 RADIOBOX # \_\_\_\_\_  
 LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_  
 MASTERBOX LOCATION FRONT ENTRANCE REVERSE \_\_\_\_\_  
 MICROSWITCH ON MASTERBOX: NO TRIPS ZONE # \_\_\_\_\_  
 FIRE DEPT DISCONNECT: YES  NO \_\_\_ SUPERVISED: YES  NO \_\_\_  
 LOCATION \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

TYPE FCI OTHER FCI SEALS 4200 KEY # \_\_\_\_\_  
 RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ ma \_\_\_\_\_  
 CONTROL BOX \_\_\_\_\_ METER READING \_\_\_\_\_  
 CHARGER-TIMER \_\_\_\_\_  
 FUSE OR DISCONNECT \_\_\_\_\_  
 BATTERIES 3-1250NB  
 GEL NONE 12V 18 and hr  
 YES \_\_\_ NO \_\_\_ EMERGENCY GENERATOR \_\_\_\_\_  
 KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REGISTER TIME SWITCH \_\_\_\_\_  
 KEY # 819 REMOVE ANNUNCIATOR \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REMOVE TROUBLE SIGNAL \_\_\_\_\_  
 CODED \_\_\_\_\_ NON-CODED

HORN	BELL	CHIME	DEVICE	VOLTS	AMPS	MFG#	GLASS TYPE	MOD #
			AUDIBLE SIGNAL					
			VISUAL SIGNAL					
			DOOR HOLDER					
			COMBO SMOKE/DOOR HOLDER					
			SINGLE STATION SMOKES					
			SYSTEM SMOKES					
			DUCT SMOKES					

RESET PROCEDURES FOR SMOKES  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_  
 HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS  WET \_\_\_\_\_ DRY \_\_\_\_\_ RETARD: YES \_\_\_ NO \_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ TIME TO ALARM \_\_\_\_\_  
 CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ AIR PSI \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_  
 DATA CARD \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 GATE TAMPERS: YES \_\_\_ NO \_\_\_



ZONE

DESCRIPTION

YEAR  
DATE

NO.

ADDRESS

PG

11115 011 10014 (A172)

3006 07 08 09 10 11  
3/21 10/11 12-13 3-27 8/21 9/12 3/12

Str. loc	Women's Rm	V-208	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
"	Men's Rm	V-209	S	S		S	S	S	S												
"	Meeting Rm	V-211	S	S		S	S	S	S												
"	Game Rm	V-212	S	S		S	S	S	S												
"	Game Rm	V-213	S	S		S	S	S	S												

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----

FOR SATISFACTORY TEST

FOR UNSATISFACTORY TEST & DESCRIBE IN REMARKS OR TROUBLE SLIP

FOR NO TEST, LEAVE BLANK & DESCRIBE IN REMARKS OR INFO SLIP

INT 8304261 TEST CARD

LOCATION TESTED **Danehy Park** ADDRESS **99 Sherman St.** PG 1 OF 2

MAILING ADDRESS \_\_\_\_\_ #MEN RECD \_\_\_\_\_

TYPE OF TEST \_\_\_\_\_ FREQUENCY OF TESTING \_\_\_\_\_ CODE 3

SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_

DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_ FIRE DEPARTMENT CONNECTION: YES  NO \_\_\_

DIGITAL # \_\_\_\_\_ MCCUL# \_\_\_\_\_ MASTERBOX # **6871** RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION **Garage Entrance** INCREASE REVERSE

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: \_\_\_\_\_ TRIPS ZONE # \_\_\_\_\_ DRILL ONLY

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES  NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_

OTHER \_\_\_\_\_ ITEM \_\_\_\_\_ LOCATION \_\_\_\_\_

TYPE **Fire Lite Miscar 4244** KEY # \_\_\_\_\_ CONTROL BOX \_\_\_\_\_

RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ METER READING \_\_\_\_\_

YES \_\_\_ NO \_\_\_ CHARGER-TIMER \_\_\_\_\_

KEY # \_\_\_\_\_ FUSE OR DISCONNECT \_\_\_\_\_

WET DRY \_\_\_\_\_ BATTERIES **24V 7AH** Panel

GEL NONE \_\_\_\_\_ EMERGENCY GENERATOR \_\_\_\_\_

YES \_\_\_ NO \_\_\_ KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_

YES \_\_\_ NO \_\_\_ KEY # \_\_\_\_\_ REGISTER TIME SWITCH \_\_\_\_\_

KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_

YES \_\_\_ NO \_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

MANUAL PULL STATION MFGR **Fire Lite Alarms** CODED \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE **NO**

OTHER **BG-10 Series** \_\_\_\_\_

OTHER	DEVICE	VOLTS	AMPS	MFG#	MOD.#
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
			SINGLE STATION SMOKES		
			SYSTEM SMOKES		
			DUCT SMOKES		

FUSE OR DISCONNECT LOCATION \_\_\_\_\_

POWERED IN-LINE \_\_\_\_\_

POWERED IN-LINE \_\_\_\_\_

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_

CITY PSI HOUSE PSI AIR PSI

ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_

SUPERVISORY PANEL LOCATION \_\_\_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_

DATA CARD \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI



LOCATION TESTED CITY HALL ANNEX ADDRESS 344 Broadway PG. 01

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ #MEN REC'D \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_  
 SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES  NO   
 DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_ RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ REVERSE \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION FIRST OF BLDG.  
 MICROSWITCH ON MASTERBOX: NO TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_  
 TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES  NO  SUPERVISED: YES  NO

ASSIGNMENT OR TEL # \_\_\_\_\_ LOCATION \_\_\_\_\_  
 OTHER \_\_\_\_\_

TYPE	OTHER	KEY #	CONTROL BOX	ITEM	LOCATION
TYPE	<u>Mic &amp; FX 3000</u>	KEY #	METER READING		
RESET PROCEDURE FOR CONTROL		YES <input type="checkbox"/> NO <input type="checkbox"/>	CHARGER-TIMER		
		KEY #	FUSE OR DISCONNECT		
		WET <input type="checkbox"/> DRY <input checked="" type="checkbox"/>	BATTERIES	<u>APR 18-12</u>	<u>(D)</u>
		GEL <input type="checkbox"/> NONE <input type="checkbox"/>	EMERGENCY GENERATOR	<u>18V 15AH</u>	
		YES <input type="checkbox"/> NO <input type="checkbox"/>	DRILL SWITCH		
		KEY #	REGISTER TIME SWITCH		
		YES <input type="checkbox"/> NO <input type="checkbox"/>	REMOTE ANNUNCIATOR		
		KEY #	REMOTE TROUBLE SIGNAL		
		YES <input type="checkbox"/> NO <input type="checkbox"/>			

MANUAL PULL STATION MFG# \_\_\_\_\_ CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

OTHER	DEVICE	VOLTS	AMPS	MFG#	MOD.#
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
			SINGLE STATION SMOKES		
			SYSTEM SMOKES		
			DUCT SMOKES		

RESET PROCEDURES FOR SMOKES \_\_\_\_\_  
 HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET  DRY  RETARD: YES  NO  TIME TO ALARM \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ WATERFLOW ALARM 2' DRAIN PSI \_\_\_\_\_  
 CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ GATE TAMPERS: YES  NO   
 ELECTRIC BELL: YES  NO  WATERFLOW MOTOR GONG: YES  NO   
 SUPERVISORY PANEL LOCATION \_\_\_\_\_

ZONE	DESCRIPTION	YEAR	DATE
		10	5/21
		11	11/10-19

NO	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
----	---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----

ZONE	DESCRIPTION	YEAR	DATE	NO	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
	ASST DIR 2ND FL	SD-021			S	S	S	S																
	2ND FL KITCHEN	SD-026			S	S	S	S																
	2ND FL HALL 0008	SD-019			S	S	S	S																
	2ND FL JANITEN 210	SD-017			S	S	S	S																
	2ND FL UPPER LOBBY	SD-038			S	S	S	S																
	2ND FL ELECT CLOSET	SD-031			S	S	S	S																
	2ND FL COMM CLOSET	SD-061			S	S	S	S																
	2ND FL UPPER LOBBY	SD-015			S	S	S	S																
	" " " "	SD-010			S	S	S	S																
	" " " "	SD-009			S	S	S	S																
	" " " "	SD-003			S	S	S	S																
	2ND FL ADMIN AREA	SD-041			S	S	S	S																
	2ND FL HALL 003A	SD-012			S	S	S	S																
	2ND FL STAIR # 1	SD-029			S	S	S	S																
	2ND FL STAIR # 2	SD-016			S	S	S	S																
	1ST FL STAIR # 2	SD-020			S	S	S	S																
	1ST FL STAIR # 1	SD-030			S	S	S	S																
	2ND FL HALL 007	SD-007			S	S	S	S																
	2ND FL SPRINK RM	SD-006			S	S	S	S																
	2ND FL GEN RM	SD-005			S	S	S	S																
	3RD FL HALL 348	SD-042			S	S	S	S																
	3RD FL DIA RM 346	SD-041			S	S	S	S																
	3RD FL RECP 300	SD-050			S	S	S	S																
	" " " "	SD-054			S	S	S	S																
	3RD FL ELECT CLOSET	SD-037			S	S	S	S																
	3RD FL RECP 343	SD-061			S	S	S	S																
	3RD FL HALL 338	SD-060			S	S	S	S																
	" " " "	SD-058			S	S	S	S																
	" " " "	SD-057			S	S	S	S																
	" " " "	SD-047			S	S	S	S																
	3RD FL HAND DESK	SD-045			S	S	S	S																
	3RD FL NET RM 309	SD-048			S	S	S	S																
	3RD FL COMM RM 308	SD-049			S	S	S	S																
	3RD FL HALL 310A	SD-044			S	S	S	S																
	3RD FL ADMIN AREA	SD-043			S	S	S	S																

INT 8004261 TEST CARD       FOR SATISFACTORY TEST       FOR UNSATISFACTORY TEST & DESCRIBE IN REMARKS OR TROUBLE SLIP       FOR NO TEST, LEAVE BLANK & DESCRIBE IN REMARKS OR INFO SLIP

ZONE	DESCRIPTION	YEAR DATE NO.	ADDRESS																			
			10	11	11	10	11	10	11	10	11	10	11	10	11	10	11	10	11	10	11	
1st Fl	Main Lobby	S-114	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Main Lobby	S-115	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Hallway	S-129	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Hallway	S-119	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	Stair 2	S-113	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	Hallway	S-128	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Acad Room	S-116	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	Hallway 222B	S-118	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	Hallway 200C	S-130	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	Hallway 203A	S-114	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
3rd Fl	Hallway 348	S-146	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
3rd Fl	Reception	S-163	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
3rd Fl	Hallway 331A	S-156	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
3rd Fl	Hallway 331A	S-146	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
3rd Fl	Reception	S-146	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
4th Fl	Hallway 443	S-138	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
4th Fl	Hallway 400	S-159	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
4th Fl	Hallway 433A	S-151	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
4th Fl	Hallway 418A	S-148	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Bike Room	SD-012	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Main Lobby/00	SD-013	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	11	SD-001	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	11	SD-038	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	11	SD-021	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	11	SD-016	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	INTERNAL 123	SD-017	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	HALL 3	SD-018	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	HALL 3	SD-023	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	HALL 122	SD-027	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Public Corridor	SD-025	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	Rollcall 126	SD-026	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	HEAR. OFFICE	SD-024	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	ACD 135	SD-069	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	DIN STORAGE	SD-011	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
1st Fl	ELECT Rm	SD-031	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	HST GALL	SD-033	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	HALL 219	SD-026	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	HST GALL	SD-034	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	GALLERY Rm	SD-027	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	
2nd Fl	ASSIST DIR	SD-022	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	

INT RECORDS TEST GAIN [ ] LONG SATISFACTORY TEST [ ] LONG INVESTIGATIVE TEST & RECORDS IN DETAIL AND TERRITORY C. GIB [ ] LONG AND TEST LEAVE IN HAND & RECORDS IN DETAIL AND TERRITORY C. GIB

LOCATION TESTED Golf Maintenance ADDRESS 14 Blackhawk R.D. PG 1 OF 2

MAILING ADDRESS \_\_\_\_\_ #MEN REQ'D \_\_\_\_\_

TYPE OF TEST \_\_\_\_\_ FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_

SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES  NO  FIRE DEPARTMENT CONNECTION: YES  NO

DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_ RADIOBOX # \_\_\_\_\_ PANEL Key CAT 45

DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION Near ~~Area~~ Exterior Rest rooms

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: NO TRIPS ZONE # \_\_\_\_\_ DRILL ONLY

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES  NO  SUPERVISED: YES  NO

OTHER LOCATION

TYPE	OTHER	KEY #	CONTROL BOX	ITEM	LOCATION
RESET PROCEDURE FOR CONTROL	57548-22	KEY #	METER READING		
		YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	CHARGER-TIMER		
		KEY #	FUSE OR DISCONNECT		
		WET DRY	BATTERIES <u>NP4-12</u>		
		GEL NONE	<u>40BH</u>		
		YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	EMERGENCY GENERATOR		
		KEY #	DRILL SWITCH		
		YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	REGISTER TIME SWITCH		
		KEY #	REMOTE ANNUNCIATOR		
		YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	REMOTE TROUBLE SIGNAL		

MANUAL PULL STATION MFGR \_\_\_\_\_ CODED \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

HORN	BELL	CHIME	AUDIBLE SIGNAL	DEVICE	VOLTS	AMPS	MFGR	MOD.#
LAMP #			VISUAL SIGNAL					
			DOOR HOLDER					
			COMBO SMOKE/DOOR HOLDER					
			SINGLE STATION SMOKES					
			SYSTEM SMOKES					
			DUCT SMOKES					

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES  NO  TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_

CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ AIR PSI \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_

ELECTRIC BELL: YES  NO  WATERFLOW MOTOR GONG: YES  NO  GATE TAMPER: YES  NO

SUPERVISORY PANEL LOCATION \_\_\_\_\_

DATA CARD \_\_\_\_\_



LOCATION TESTED Public Works Carpentry/ADMIN office ADDRESS 147 Hampshire St.

MAILING ADDRESS \_\_\_\_\_  
 TYPE OF TEST \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_  
 SCHEDULED TESTING MONTHS \_\_\_\_\_  
 #MEN REQ'D \_\_\_\_\_  
 CODE 3 \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

**CENTRAL STATION CONNECTION:** YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_  
 TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_  
 MICROSWITCH ON MASTERBOX: \_\_\_\_\_  
 FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_  
 TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

**FIRE DEPARTMENT CONNECTION:** YES \_\_\_ NO \_\_\_  
 MASTERBOX # 2931 RADIOBOX # \_\_\_\_\_  
 LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_  
 MASTERBOX LOCATION ADMIN Building By rear entrance. REVERSE \_\_\_\_\_

**OTHER**  
 TYPE Custom 6500 12 Zone Key ITEM \_\_\_\_\_  
 RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ ma \_\_\_\_\_  
 CONTROL BOX \_\_\_\_\_  
 METER READING \_\_\_\_\_  
 CHARGER-TIMER \_\_\_\_\_  
 FUSE OR DISCONNECT \_\_\_\_\_  
 WET DRY W BATTERIES 52335  
 GEL NONE \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ EMERGENCY GENERATOR \_\_\_\_\_  
 KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REGISTER TIME SWITCH \_\_\_\_\_  
 KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_  
 YES \_\_\_ NO \_\_\_ REMOTE TROUBLE SIGNAL \_\_\_\_\_

OTHER	DEVICE	VOLTS	AMPS	MFG#	GLASS TYPE	MOD. #
HORN	AUDIBLE SIGNAL					
LAMP #	VISUAL SIGNAL					
	DOOR HOLDER					
	COMBO SMOKE/DOOR HOLDER					
FUSE OR DISCONNECT LOCATION	SINGLE STATION SMOKES					
	SYSTEM SMOKES					
RESET PROCEDURES FOR SMOKES	DUCT SMOKES					

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_  
 CITY PSI HOUSE PSI AIR PSI \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_

WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 DATA CARD \_\_\_\_\_







LOCATION TESTED *Engine 6* ADDRESS *176 River St.* PG. 01 OF 01

MAILING ADDRESS *Door code 2-3* TYPE OF TEST  
 FREQUENCY OF TESTING  
 SCHEDULED TESTING MONTHS

NOTICE REQUIRED PRIOR TO TEST  
 TEST PROCEDURE PER TERMS OF CONTRACT  
 FIRE DEPARTMENT PROCEDURES FOR TESTING

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # MULTIPLE #  
 DIGITAL # MCCUL #  
 XMITTER LOCATION KEY #  
 TEL. JACK OR BLOCK LOCATION CS  
 ASSIGNMENT OR TEL # FD

FIRE DEPARTMENT CONNECTION: YES \_\_\_ NO \_\_\_  
 MASTERBOX # *3611* RADIOBOX #  
 LEASE LINES INCREASE REVERSE  
 MASTERBOX LOCATION  
 MICROSWITCH ON MASTERBOX: TRIPS ZONE #  
 FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_  
 LOCATION

OTHER	KEY #	ITEM	LOCATION
TYPE <i>Synplex 4001</i>	KEY #	CONTROL BOX	
RESET PROCEDURE FOR CONTROL	VOLTS ma	METER READING	<i>C</i>
	YES ___ NO ___	CHARGER-TIMER	
	KEY #	FUSE OR DISCONNECT	
	WET DRY	BATTERIES	<i>2</i>
	GEL NONE	BATTERIES	<i>12V 7.0 AH</i>
	YES ___ NO ___	EMERGENCY GENERATOR	
	KEY #	DRILL SWITCH	
	YES ___ NO ___	REGISTER TIME SWITCH	
	KEY #	REMOTE ANNUNCIATOR	
	YES ___ NO ___	REMOTE TROUBLE SIGNAL	
TYPE	YES ___ NO ___		
MANUAL PULL STATION	MFGR	CODED	GLASS TYPE
		NON-CODED	

OTHER	DEVICE	VOLTS	AMPS	MFGR	MOD #
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
FUSE OR DISCONNECT LOCATION			SINGLE STATION SMOKES		
	POWERED	IN-LINE	SYSTEM SMOKES		
	POWERED	IN-LINE	DUCT SMOKES		<i>Synplex</i>
RESET PROCEDURES FOR SMOKES					<i>2098-9836 Phobos Batts</i>

HEAT DETECTORS SPECIAL TYPES  
 SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM  
 END OF LINE LOCATION  
 CITY PSI HOUSE PSI AIR PSI  
 WATERFLOW ALARM 2" DRAIN PSI  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_  
 WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION

DATA CARD





LOCATION TESTED *Engine 4/Squad 4* ADDRESS *8029 Mass Ave.* PG. 1 OF 2

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ #MEN REC'D \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_  
 SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

**CENTRAL STATION CONNECTION:** YES \_\_\_ NO  **FIRE DEPARTMENT CONNECTION:** YES \_\_\_ NO   
 DIRECT WIRE # \_\_\_\_\_ MULTI/# \_\_\_\_\_ MASTERBOX # *7171* RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION \_\_\_\_\_

TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: *NO* TRIPS ZONE # \_\_\_\_\_ DRILL ONLY \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_

TYPE	OTHER	KEY #	VOLTS	ma	CONTROL BOX	METER READING	ITEM	LOCATION
RESET PROCEDURE FOR CONTROL		YES ___ NO ___			METER READING			
		KEY #			CHARGER-TIMER			
		WET DRY			FUSE OR DISCONNECT			
		GEL NONE			BATTERIES <i>PS-1276</i>			<i>At Panel</i>
		YES ___ NO ___			EMERGENCY GENERATOR			
		KEY #			DRILL SWITCH			
		YES ___ NO ___			REGISTER TIME SWITCH			
		KEY #			REMOTE ANNUNCIATOR			
		YES ___ NO ___			REMOTE TROUBLE SIGNAL			

MANUAL PULL STATION MFGH \_\_\_\_\_ CODED \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

HORN	BELL	OTHER	CHIME	DEVICE	VOLTS	AMPS	MFGH	MOD #
				AUDIBLE SIGNAL				
				VISUAL SIGNAL				
				DOOR HOLDER				
				COMBO SMOKE/DOOR HOLDER				
				SINGLE STATION SMOKES				
				SYSTEM SMOKES				
				DUCT SMOKES				

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET DRY RETARD. YES \_\_\_ NO \_\_\_ TIME TO ALARM \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ AIR PSI \_\_\_\_\_ WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 CITY PSI HOUSE PSI WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_





LOCATION TESTED Engine 3/ Ladder 2 ADDRESS 173 Cambridge St #MEN REQ'D  
 MAILING ADDRESS TYPE OF TEST FREQUENCY OF TESTING SCHEDULED TESTING MONTHS CODE 3

PG 10 of 2

NOTICE REQUIRED PRIOR TO TEST  
 TEST PROCEDURE PER TERMS OF CONTRACT  
 FIRE DEPARTMENT PROCEDURES FOR TESTING

**GENERAL STATION CONNECTION:** YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # MULTI/# MCCUL #  
 DIGITAL # REVERSE  
 XMITTER LOCATION MASTERBOX LOCATION  
 TEL. JACK OR BLOCK LOCATION CS MICROSWITCH ON MASTERBOX: TRIPS ZONE # DRILL ONLY  
 ASSIGNMENT OR TEL # FD FIRE DEPT DISCONNECT: YES \_\_\_ NO 1 SUPERVISED: YES 1 NO \_\_\_ LOCATION

TYPE	OTHER	KEY #	ITEM	CONTROL BOX	LOCATION
RESET PROCEDURE FOR CONTROL	<u>Silent Knobs</u>	KEY # ma	METER READING		
		YES ___ NO ___	CHARGER-TIMER		
		KEY #	FUSE OR DISCONNECT		
		WET DRY	BATTERIES		
		GEL NONE	EMERGENCY GENERATOR		
		YES ___ NO ___	DRILL SWITCH		
		KEY #	REGISTER TIME SWITCH		
		YES ___ NO ___	REMOTE ANNUNCIATOR		
		KEY #	REMOTE TROUBLE SIGNAL		
TYPE		YES ___ NO ___			
MANUAL PULL STATION	MFG#		CODED	NON-CODED	GLASS TYPE

OTHER	DEVICE	VOLTS	AMPS	MFG#	MOD.#
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
FUSE OR DISCONNECT LOCATION			SINGLE STATION SMOKES		
	POWERED	IN-LINE	SYSTEM SMOKES		
	POWERED	IN-LINE	DUCT SMOKES		

RESET PROCEDURES FOR SMOKES  
 HEAT DETECTORS SPECIAL TYPES

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM  
 END OF LINE LOCATION AIR PSI WATERFLOW ALARM 2" DRAIN PSI  
 CITY PSI HOUSE PSI WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION





LOCATION 1 ED ADDRESS: 55 First St PG. OF

MAILING ADDRESS 55 First St TYPE OF TEST # MEN REQ'D  
 FREQUENCY OF TESTING CODE 3  
 SCHEDULED TESTING MONTHS

NOTICE REQUIRED PRIOR TO TEST  
 TEST PROCEDURE PER TERMS OF CONTRACT  
 FIRE DEPARTMENT PROCEDURES FOR TESTING

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # MULTI/# RADIOBOX # DIGITAL #  
 DIGITAL # MCCUL.# INCREASE REVERSE  
 XMITTER LOCATION KEY # MASTERBOX LOCATION

TEL JACK OR BLOCK LOCATION CS TRIPS ZONE # DRILL ONLY  
 ASSIGNMENT OR TEL # FD FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_  
 LOCATION

TYPE	OTHER	KEY #	ITEM	LOCATION
RESET PROCEDURE FOR CONTROL		YES ___ NO ___	METER READING	
		YES ___ NO ___	CHARGER-TIMER	
		WET DRY	FUSE OR DISCONNECT	
		GEL NONE	BATTERIES	
		YES ___ NO ___	EMERGENCY GENERATOR	
		KEY #	DRILL SWITCH	
		YES ___ NO ___	REGISTER TIME SWITCH	
		KEY #	REMOTE ANNUNCIATOR	
		YES ___ NO ___	REMOTE TROUBLE SIGNAL	

MANUAL PULL STATION MFG# CODED NON-CODED GLASS TYPE

OTHER	DEVICE	VOLTS	AMPS	MFG#	MOD.#
HORN BELL	AUDIBLE SIGNAL				
	VISUAL SIGNAL				
LAMP #	DOOR HOLDER				
	COMBO SMOKE/DOOR HOLDER				
FUSE OR DISCONNECT LOCATION	SINGLE STATION SMOKES				
	SYSTEM SMOKES				
	DUCT SMOKES				

RESET PROCEDURES FOR SMOKES  
 HEAT DETECTORS SPECIAL TYPES

SPRINKLERS WET DRY RETARD: YES \_\_\_ NO \_\_\_ TIME TO ALARM

END OF LINE LOCATION CITY PSI HOUSE PSI AIR PSI WATERFLOW ALARM 2" DRAIN PSI  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_ GATE TAMPERS: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION

DATA CARD

ONE	DESCRIPTION	YEAR		DATE																					
		NO.	NO.	NO.	NO.	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20

Middle of Each Floor  
 1st WGN Storage  
 2nd Horn Storage  
 3rd Horn Storage  
 4th Horn Storage  
 5th Horn Storage  
 Middle Speech Floor  
 Pull Station

1st Pull Station  
 2nd Pull Station  
 3rd Pull Station  
 4th Pull Station  
 5th Pull Station

Traffic Area  
 Heat  
 Heat  
 Heat

Pull Station  
 Smoke Elec Rm  
 Heat traffic Storage

Pull Station  
 Traffic Storage  
 Horn Storage  
 Smoke Elec Rm East

Sprinkler Rm Heat  
 First Street Side  
 Elevator Lobby

Smoke  
 Smoke  
 Smoke  
 Smoke

Smoke  
 Pull Station  
 Horn Storage  
 Pull Station



LOCATION TESTED 45 Pearl St. LIBRARY ADDRESS

MAILING ADDRESS 45 Pearl St

TYPE OF TEST \_\_\_\_\_

FREQUENCY OF TESTING \_\_\_\_\_

SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

#MEN REQ'D \_\_\_\_\_

CODE 3 \_\_\_\_\_

PG. OF \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

CENTRAL STATION CONNECTION: YES \_\_\_ NO \_\_\_  
 DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_  
 TEL. JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_  
 FIRE DEPARTMENT CONNECTION: YES X NO \_\_\_  
 MASTERBOX # 3911 RADIOBOX # \_\_\_\_\_  
 LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_  
 MASTERBOX LOCATION PEARL ST ENTRANCE  
 MICROSWITCH ON MASTERBOX: Nb TRIPS ZONE # \_\_\_\_\_  
 FIRE DEPT DISCONNECT: YES \_\_\_ NO \_\_\_ SUPERVISED: YES \_\_\_ NO \_\_\_  
 LOCATION \_\_\_\_\_

TYPE	OTHER	KEY #	CONTROL BOX	ITEM	NON-CODED	GLASS TYPE
RESET PROCEDURE FOR CONTROL	FGI	FG 73	METER READING	CHARGER-TIMER		
		YES ___ NO ___	FUSE OR DISCONNECT	BATTERIES		
		WET DRY	EMERGENCY GENERATOR			
		GEL NONE	DRILL SWITCH			
		YES ___ NO ___	REGISTER TIME SWITCH			
		KEY #	REMOTE ANNUNCIATOR			
		YES ___ NO ___	REMOTE TROUBLE SIGNAL			
		KEY #				
		YES ___ NO ___				

MANUAL PULL STATION Yes MFG# FGI  
 CODED \_\_\_\_\_ NON-CODED \_\_\_\_\_  
 OTHER: \_\_\_\_\_  
 HORN \_\_\_\_\_ BELL \_\_\_\_\_ CHIME \_\_\_\_\_  
 LAMP # \_\_\_\_\_  
 FUSE OR DISCONNECT LOCATION \_\_\_\_\_  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_  
 POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_  
 RESET PROCEDURES FOR SMOKES \_\_\_\_\_  
 HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_  
 SPRINKLERS \_\_\_\_\_ WET \_\_\_\_\_ DRY \_\_\_\_\_ RETARD: YES \_\_\_ NO \_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ TIME TO ALARM \_\_\_\_\_  
 CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ AIR PSI \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_ NO \_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_ NO \_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_  
 WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 GATE TAMPERS: YES \_\_\_ NO \_\_\_  
 DATA CARD





LOCATION TESTED Central Sq Wlp ADDRESS 45 Pearl St #MEN REQ'D \_\_\_\_\_

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_

SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_

TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_

FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES  NO  FIRE DEPARTMENT CONNECTION: YES  NO

DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_ RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_

DIGITAL # \_\_\_\_\_ MCCUL # \_\_\_\_\_ LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_

XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_ MASTERBOX LOCATION \_\_\_\_\_

TEL JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_ MICROSWITCH ON MASTERBOX: \_\_\_\_\_

ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_ FIRE DEPT DISCONNECT: YES  NO  SUPERVISED: YES  NO

OTHER FC-73 ITEM Fire Rooster Power Supply 2-12v 10 Amp hr LOCATION \_\_\_\_\_

TYPE FCT KEY # \_\_\_\_\_ CONTROL BOX \_\_\_\_\_

RESET PROCEDURE FOR CONTROL \_\_\_\_\_ VOLTS \_\_\_\_\_ METER READING \_\_\_\_\_

20 zone YES  NO  CHARGER-TIMER \_\_\_\_\_

KEY # \_\_\_\_\_ FUSE OR DISCONNECT \_\_\_\_\_

WET DRY \_\_\_\_\_ BATTERIES 2

GEL NONE \_\_\_\_\_ 12v 10 amp hr

YES  NO  EMERGENCY GENERATOR \_\_\_\_\_

KEY # \_\_\_\_\_ DRILL SWITCH \_\_\_\_\_

YES  NO  REGISTER TIME SWITCH \_\_\_\_\_

KEY # \_\_\_\_\_ REMOTE ANNUNCIATOR \_\_\_\_\_

YES  NO  REMOTE TROUBLE SIGNAL \_\_\_\_\_

MANUAL PULL STATION \_\_\_\_\_ MFG# \_\_\_\_\_ NON-CODED \_\_\_\_\_ GLASS TYPE \_\_\_\_\_

OTHER \_\_\_\_\_ DEVICE \_\_\_\_\_ VOLTS \_\_\_\_\_ AMPS \_\_\_\_\_ MFG# \_\_\_\_\_ MOD # \_\_\_\_\_

HORN \_\_\_\_\_ BELL \_\_\_\_\_ CHIME \_\_\_\_\_ AUDIBLE SIGNAL \_\_\_\_\_

LAMP # \_\_\_\_\_ VISUAL SIGNAL \_\_\_\_\_

DOOR HOLDER \_\_\_\_\_

COMBO SMOKE/DOOR HOLDER \_\_\_\_\_

SINGLE STATION SMOKES \_\_\_\_\_

POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_ SYSTEM SMOKES \_\_\_\_\_

POWERED \_\_\_\_\_ IN-LINE \_\_\_\_\_ DUCT SMOKES \_\_\_\_\_

RESET PROCEDURES FOR SMOKES \_\_\_\_\_

HEAT DETECTORS SPECIAL TYPES \_\_\_\_\_

SPRINKLERS WET \_\_\_\_\_ DRY \_\_\_\_\_ RETARD: YES  NO  TIME TO ALARM \_\_\_\_\_

END OF LINE LOCATION \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ AIR PSI \_\_\_\_\_

CITY PSI \_\_\_\_\_ WATERFLOW MOTOR GONG: YES  NO  WATERFLOW ALARM 2 DRAIN PSI \_\_\_\_\_

ELECTRIC BELL: YES  NO  GATE TAMPERS: YES  NO

SUPERVISORY PANEL LOCATION \_\_\_\_\_

LOCATION 1 RED Engine & Ladder 4 / Div. 2 ADDRESS 13 Garden St PG. OF 5

MAILING ADDRESS \_\_\_\_\_ TYPE OF TEST \_\_\_\_\_ #MEN REQ'D \_\_\_\_\_  
 FREQUENCY OF TESTING \_\_\_\_\_ CODE 3 \_\_\_\_\_  
 SCHEDULED TESTING MONTHS \_\_\_\_\_

NOTICE REQUIRED PRIOR TO TEST \_\_\_\_\_  
 TEST PROCEDURE PER TERMS OF CONTRACT \_\_\_\_\_  
 FIRE DEPARTMENT PROCEDURES FOR TESTING \_\_\_\_\_

CENTRAL STATION CONNECTION: YES NO X  
 DIRECT WIRE # \_\_\_\_\_ MULTI# \_\_\_\_\_  
 DIGITAL # \_\_\_\_\_ MCCUL# \_\_\_\_\_  
 XMITTER LOCATION \_\_\_\_\_ KEY # \_\_\_\_\_  
 TEL JACK OR BLOCK LOCATION \_\_\_\_\_ CS \_\_\_\_\_  
 ASSIGNMENT OR TEL # \_\_\_\_\_ FD \_\_\_\_\_  
 MICROSWITCH ON MASTERBOX: \_\_\_\_\_ TRIPS ZONE # \_\_\_\_\_  
 FIRE DEPT DISCONNECT: YES \_\_\_\_\_ NO \_\_\_\_\_ SUPERVISED: YES X NO \_\_\_\_\_ DRILL ONLY \_\_\_\_\_

FIRE DEPARTMENT CONNECTION: YES \_\_\_\_\_ NO \_\_\_\_\_  
 MASTERBOX # 6861 RADIOBOX # \_\_\_\_\_ DIGITAL # \_\_\_\_\_  
 LEASE LINES \_\_\_\_\_ INCREASE \_\_\_\_\_ REVERSE \_\_\_\_\_  
 MASTERBOX LOCATION Middle Garage Entrance

OTHER	ITEM	LOCATION
TYPE <u>Edwards System EST 2</u> KEY # <u>45</u>	CONTROL BOX	<u>Edwards</u>
RESET PROCEDURE FOR CONTROL	METER READING	<u>1-800-336-4206</u>
YES _____ NO _____	CHARGER-TIMER	
KEY # _____	FUSE OR DISCONNECT	
WET _____ DRY _____	BATTERIES	
GEL _____ NONE _____	EMERGENCY GENERATOR	
YES _____ NO _____	DRILL SWITCH	
KEY # _____	REGISTER TIME SWITCH	
YES _____ NO _____	REMOTE ANNUNCIATOR	
KEY # _____	REMOTE TROUBLE SIGNAL	
YES _____ NO _____		

OTHER	DEVICE	VOLTS	AMPS	MFG#	MOD #
HORN	BELL	CHIME	AUDIBLE SIGNAL		
LAMP #			VISUAL SIGNAL		
			DOOR HOLDER		
			COMBO SMOKE/DOOR HOLDER		
FUSE OR DISCONNECT LOCATION	POWERED	IN-LINE	SINGLE STATION SMOKES		
	POWERED	IN-LINE	SYSTEM SMOKES		
	POWERED	IN-LINE	DUCT SMOKES		

RESET PROCEDURES FOR SMOKES \_\_\_\_\_  
 HEAT DETECTORS SPECIAL TYPES SIGA - HFS 1356 FIX Temp

SPRINKLERS WET \_\_\_\_\_ DRY \_\_\_\_\_ RETARD: YES \_\_\_\_\_ NO \_\_\_\_\_ TIME TO ALARM \_\_\_\_\_  
 END OF LINE LOCATION \_\_\_\_\_ AIR PSI \_\_\_\_\_  
 CITY PSI \_\_\_\_\_ HOUSE PSI \_\_\_\_\_ WATERFLOW MOTOR GONG: YES \_\_\_\_\_ NO \_\_\_\_\_  
 ELECTRIC BELL: YES \_\_\_\_\_ NO \_\_\_\_\_ GATE TAMPERS: YES \_\_\_\_\_ NO \_\_\_\_\_  
 SUPERVISORY PANEL LOCATION \_\_\_\_\_

WATERFLOW ALARM 2" DRAIN PSI \_\_\_\_\_  
 GATE TAMPERS: YES \_\_\_\_\_ NO \_\_\_\_\_  
 DATA CARD \_\_\_\_\_





**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**Maria L. Baldwin School**  
**28 Sacramento Street**  
**Cambridge, MA 02139**

**Date of test: 9/09/2010**

**7/08/2010**

**FACP - F.C.I.**

**Model - 7100**

**Addressable**



**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X		All OK
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X		OK
Load Voltage	--	X		OK
<b>Transient Suppressors</b>	--	--		None Installed
<b>Remote Annunciator</b> --	--	--		N/A
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b> X		X		Elevator Recall is working

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 09/09/2010**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
L1S17	Smoke Photo	Ground Floor Mechanical	9-Sep	Pass
L1S20	Smoke Photo	Ground Floor Elevator Lobby	9-Sep	Pass
L1S28	Smoke Photo	Ground Floor Electrical Room	9-Sep	Pass
L1S26	Thermal Det	Ground Floor Mechanical	9-Sep	Pass
L1S27	Thermal Det	Ground Floor Mechanical	9-Sep	Pass
L1M24	Pull Station	Ground Floor Corridor by Café	9-Sep	Pass
L117	Pull Station	Ground Floor Corridor Stairway 3	9-Sep	Pass
L1M37	Pull Station	1st Floor Stairway 3	9-Sep	Pass
L1M18	Pull Station	Ground Floor Gym	9-Sep	Pass
L1M20	Pull Station	Ground Floor Gym	9-Sep	Pass
L1M19	Pull Station	Ground Floor Gym	9-Sep	Pass
L1M21	Pull Station	Ground Floor Stage	9-Sep	Pass
		Ground Floor boys room strobe not working	9-Sep	Fail
L2S36	Smoke Photo	4th Floor Mechanical Room	9-Sep	Pass
	Tamper			
L2M22	Switch	3rd Floor Stairway 6	9-Sep	Pass
	Tamper			
L2M30	Switch	4th Floor Stairway 6	9-Sep	Pass
	Tamper			
L1M06	Switch	1st Floor by Elevator	9-Sep	Pass
	Tamper			
L1M10	Switch	1st Floor by Stairway 4	9-Sep	Pass
	Tamper			
L1M03	Switch	1st Floor Pump Room	9-Sep	Pass
	Tamper	1st Floor Pump Room - Main Control		
L1M03	Switch	Valve	9-Sep	Pass
	Tamper	1st Floor Pump Room - Main Control		
L1M03	Switch	Valve	9-Sep	Pass
	Tamper	1st Floor Pump Room - Main Control		
L1M03	Switch	Valve	9-Sep	Pass
		Testing Ebu Units and Exit Signs	9-Sep	Pass
L2S33	Smoke Photo	Computer Lab 4th Floor	8-Jul	Pass
L2S38	Smoke Photo	4th Floor Stairway 6	8-Jul	Pass
L2S35	Smoke Photo	4th Floor Library	8-Jul	Pass
L2S34	Smoke Photo	4th Floor Library	8-Jul	Pass
L2S30	Smoke Photo	4th Floor 402A	8-Jul	Pass
L2S29	Smoke Photo	4th Floor Faculty Restroom	8-Jul	Pass
L2S28	Smoke Photo	4th Floor Faculty Restroom	8-Jul	Pass
L2S27	Smoke Photo	4th Floor Corridor by Rm 401	8-Jul	Pass
L2M32	Pull Station	4th Floor Library	8-Jul	Pass
L2S32	Smoke Photo	4th Floor Elevator Lobby	8-Jul	Pass
		Elevator Recall is working OK	8-Jul	Pass
L2M23	Pull Station	4th Floor Elevator Lobby	8-Jul	Pass

L2S13	Smoke Photo	3rd Floor Stairway 1	8-Jul	Pass
L2M14	Pull Station	3rd Floor Elevator Lobby	8-Jul	Pass
L2S15	Smoke Photo	3rd Floor Corridor by Rm 304	8-Jul	Pass
L2S16	Smoke Photo	3rd Floor by Restrooms	8-Jul	Pass
L2S17	Smoke Photo	3rd Floor Girls Restroom	8-Jul	Pass
L2S18	Smoke Photo	3rd Floor Boys Restroom	8-Jul	Pass
L2S19	Smoke Photo	3rd Floor Corridor by Rm 312	8-Jul	Pass
L2T20	Thermal Det	3rd Floor Electrical Rm	8-Jul	Pass
L2S20	Smoke Photo	3rd Floor Corridor by rm 307	8-Jul	Pass
L2S23	Smoke Photo	3rd Floor Corridor by Rm 308	8-Jul	Pass
L2S22	Smoke Photo	3rd Floor Corridor by Rm 310	8-Jul	Pass
L2M20	Pull Station	3rd Floor Corridor by RM 208	8-Jul	Pass
L2S24	Smoke Photo	3rd Floor Corridor by stairway 6	8-Jul	Pass
L2S25	Smoke Photo	3rd Floor Corridor by Stairway 4	8-Jul	Pass
L2S12	Smoke Photo	2nd Floor Stairway 4	8-Jul	Pass
L2S11	Smoke Photo	2nd Floor Corridor by Rm 208	8-Jul	Pass
L2M08	Pull Station	2nd Floor by Stairway 4	8-Jul	Pass
L2S10	Smoke Photo	2nd Floor corridor by Rm 208	8-Jul	Pass
L2S09	Smoke Photo	2nd Floor corridor by Rm 210	8-Jul	Pass
L2S07	Smoke Photo	2nd Floor corridor by Rm 207	8-Jul	Pass
L2S06	Smoke Photo	2nd floor corridor by Rm 212	8-Jul	Pass
L2T08	Thermal Detect	2nd Floor Electrical Rm	8-Jul	Pass
L2S04	Smoke Photo	2nd Floor Corridor by restrooms	8-Jul	Pass
L2S05	Smoke Photo	2nd Floor Boys Restroom	8-Jul	Pass
L2S03	Smoke Photo	2nd Floor Girls Restroom	8-Jul	Pass
L2S02	Smoke Photo	2nd Floor Corridor by Rm 204	8-Jul	Pass
L2M01	Pull Station	2nd Floor Elevator Lobby	8-Jul	Pass
L1M01	Pull Station	1st Floor Main Entrance	8-Jul	Pass
L1S03	Smoke Photo	1st Floor Corridor by custodian	8-Jul	Pass
L1T01	Thermal Det	1st Floor Main Electric Rm	8-Jul	Pass
L1S02	Smoke Photo	1st Floor Corridor Electric Rm	8-Jul	Pass
L1S07	Smoke Photo	1st Floor Corridor Main Lobby	8-Jul	Pass
L1S08	Smoke Photo	1st Floor Corridor Main Office	8-Jul	Pass
L1S14	Smoke Photo	1st Floor Copy Rm	8-Jul	Pass
L1S09	Smoke Photo	1st Floor Corridor by Rm 102	8-Jul	Pass
L1M29	Pull Station	1st Floor Rm 102	8-Jul	Pass
L1S34	Smoke Photo	1st Floor hallway by Rm 106	8-Jul	Pass
L1M30	Pull Station	1st Floor Rm 104	8-Jul	Pass
L1S11	Smoke Photo	1st Floor Hallway	8-Jul	Pass
L1S12	Smoke Photo	1st Floor Stairway 4	8-Jul	Pass
L1M08	Pull Station	1st Floor Corridor by Stairway 4	8-Jul	Pass
L1S10	Smoke Photo	1st Floor Hall by Gym	8-Jul	Pass
L1M11	Pull Station	1st Floor Side Entrance	8-Jul	Pass
L1T05	Thermal Det	1st Floor Sprinkler Pump Rm	8-Jul	Pass
L1S18	Smoke Photo	Ground Floor Elevator Lobby	8-Jul	Pass
L1S33	Smoke Photo	Ground Floor Cafeteria	8-Jul	Pass
L1S32	Smoke Photo	Ground Floor Cafeteria	8-Jul	Pass
L1S30	Smoke Photo	Ground Floor Cafeteria	8-Jul	Pass
L1S31	Smoke Photo	Ground Floor Cafeteria	8-Jul	Pass
L1S29	Smoke Photo	Ground Floor Gym Lobby	8-Jul	Pass

L1S22	Smoke Photo	Ground Floor Boys Rm	8-Jul	Pass
L1S21	Smoke Photo	Ground Floor Girls Rm	8-Jul	Pass
L1S23	Smoke Photo	Ground Floor Corridor by Bath rm	8-Jul	Pass
L1S24	Smoke Photo	Ground Floor Corridor by Gym	8-Jul	Pass

**Name of Inspector:** William Tinker

**Organization:** City of Cambridge School Department

**Date:** September 9, 2010

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
Cambridge Port Elementary School  
89 Elm Street  
Cambridge, MA 02139**

**Date of test: 10/21/2010  
10/20/2010  
FACP - F.C.I.**

**Model - 7100**

**Addressable**



### Prior to Any Testing

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X	All OK	
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X	OK	
Load Voltage	--	X	OK	
<b>Transient Suppressors</b>	--	--	None Installed	
<b>Remote Annunciator</b> --	--		N/A	
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b>	X	X		No Elevator Recall at this time

### Initiating and Supervisory Device Tests and Inspections

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 10/ 21/2010**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

<u>Address</u>	<u>Type</u>	<u>Description</u>	<u>Tested</u>
L1/01	Smoke Detector	Main Electric Room - Basement	Pass
L1/02	Smoke Detector	Boy's Rest Room - Basement	Pass
L1/03	Smoke Detector	Corridor by Boiler Room - Basement	Pass
L1/04	Smoke Detector	Corridor by Music Room - Basement	Pass
L1/05	Smoke Detector	Corridor by Men's Rest Room - Basement	Pass
L1/06	Smoke Detector	OT / PT Room Rear - Basement	Pass
L1/07	Smoke Detector	OT / PT Room Office - Basement	Pass
L1/08	Smoke Detector	Art Storage - Basement	Pass
L1/09	Smoke Detector	Music Room 62 - Basement	Pass
L1/10	Heat Detector	Heat Detector Emergency Generator Room - Basement	Pass
L1/11	Smoke Detector	Art Room 64 - Basement	Pass
L1/12	Smoke Detector	Art Room Office - Basement	Pass
L1/13	Smoke Detector	Custodian Room - Basement	Pass
L1/14	Smoke Detector	Custodian Room - Basement	Pass
L1/15	Smoke Detector	Girl's Rest Room - Basement	Pass
L1/16	Smoke Detector	Corridor by Art Room - Basement	Pass
L1/17	Smoke Detector	Front Stairs - Basement - Basement	Pass
L1/18	Smoke Detector	Elevator Lobby - Basement	Pass
L1/20	Smoke Detector	Equipment Mechanical Room - Basement	No Coverage
L1/22	Smoke Detector	Front Stairs - Ground Floor	Pass
L1/23	Smoke Detector	Room 9A - Ground Floor	Pass
L1/24	Smoke Detector	Elevator Lobby - Ground Floor	Pass
L1/25	Smoke	Cafeteria - Ground Floor	Pass

	Detector Smoke		
L1/26	Detector Smoke	Cafeteria - Ground Floor	Pass
L1/27	Detector Smoke	Kindergarten Office - Ground Floor	Pass
L1/28	Detector Smoke	Kindergarten Room 1 - Ground Floor	Pass
L1/29	Detector Smoke	Kindergarten Room 1 - Ground Floor	Pass
L1/30	Detector Smoke	Kindergarten Room 2 - Ground Floor	Pass
L1/31	Detector Smoke	Kindergarten Room 2 - Ground Floor	Pass
L1/32	Detector Smoke	Corridor by Room 3 - Ground Floor	Pass
L1/33	Detector	Kitchen Storage - Ground Floor	Pass
L1/34	Heat Detector	Kitchen - Ground Floor	Pass
L1/35	Heat Detector	Kitchen - Ground Floor	Pass
L1/38	Detector Smoke	Storage Room 3 - Ground Floor	Pass
L1/39	Detector Smoke	Elevator Lobby - Gym	Pass
L1/40	Detector Smoke	Elevator Lobby - 1st Floor	Pass
L1/41	Detector Smoke	Front Stairs - 1st Floor	Pass
L1/42	Detector Smoke	Corridor by Room 105A - 1st Floor	Pass
L1/43	Detector Smoke	Corridor by Room 102 - 1st Floor	Pass
L1/44	Detector Smoke	Corridor by Room 103 - 1st Floor	Pass
L1/45	Detector Smoke	Corridor by Room 100A - 1st Floor	Pass
L1/46	Detector Smoke	Classroom 100 - 1st Floor	Pass
L1/47	Detector Smoke	Office by Classroom 101 - 1st Floor	Pass
L1/48	Detector Smoke	Classroom 101 - 1st Floor	Pass
L1/49	Detector Smoke	Classroom 103 - 1st Floor	Pass
L1/50	Detector Smoke	Classroom 103 - 1st Floor	Pass
L1/51	Detector Smoke	Classroom 103A - 1st Floor	Pass
L1/52	Detector Smoke	Classroom 102B - 1st Floor	Pass
L1/53	Detector Smoke	Classroom 102 - 1st Floor	Pass
L1/55	Detector Smoke	Classroom 105 - 1st Floor	Pass
L1/56	Detector	Classroom 105 Electric Room - 1st Floor	Pass

L1/57	Smoke Detector	Classroom 105A - 1st Floor	Pass
L1/58	Smoke Detector	Classroom 104 Office- 1st Floor	Pass
L1/59	Smoke Detector	Classroom 104 - 1st Floor	Pass
L1/60	Smoke Detector	Elevator Machine Room - Ground Floor	Pass
L1/61	Smoke Detector	Corridor by Playground Exit- Ground Floor	Pass
L1/62	Smoke Detector	Front Stairs - Gym Floor	Pass
L1/63	Smoke Detector	Classroom 200A - 2nd Floor	Pass
L1/64	Smoke Detector	Classroom 200 - 2nd Floor	Pass
L1/65	Smoke Detector	Corridor by Class Room 203 - 2nd Floor	Pass
L1/66	Smoke Detector	Classroom 201 - 2nd Floor	Pass
L1/67	Smoke Detector	Music Storage Room - Basement	Pass
L1/68	Smoke Detector	Classroom 205 - 2nd Floor	Pass
L1/69	Smoke Detector	Corridor by Class Room 205 - 2nd Floor	Pass
L1/70	Smoke Detector	Corridor by Class Room 207 - 2nd Floor	Pass
L1/71	Smoke Detector	Front Stairs - 2nd Floor	Pass
L1/72	Smoke Detector	Corridor by Front Stairs - 2nd Floor	Pass
L1/73	Smoke Detector	Elevator Lobby - 2nd Floor	Pass
L1/75	Smoke Detector	Conference Room 202A - 2nd Floor	Pass
L1/76	Smoke Detector	Classroom 205 - 2nd Floor	Pass
L1/77	Smoke Detector	Classroom 202 - 2nd Floor	Pass
L1/78	Smoke Detector	Classroom 202 - 2nd Floor	Pass
L1/79	Smoke Detector	Classroom 204 - 2nd Floor	Pass
L1/80	Smoke Detector	Classroom 204A - 2nd Floor	Pass
L1/81	Smoke Detector	Classroom 207 - 2nd Floor	Pass
L1/82	Smoke Detector	Classroom 207A - 2nd Floor	Pass
L1/83	Smoke Detector	Girl's Office - Gym Floor	Pass
L1/84	Smoke Detector	Nurse's Office - 2nd Floor	Pass
L1/85	Smoke Detector	Ceiling Front Left - Gym	Pass

L1/86	Smoke Detector	Ceiling Front Center - Gym	Pass
L1/87	Smoke Detector	Ceiling Front Right - Gym	Pass
L1/88	Smoke Detector	Ceiling Rear Right - Gym	Pass
L1/89	Smoke Detector	Ceiling Rear Center - Gym	Pass
L1/90	Smoke Detector	Ceiling Rear Left - Gym	Pass
L1/91	Smoke Detector	Girl's Locker Room - Gym	Pass
L1/92	Smoke Detector	Girl's Rest Room - Gym	Pass
L1/93	Smoke Detector	Boy's Locker Room - Gym	Pass
L1/94	Smoke Detector	Boy's Rest Room - Gym	Pass
L1/95	Smoke Detector	Stage - Gym	Pass
L1/96	Smoke Detector	Storage Room Right - Gym	Pass
L1/97	Smoke Detector	Storage Room Left - Gym	Pass
L1/98	Smoke Detector	Rear Stair Exit - Gym	Pass
L1/99	Detector	Room 208 - Gym	Pass
L1/101	Pull Station	Corridor by Rear Stair - Basement Floor	Pass
L1/102	Monitor Module	Boiler Room Fixed Heat Detectors - Basement	Pass
L1/103	Pull Station	Emergency Exit - Basement Floor	Pass
L1/104	Pull Station	Corridor by Art Room - Basement Floor	Pass
L1/105	Pull Station	Kitchen Exit - Ground Floor	Pass
L1/106	Pull Station	By Main Office - Ground Floor	Pass
L1/107	Monitor Module	Kitchen Ansel System - Ground Floor	Pass
L1/108	Pull Station	Front Stairs - 1st Floor	Pass
L1/109	Pull Station	Rear Stairs - 1st Floor	Pass
L1/110	Pull Station	Front Stairs - 2nd Floor	Pass
L1/111	Pull Station	Rear Stairs - 2nd Floor	Pass
L1/112	Pull Station	Rear Stairs - Gym	Pass
L1/113	Pull Station	Front Wall - Gym	Pass
L1/114	Pull Station	Conference Room 9A - Ground Floor	Pass
L1/116	Pull Station	Art Room - Basement	Pass
L1/118	Pull Station	Custodian Room - Basement	Pass
L1/119	Pull Station	Lobby Exit to Playground	Pass
L1/120	Pull Station	Kindergarten Room 1 - Ground Floor	Pass
L1/121	Pull Station	Cafeteria Exit - Ground Floor	Pass
L1/122	Control Relay	Elevator Primary Recall Relay	Pass
L1/123	Control Relay	Elevator Secondary Recall Relay	Pass
L2		LOOP 2	
L2 /01	Smoke Detector	Elevator Lobby - 3rd Floor	Pass

L2/02	Smoke Detector	Front Stairs - 3rd Floor	Pass
L2/03	Smoke Detector	Corridor by Girl's Rest Room - 3rd Floor	Pass
L2/04	Smoke Detector	Corridor by Classroom 304 - 3rd Floor	Pass
L2/05	Smoke Detector	Library - 3rd Floor	Pass
L2/06	Smoke Detector	Library - 3rd Floor	Pass
L2/07	Smoke Detector	Classroom 301 - 3rd Floor	Pass
L2/08	Smoke Detector	Corridor by Classroom 300 - 3rd Floor	Pass
L2/09	Smoke Detector	Classroom 300A - 3rd Floor	Pass
L2/10	Smoke Detector	Corridor by Classroom 303 - 3rd Floor	Pass
L2/11	Smoke Detector	Classroom 303 - 3rd Floor	Pass
L2/12	Smoke Detector	Classroom 303 - 3rd Floor	Pass
L2/13	Smoke Detector	Library Office - 3rd Floor	Pass
L2/14	Smoke Detector	Classroom 305 - 3rd Floor	Pass
L2/15	Smoke Detector	Classroom 304 - 3rd Floor	Pass
L2/16	Smoke Detector	Classroom 300 - 3rd Floor	Pass
L2/17	Smoke Detector	Storage Classroom 305 - 3rd Floor	Pass
L2/18	Smoke Detector	Classroom 301A - 3rd Floor	Pass
L2/19	Smoke Detector	Classroom 305 Electric Room - 3rd Floor	Pass
L2/20	Smoke Detector	Rear Stair - 3rd Floor	Pass
L2/21	Smoke Detector	Elevator Lobby - 2.5 Floor	Pass
L2/22	Smoke Detector	Office 307 - 2.5 Floor	Pass
L2/23	Smoke Detector	Office 308 - 2.5 Floor	Pass
L2/24	Smoke Detector	Office 306 - 2.5 Floor	Pass
L2/25	Smoke Detector	Office 306 - 2.5 Floor	Pass
L2/101	Pull Station	Library Exit - 3rd Floor	Pass
L2/ 102	Monitor Module	Main Water Flow Switch - Basement	Failed
L2/103	Monitor Module	Duct Smoke Mechanical Room - Basement	Pass
L2/104	Monitor Module	Duct Smoke Ceiling HOA's - Gym	Pass
L2/105	Pull Station	Front Stairs - 2.5 Floor	Pass

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** October 21, 2010

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
Graham and Parks Elementary School  
44 Linnaen Street  
Cambridge, MA 02139**

**Date of test: 7/21/2010  
FACP**

**Model - FCI - 7100**

**Addressable**



**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b> --	--	--	NA
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	No Elevator Recall at this time

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete:**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
		1st Floor Area		
L1M02	Manual Station	Pull Station by Conference Office 1st Floor	21-Jul	Pass
L1M02	Manual Station	Pull Station by Nurse Office 1st Floor Hall	21-Jul	Pass
L1M01	Manual Station	1st Floor Pull Station by Rm 104	21-Jul	Pass
L1M03	Manual Station	1st Floor Pull Station in Café	21-Jul	Pass
L1M06	Manual Station	1st Floor Pull Station by Art Rm and Boiler Rm Stairs	21-Jul	Pass
L1M03	Manual Station	1st Floor Gym by Playground door	21-Jul	Pass
L1M03	Manual Station	1st Floor Gym Double Door by Foyer	21-Jul	Pass
L1M05	Manual Station	1st Floor Pull Station by Rm 109	21-Jul	Pass
		2nd Floor Area		
L1M05	Manual Station	2nd Floor Pull Station by Rm 224	21-Jul	Pass
L1M02	Manual Station	2nd Floor Pull Station by Library	21-Jul	Pass
L1M02	Manual Station	2nd Floor Pull Station by Rm 218B	21-Jul	Pass
L1M01	Manual Station	2nd Floor Pull Station by Rm 213	21-Jul	Pass
L1M04	Manual Station	Basement Pull Station Boiler Rm	21-Jul	Pass
		All Horn / Strobes work OK	21-Jul	Pass
		Batteries Ok	21-Jul	Pass

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** July 21, 2010

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
Haggerty Elementary School  
110 Cushing Street  
Cambridge, MA 02139**

**Date of test: 4/13/2011**

**FACP - F.C.I.**

**Model - 7100**

**Addressable**



### Prior to Any Testing

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X	All OK	
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X	OK	
Load Voltage	--	X	OK	
<b>Transient Suppressors</b>	--	--	None Installed	
<b>Remote Annunciator</b>	--	--	<b>OK</b>	
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b>	X	X		Elevator Recall is working

### Initiating and Supervisory Device Tests and Inspections

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 04/13/2011**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
L1M36	Pull Station	Basement Boiler Room	13-Apr-11	Pass
L1S41	Thermal Det	Over Boilers Basement	13-Apr-11	Pass
L1S42	Thermal Det	Over Basement Compressor	13-Apr-11	Pass
L1S40	Smoke Photo	Basement Gen Trans Room	13-Apr-11	Pass
L1S39	Smoke Photo	Basement Electric Room	13-Apr-11	Pass
L1S36	Smoke Photo	Basement at Cafeteria	13-Apr-11	Pass
L1S44	Thermal Det	Over Kitchen Sink	13-Apr-11	Pass
L1S47	Smoke Photo	1st Floor Right Rear Stairs	13-Apr-11	Pass
L1S43	Thermal Det	Kitchen Stove	13-Apr-11	Pass
L1S45	Thermal Det	Kitchen Refrigerator	13-Apr-11	Pass
L1M37	Tamper Sw	Main A Tamper Switch Sprinkler Rm Base	13-Apr-11	Pass
L1S37	Smoke Photo	Basement L14 Electric Room	13-Apr-11	Pass
L1S49	Smoke Photo	Basement Stair # 2	13-Apr-11	Pass
L1S34	Smoke Photo	Basement Custodian Office	13-Apr-11	Pass
L1S48	Smoke Photo	Basement Stair # 1	13-Apr-11	Pass
L1S46	Smoke Photo	1st Floor Left Rear Stairs	13-Apr-11	Pass
L1M34	Pull Station	Basement Stair # 2	13-Apr-11	Pass
L1M32	Pull Station	Basement Stair # 1	13-Apr-11	Pass
L1M33	Pull Station	Basement Left Rear Stairs	13-Apr-11	Pass
L1M35	Pull Station	Basement Right Rear Stairs	13-Apr-11	Pass
L1M38	Tamper Sw	Main B Tamper Switch Sprinkler Rm Base 1st Floor Area	13-Apr-11	Pass
L1S25	Smoke Photo	1st Floor Left Rear Hall	13-Apr-11	Pass
L1S24	Smoke Photo	1st Floor Left Rear Hall	13-Apr-11	Pass
L1M55	Pull Station	1st Floor Room # 109	13-Apr-11	Pass
L1S51	Smoke Photo	1 st Floor Left Rear Hall	13-Apr-11	Pass
L1M21	Pull Station	1st Floor Room # 108	13-Apr-11	Pass
L1S23	Smoke Photo	1st Floor Lawn Street Exit	13-Apr-11	Pass
L1S26	Smoke Photo	1st Floor Left Center Stairs	13-Apr-11	Pass
L1M20	Pull Station	1st Floor Lawn Street	13-Apr-11	Pass
L1S29	Smoke Photo	1st Floor Right Center Stair	13-Apr-11	Pass
L1S16	Smoke Photo	1st Floor Stair # 1	13-Apr-11	Pass
L1S50	Smoke Photo	1st Floor R Rear Hall	13-Apr-11	Pass
L1M25	Pull Station	1st Floor Play Ground Exit	13-Apr-11	Pass
L1M23	Pull Station	1st Floor Room # 110	13-Apr-11	Pass
L1S21	Smoke Photo	1st Floor Stair # 2	13-Apr-11	Pass

L1S30	Smoke Photo	1st Floor R Rear Hall	13-Apr-11	Pass
L1S31	Smoke Photo	1st Floor R Rear Hall	13-Apr-11	Pass
L1M56	Pull Station	1st Floor Room # 111	13-Apr-11	Pass
L1M24	Pull Station	1st Floor Room # 111	13-Apr-11	Pass
L1S18	Smoke Photo	1st Floor Basement Stair # 1	13-Apr-11	Pass
L1M18	Pull Station	1st Floor Room # 102	13-Apr-11	Pass
L1M19	Pull Station	1st Floor Room # 103	13-Apr-11	Pass
L1S22	Smoke Photo	1st Floor Basement Stair # 2	13-Apr-11	Pass
L1S20	Smoke Photo	1st Floor by Stair # 2	13-Apr-11	Pass
L1M16	Pull Station	1st Floor Stair # 1	13-Apr-11	Pass
L1S19	Smoke Photo	1st Floor by Teachers Lounge	13-Apr-11	Pass
L1M17	Pull Station	1st Floor Stair # 2	13-Apr-11	Pass
L1S17	Smoke Photo	1st Floor by Stair # 1	13-Apr-11	Pass
L1S32	Smoke Photo	1st Floor Play Ground Exit	13-Apr-11	Pass
L1M17	Pull Station	1 <sup>st</sup> Floor by room 103	13-Apr-11	Pass
		2nd Floor Area		
L1S09	Smoke Photo	2nd Floor Stair # 1	13-Apr-11	Pass
L1S10	Smoke Photo	2nd Floor by Stair # 1	13-Apr-11	Pass
L1S12	Smoke Photo	2nd Floor Front Desk	13-Apr-11	Pass
L1M10	Pull Station	2nd Floor by Stair # 1	13-Apr-11	Pass
L1S11	Smoke Photo	2nd Floor Main Lobby	13-Apr-11	Pass
L1M12	Pull Station	2nd Floor Stair # 2	13-Apr-11	Pass
L1S15	Smoke Photo	2nd Floor Stair # 2	13-Apr-11	Pass
L1S14	Smoke Photo	2nd Floor by Rm 213	28-Apr-11	Pass
L1M15	Pull Station	2nd Floor front lobby	28-Apr-11	Pass
		3rd Floor Area		
L1S08	Smoke Photo	3rd Floor by Stair # 2	13-Apr-11	Pass
L1M09	Pull Station	3rd Floor Stair # 2	13-Apr-11	Pass
L1S06	Smoke Photo	3rd Floor Stair # 1	13-Apr-11	Pass
L1M08	Pull Station	3rd Floor Stair # 1	13-Apr-11	Pass
		4th Floor Area		
L1S01	Smoke Photo	4th Floor top of Stair # 1	13-Apr-11	Pass
L1M01	Pull Station	4th Floor Stair # 1	13-Apr-11	Pass
L1S02	Smoke Photo	Librarians Desk	13-Apr-11	Pass
L1S04	Smoke Photo	A/V Office 4th Floor	13-Apr-11	Pass
L1M02	Pull Station	4th Floor Stair # 2	13-Apr-11	Pass
L1S05	Smoke Photo	4th Floor Stair # 2	13-Apr-11	Pass
		All Horns / Strobes / Speakers working	13-Apr-11	Pass
		EBU, Exit Signs & Remote Heads Ok	13-Apr-11	Fail
		Need to add EBU added on each floor		
		Generator needs work		
		Batteries are OK 33AmpHR 2	13-Apr-11	Pass
		Elevator Recall working properly	13-Apr-11	Passed

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** April 13, 2011

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
High School Extension  
15 Upton Street  
Cambridge, MA 02139**

**Date of test: 5/11/2011  
FACP**

**Model - Notifier Panel 4800**

**Conventional Hard Wire**

Panel Manufacturer: Notifier                      Model Number: 4800-2  
Monitoring Entity:                                      Approving Agency:  
   Cambridge Fire Department  
Type Transmission:                                      Account /Master box #: 3621

Circuit Styles: Class -A, NAC-Style-B  
Number of Addressable Loops: 2  
Number of Conventional Loops:

Last Date System Had Any Service performed: February 2010

#### Alarm Initiating Devices and Circuit Information

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
33	6	Photo Electric Smoke
11	6	Heat Detectors
11	6	Manual Stations
0	6	Duct Smoke
0	6	Monitor Module

#### Alarm Indicating Appliances and Circuit Information

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
1	B	Nac Boosters
6	B	Mini horns
21	B	Electronic Horn/Strobe
0	B	Strobe only
0	B	Exterior Beacon
0	B	Speaker/ Strobes

Number of Notification Appliance Circuits: 2  
Are Circuits Supervised? Yes

#### Main FACP System Power Supply

Primary: 120 Volts, 20 Amps  
Over Current Protection: Circuit Breaker  
Location: Panel in Main Electric Rm  
Secondary: 2- Storage Batteries, 12-Amp Hour's, 12 Volts DC  
Calculated to Operate System: in 24 Hours  
Batteries located: Main Electric Rm

**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK

**Secondary Power**

Battery Condition	X	X	OK
Load Voltage	--	X	OK

**Transient Suppressors** -- -- None Installed

**Remote Annunciator**-- -- OK

**Notification Appliances**

Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate

**Interface Equipment** X X No Elevator Recall at this time

Trouble Light on both Horn Strobes Circuits but system is working properly. A new system is scheduled to be installed in 2012.

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 5/11/2011**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Type	Description	Tested	Pass/Fail
Pull Station	Basement by Boiler Room	11-May	Passed
Heat Detector	Basement Room 003	11-May	Passed
Heat Detector	Basement Room 003	11-May	Passed
Heat Detector	Basement Boiler Room	11-May	Passed
Heat Detector	Basement Boiler Room	11-May	Passed
Heat Detector	Basement Boiler Room	11-May	Passed
Heat Detector	Basement Boiler Room	11-May	Passed
Pull Station	Basement Hallway by Room 001	11-May	Passed
Photo Smoke	Basement Hallway by Room 001	11-May	Passed
Photo Smoke	Basement Hallway by Room 010	11-May	Passed
Photo Smoke	Basement Hallway by Room 002	11-May	Passed
Photo Smoke	Basement Cafeteria	11-May	Passed
Heat Detector	Basement Room 009	11-May	Passed
Heat Detector	Basement Kitchen Area	11-May	Passed
Heat Detector	Basement Kitchen Area	11-May	Passed
Heat Detector	Basement Room 008	11-May	Passed
Pull Station	1st Floor Hallway by Room 107	11-May	Passed
Photo Smoke	1st Floor Hallway by Room 107	11-May	Passed
Photo Smoke	1st Floor Hallway by Room 108	11-May	Passed
Photo Smoke	1st Floor Rear Vestibule Area	11-May	Passed
Photo Smoke	1st Floor Main Front Stairs	11-May	Passed
Photo Smoke	1st Floor Front Vestibule Area	11-May	Passed
Pull Station	1st Floor Hallway by Room 106	11-May	Passed
Photo Smoke	1st Floor Hallway by Room 103	11-May	Passed
Photo Smoke	1st Floor Gym Area	11-May	Passed
Photo Smoke	1st Floor Gym Area	11-May	Passed
Photo Smoke	1st Floor Gym Area	11-May	Passed
Photo Smoke	1st Floor Gym Area	11-May	Passed
Pull Station	1st Floor Gym Stage Area	11-May	Passed
Heat Detector	1st Floor Gym Back Hall	11-May	Passed
Photo Smoke	1st Floor Gym Storage Area	11-May	Passed
Pull Station	1st Floor Back Exit Stairs of Gym	11-May	Passed
Photo Smoke	1st Floor Back Exit Stairs of Gym	11-May	Passed
Photo Smoke	1st Floor Back Exit Top of Stairs	11-May	Passed
Photo Smoke	1st Floor Hall going to Gym	11-May	Passed
Photo Smoke	1st Floor Hall by Preschool	11-May	Passed
Photo Smoke	Office	11-May	Passed
Pull Station	1st Floor Hall by Room 103	11-May	Passed
Photo Smoke	1st Floor Hall by Room 103	11-May	Passed
Pull Station	2nd Floor Hall by Room 203	11-May	Passed
Photo Smoke	2nd Floor Hall by Room 203	11-May	Passed

Photo Smoke	2nd Floor Hall by Room 207	11-May	Passed
Photo Smoke	2nd Floor Hall by Room 208	11-May	Passed
Pull Station	2nd Floor Hall by Room 215	11-May	Passed
Photo Smoke	2nd Floor Hall by Room 215	11-May	Passed
Photo Smoke	2nd Floor in Room 218 Library	11-May	Passed
Photo Smoke	2nd Floor in Room 218 Library	11-May	Passed
Photo Smoke	3rd Floor Top of Stairs	11-May	Passed
Pull Station	3rd Floor Hall by Room 309	11-May	Passed
Photo Smoke	3rd Floor Hall by Room 309	11-May	Passed
Photo Smoke	3rd Floor Hall by Room 306	11-May	Passed
	3rd Floor in Room 306 Science		
Photo Smoke	Rm	11-May	Passed
Photo Smoke	3rd Floor Hall by Room 305	11-May	Passed
Photo Smoke	3rd Floor Hall by Room 303	11-May	Passed
Pull Station	3rd Floor Hall by Room 304	11-May	Passed
	3rd Floor Top of Stairs by Rm		
Photo Smoke	302	11-May	Passed

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** May 11, 2011

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**Kennedy Longfellow School**  
**158 Spring Street**  
**Cambridge, MA 02139**

**Date of test: May 16, 2011**  
**May 17, & 18<sup>th</sup> 2011**

**FACP – F.C.I.**

**Model – 7100**

**Addressable**

**Panel Manufacturer:** F.C.I.                      **Model Number:** 7100  
**Monitoring Entity:**                              **Approving Agency:**  
Cambridge Fire Department  
**Type Transmission:**                              **Account /Master box #:** 1911

**Circuit Styles:** SLCs - Class -B, NAC-Style-B  
**Number of Addressable Loops:** 2  
**Number of Conventional Loops:**

**Last Date System Had Any Service preformed:** April 2010

#### **Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
131	4	Photo Electric Smoke
28	4	Heat Detectors
34	4	Manual Stations
6	4	Duct Smoke
0	4	Monitor Module

#### **Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
4	B	Nac Boosters
0	B	Mini horns
55	B	Electronic Horn/Strobe
35	B	Strobe only
1	B	Exterior Beacon
0	B	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 16  
**Are Circuits Supervised?** Yes

#### **Main FACP System Power Supply**

Primary: 120 Volts, 20 Amps  
Over Current Protection: Circuit Breaker 1P 20A  
Location: Main Entrance Vestibule  
Secondary: 2- Storage Batteries, 12-Amp Hour's, 12 Volts DC  
Calculated to Operate System: in 24 Hours

Batteries located: In Panel

### Prior to Any Testing

#### Notifications Are Made:

Building Occupants Yes

Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b> --	--	--	N/A
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b> X		X	

### Initiating and Supervisory Device Tests and Inspections

On/Off Premises Monitoring:

## Notification That Testing Is Complete: 05/18/2011

Building Occupants Yes  
Building Management Yes

This Testing Was Done In Accordance With Applicable NFPA Standards.

Address	Type	Description	Tested	Pass/Fail
L1S48	Photo Smoke	2nd Floor by Art Rm	18-May	Passed
L1S64	Thermal Det	2nd Floor Kiln Rm in Art Rm	18-May	Passed
L1S49	Photo Smoke	2nd Floor by Auditorium	18-May	Passed
L1S50	Photo Smoke	2nd Floor by Rm 215	18-May	Passed
L1S67	Thermal Det	2nd Floor Science Lab	18-May	Passed
L1S68	Thermal Det	2nd Floor Science Lab	18-May	Passed
L1S69	Photo Smoke	2nd Floor Science Lab	18-May	Passed
L1M15	Pull Station	2nd Floor by Rm 215	18-May	Passed
L1S60	Photo Smoke	2nd Floor in Room 215	18-May	Passed
L1S61	Photo Smoke	2nd Floor in Room 215	18-May	Passed
L1S62	Photo Smoke	2nd Floor in Room 215	18-May	Passed
L1S63	Photo Smoke	2nd Floor in Room 215	18-May	Passed
L1S51	Photo Smoke	2nd Floor by Gym Entry	18-May	Passed
L1S52	Thermal Det	2nd Floor Mechanical Rm	18-May	Passed
L1S57	Duct Detector	2nd Floor Mechanical Rm Unit 4	18-May	Passed
L1S44	Photo Smoke	Gym Hall Mini Gyms	18-May	Passed
L1M11	Pull Station	Gym Main Hall	18-May	Passed
L1S53	Thermal Det	2nd Floor Mechanical Rm	18-May	Passed
L1S45	Photo Smoke	Gym Hall Mini Gyms	18-May	Passed
L1S58	Duct Detector	2nd Floor Mechanical Rm Unit 5	18-May	Passed
L1S59	Duct Detector	2nd Floor Mechanical Rm Unit 6	18-May	Passed
L1S54	Thermal Det	2nd Floor Mechanical Rm	18-May	Passed
L1S40	Photo Smoke	Gym Hall by Janitors Closet	18-May	Passed
L1S55	Thermal Det	2nd Floor Mechanical Rm	18-May	Passed
L1S41	Photo Smoke	Gym Janitors Closet	18-May	Passed
L1S56	Duct Detector	2nd Floor Mechanical Rm Unit 3	18-May	Passed
L1S42	Photo Smoke	Gym Mens Toilet	18-May	Passed
L1S43	Photo Smoke	Gym Womens Rm	18-May	Passed
L1S39	Photo Smoke	Gym Hall by Womens Locker Rm	18-May	Passed
L1S36	Photo Smoke	Gym Womens Locker Rm	18-May	Passed
L1S38	Photo Smoke	Gym Womens Locker Rm	18-May	Passed
L1S37	Photo Smoke	Gym Womens Toilet	18-May	Passed
L2M09	Pull Station	2nd Floor Service Stairs	18-May	Passed
L2S46	Photo Smoke	2nd Floor by Room 222	18-May	Passed
L2S34	Photo Smoke	2nd Floor Service Stairs	18-May	Passed
L2S48	Photo Smoke	2nd Floor in Room 221	18-May	Passed
L2S47	Photo Smoke	2nd Floor by Room 225	18-May	Passed
L2S49	Photo Smoke	2nd Floor in Room 221	18-May	Passed
L2S51	Photo Smoke	Gym Mens Locker Rm	18-May	Passed
L2S50	Photo Smoke	2nd Floor in Room 222	18-May	Passed
L2S52	Photo Smoke	Gym Mens Locker Rm	18-May	Passed

L2S53	Photo Smoke	Gym Hall Right Exit	18-May	Passed
L2M10	Pull Station	Gym Hall Right Exit	18-May	Passed
L2M12	Pull Station	1st Floor Service Exit	18-May	Passed
L2M07	Pull Station	1st Floor Rear Service Door	18-May	Passed
L2S30	Photo Smoke	1st Floor Rear Service Storage	18-May	Passed
L2S28	Thermal Det	Boiler Room	18-May	Passed
L2S27	Thermal Det	Boiler Room	18-May	Passed
L2S25	Thermal Det	Boiler Room	18-May	Passed
L2S26	Thermal Det	Boiler Room	18-May	Passed
L2S29	Photo Smoke	Maintenance Storage Rm	18-May	Passed
L2S31	Photo Smoke	Storage Rm G105	18-May	Passed
L2M08	Pull Station	Transportation Department	18-May	Passed
L2S33	Photo Smoke	Transportation Department	18-May	Passed
L2S32	Photo Smoke	Transportation Department	18-May	Passed
L2S64	Thermal Det	Parking Lot Stock Rm	18-May	Passed
L2S61	Photo Smoke	Hall by Service Rm	18-May	Passed
L2S60	Photo Smoke	Hall by Cafeteria	18-May	Passed
L2S24	Photo Smoke	Storage Rm G104	18-May	Passed
L2M05	Pull Station	1st Floor Cargo Door	18-May	Passed
L2S23	Photo Smoke	Service Mens Room	18-May	Passed
L2S59	Photo Smoke	Hall by Cafeteria	18-May	Passed
L2S23	Photo Smoke	Service Mens Room	18-May	Passed
L2S62	Photo Smoke	Auditorium Hall Right Side	17-May	Passed
L2M13	Pull Station	Auditorium Exit Right Side	17-May	Passed
L2S08	Photo Smoke	Auditorium Right Stage	17-May	Passed
L2S07	Photo Smoke	Auditorium Right Stage	17-May	Passed
L2S06	Photo Smoke	Auditorium Center Stage	17-May	Passed
L2S05	Photo Smoke	Auditorium Left Stage	17-May	Passed
L2M03	Pull Station	Auditorium Rear Stage	17-May	Passed
L2M02	Pull Station	Auditorium Right Door Exit	17-May	Passed
L2M01	Pull Station	Auditorium Left Door Exit	17-May	Passed
L1M13	Pull Station	1st Floor Hall by Rm 101	17-May	Passed
L1M01	Pull Station	1st Floor in Rm 101	17-May	Passed
L1S27	Photo Smoke	Room 101 Storage Closet	17-May	Passed
L1S10	Photo Smoke	Hall by Rm 102	17-May	Passed
L1M02	Pull Station	Room 102	17-May	Passed
L1S23	Photo Smoke	Room 102 Closet	17-May	Passed
L1S09	Photo Smoke	Hall by Rm 103	17-May	Passed
L1M03	Pull Station	In Room 103	17-May	Passed
L1S30	Photo Smoke	Room 103 Closet	17-May	Passed
L1M04	Pull Station	Room 104	17-May	Passed
L1S08	Photo Smoke	Hall by Rm 104	17-May	Passed
L1S06	Photo Smoke	Hall by Rm 106	17-May	Passed
L1S31	Photo Smoke	Room 104 Closet	17-May	Passed
L1M05	Pull Station	Room 105	17-May	Passed
L1S29	Photo Smoke	Room 105 Closet	17-May	Passed
L1S07	Photo Smoke	Lobby by Rm 105	17-May	Passed
L1M06	Pull Station	Exit by Rm 106	17-May	Passed
L1M07	Pull Station	Room 106	17-May	Passed
L1S28	Photo Smoke	Room 106 Closet	17-May	Passed

L1M08	Pull Station	Room 107	17-May	Passed
L1S26	Photo Smoke	Room 107 Closet	17-May	Passed
L1S05	Photo Smoke	Hall by Rm 107	17-May	Passed
L1S04	Photo Smoke	Hall by Rm 108	17-May	Passed
L1M09	Pull Station	Room 108	17-May	Passed
L1S24	Photo Smoke	1st Floor Teachers Rm	17-May	Passed
L1S25	Photo Smoke	1st Floor Teachers Bathroom	17-May	Passed
L1M10	Pull Station	Room 109	17-May	Passed
L1S20	Photo Smoke	Room 109 Closet	17-May	Passed
L1S05	Photo Smoke	Hall by Rm 107	17-May	Passed
L1S22	Photo Smoke	Room 108 Closet	17-May	Passed
L1S33	Photo Smoke	Room 109-A	17-May	Passed
L1M12	Pull Station	Hall by Rm 110	17-May	Passed
L1M11	Pull Station	Room 110	17-May	Passed
L1S18	Photo Smoke	Room 110 Closet	17-May	Passed
L1S02	Photo Smoke	Hall by Rm 110	17-May	Passed
L1S32	Photo Smoke	Room 102-A	17-May	Passed
L1S21	Photo Smoke	Activity Rm Closet	17-May	Passed
L1S03	Photo Smoke	Hall by Rm 109	17-May	Passed
L1S15	Photo Smoke	Main Hall Entrance	17-May	Passed
L2M04	Pull Station	Main Entrance	17-May	Passed
L1S16	Photo Smoke	Hall by Guidance Office	17-May	Passed
L2S09	Photo Smoke	Music Rm Storage	17-May	Passed
L2S11	Thermal Det	Industrial Arts Rm	17-May	Passed
L2S10	Thermal Det	Industrial Arts Rm	17-May	Passed
L2S56	Thermal Det	Industrial Arts Storage Rm	17-May	Passed
L2S55	Thermal Det	Tool Rm Industrial Arts	17-May	Passed
L2M06	Pull Station	Cafeteria	17-May	Passed
L2S57	Photo Smoke	Cafeteria Left Side	17-May	Passed
L2S58	Photo Smoke	Cafeteria Right Side	17-May	Passed
L2S12	Thermal Det	Kitchen Front Line Left	17-May	Passed
L2S17	Thermal Det	Kitchen Area	17-May	Passed
L2S20	Thermal Det	Kitchen Area	17-May	Passed
L2S17	Thermal Det	Kitchen Area	17-May	Passed
L2S20	Thermal Det	Kitchen Area	17-May	Passed
L2S15	Thermal Det	Kitchen Area	17-May	Passed
L2S14	Thermal Det	Kitchen Pot Washing Rm	17-May	Passed
L2S13	Thermal Det	Kitchen Dishwashing Rm	17-May	Passed
L2S21	Photo Smoke	Kitchen Office Area	17-May	Passed
L2S22	Photo Smoke	Kitchen Office Area	17-May	Passed
L2S19	Photo Smoke	Kitchen Womens Rm	17-May	Passed
L2S16	Photo Smoke	Kitchen Storage Rm	17-May	Passed
L2S18	Photo Smoke	Kitchen Storage Rm	17-May	Passed
L2M04	Pull Station	Main Entrance	16-May	Passed
L2M14	Pull Station	Main Entry Foyer	16-May	Passed
L2S01	Photo Smoke	1st Floor Mens Rm	16-May	Passed
L2S02	Photo Smoke	1st Floor Girls Rm	16-May	Passed
L1S12	Photo Smoke	1st Floor Hall by Elevator Rm	16-May	Passed
L1S17	Thermal Det	Janitors Closet by Rm 111	16-May	Passed
L1S34	Photo Smoke	Elevator Storage Rm	16-May	Passed

L1S01	Photo Smoke	1st Floor Hall by Rm 111	16-May	Passed
L1S11	Photo Smoke	1st Floor Hall by Rm 101	16-May	Passed
L1S19	Photo Smoke	Elevator Machine Rm	16-May	Passed
L2S04	Photo Smoke	1st Floor Copier Rm	16-May	Passed
L1S14	Photo Smoke	Hall by Liaison Office	16-May	Passed
L1S13	Photo Smoke	Main Hall by Bathroom	16-May	Passed
L2S03	Photo Smoke	1st Floor Guidance Office	16-May	Passed
L1M18	Pull Station	Penthouse Mechanical Room	16-May	Passed
L1S83	Duct Detector	ACC2 Penthouse	16-May	Passed
L1S77	Thermal Det	Penthouse Mechanical Room	16-May	Passed
L1S82	Duct Detector	ACC1 Penthouse	16-May	Passed
L1S79	Thermal Det	Penthouse Mechanical Room	16-May	Passed
L2M20	Pull Station	3rd Floor by Elevator	16-May	Passed
L2S79	Photo Smoke	3rd Floor Elevator Recall	16-May	Passed
L2S80	Thermal Det	3rd Floor Janitors Closet	16-May	Passed
L2S95	Photo Smoke	3rd Floor by Rm 301	16-May	Passed
L2S81	Photo Smoke	3rd Floor by Rm 317	16-May	Passed
L2S96	Photo Smoke	3rd Floor Girls Rm	16-May	Passed
L2S94	Photo Smoke	3rd Floor by Rm 303	16-May	Passed
L2S97	Photo Smoke	3rd Floor Boys Rm	16-May	Passed
L2S92	Photo Smoke	3rd Floor by Rm 307	16-May	Passed
L2M19	Pull Station	3rd Floor by 307	16-May	Passed
L2S91	Photo Smoke	3rd Floor by Rm 308	16-May	Passed
L2S93	Photo Smoke	3rd Floor by Rm 304	16-May	Passed
L2S90	Photo Smoke	3rd Floor by Rm 309	16-May	Passed
L2M18	Pull Station	3rd Floor Hallway by Rm 311	16-May	Passed
L2S89	Photo Smoke	3rd Floor by Rm 310	16-May	Passed
L2S88	Photo Smoke	3rd Floor by Rm 311	16-May	Passed
L2S83	Photo Smoke	3rd Floor by Rm 314	16-May	Passed
L2S84	Photo Smoke	3rd Floor by Rm 312	16-May	Passed
L2S85	Photo Smoke	3rd Floor Teachers Lounge	16-May	Passed
L2S87	Photo Smoke	3rd Floor Teachers Men Rm	16-May	Passed
L2S78	Photo Smoke	Storage Rm 317	16-May	Passed
L2S82	Photo Smoke	3rd Floor by Rm 316	16-May	Passed
L2S86	Photo Smoke	3rd Floor Teachers Ladies Rm	16-May	Passed
L1S47	Photo Smoke	2nd Floor Elevator Recall	16-May	Passed
L1S66	Photo Smoke	2nd Floor Storage Rm 215	16-May	Passed
L1S70	Thermal Det	2nd Floor Janitors Closet	16-May	Passed
L1S35	Photo Smoke	2nd Floor by Rm 220	16-May	Passed
L1S72	Photo Smoke	2nd Floor Girls Rm	16-May	Passed
L1S36	Photo Smoke	2nd Floor Mens Rm	16-May	Passed
L1S71	Photo Smoke	2nd Floor Mens Rm	16-May	Passed
L1S37	Photo Smoke	2nd Floor by Rm 202	16-May	Passed
L1S38	Photo Smoke	2nd Floor by Rm 204	16-May	Passed
L1M16	Pull Station	2nd Floor by Rm 205	16-May	Passed
L1S40	Photo Smoke	2nd Floor by Rm 206	16-May	Passed
L1S39	Photo Smoke	2nd Floor by Rm 205	16-May	Passed
L1S41	Photo Smoke	2nd Floor by Rm 207	16-May	Passed
L1M17	Pull Station	2nd Floor by Rm 209	16-May	Passed
L1S42	Photo Smoke	2nd Floor by Rm 208	16-May	Passed

L1S43	Photo Smoke	2nd Floor by Rm 209	16-May	Passed
L1S75	Photo Smoke	2nd Floor Teachers Mens Rm	16-May	Passed
L1S76	Photo Smoke	2nd Floor Teachers Womens Rm	16-May	Passed
L1S74	Photo Smoke	2nd Floor Teachers Lounge	16-May	Passed
L1S45	Photo Smoke	2nd Floor by Rm 212	16-May	Passed
L1S46	Photo Smoke	2nd Floor by Rm 213	16-May	Passed
L1S44	Photo Smoke	2nd Floor by Rm 210	16-May	Passed
L1S73	Photo Smoke	2nd Floor by Rm 203A	16-May	Passed
L1S80	Photo Smoke	2nd Floor Library	16-May	Passed
L1S81	Photo Smoke	2nd Floor Library	16-May	Passed

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** May 18, 2011

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
King Open School  
850 Cambridge Street  
Cambridge, MA 02139**

**Date of test: April 19 & 20, 2011**

**FACP – F.C.I.**

**Model – 7100**

**Addressable**

**Panel Manufacturer:** F.C.I.                      **Model Number:** 7100  
**Monitoring Entity:**                                **Approving Agency:**  
    **Cambridge Fire Department**  
**Type Transmission:**                                **Account /Master box #:** 2171

**Circuit Styles:** SLCs - Class -A, NAC-Style-A  
**Number of Addressable Loops:** 2  
**Number of Conventional Loops:**

**Last Date System Had Any Service performed:**

**Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
50	6	Photo Electric Smoke
6	6	Heat Detectors
27	6	Manual Stations
0	6	Duct Smoke
2	6	Monitor Module

**Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
1	A	Nac Boosters
0	A	Mini horns
41	A	Electronic Horn/Strobe
19	A	Strobe only
1	A	Exterior Beacon
0	A	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 6  
**Are Circuits Supervised?** Yes

**Main FACP System Power Supply**

Primary: 120 Volts, 20 Amps  
 Over Current Protection: Circuit Breaker 1P 20A  
 Location: Main Electric Room  
 Secondary: 2- Storage Batteries, 12-Amp Hour's, 12 Volts DC  
 Calculated to Operate System: in 24 Hours  
 Batteries located: In Panel

**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b> --	--	--	N/A
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b> X		X	Elevator Recall Passed

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 04/20/2011**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
	Smoke			
L1S16	Photo	2nd Floor Stairway 1	19-Apr	pass
L1M07	Pull Station	2nd Floor Corridor by Stairway 1	19-Apr	pass
	Smoke			
L1S17	Photo	2nd Floor Corridor by room 202	19-Apr	pass
	Smoke			
L1S15	Photo	2nd Floor Corridor by Rm 203	19-Apr	pass
	Smoke			
L1S14	Photo	2nd Floor Corridor by Rm 206	19-Apr	pass
	Smoke			
L1S18	Photo	2nd Floor Corridor by Rm 209	19-Apr	pass
	Smoke			
L1S19	Photo	2nd Floor Corridor by Rm 211 <sup>8</sup>	19-Apr	pass
	Smoke			
L1S20	Photo	2nd Floor Stairway 2	19-Apr	pass
L1M08	Pull Station	2nd Floor Corridor by Stairway 2	19-Apr	pass
	Smoke			
L1S13	Photo	2nd Floor Corridor by Girl's Rm	19-Apr	pass
	Smoke			
L1S04	Photo	2nd Floor Lobby Elevator Smoke	19-Apr	pass
	Smoke			
L1S05	Photo	2nd Floor Stairway 3	19-Apr	pass
	Smoke			
L1S06	Photo	2nd Floor Corridor by Rm 213	19-Apr	pass
	Smoke			
L1S07	Photo	2nd Floor Corridor by Rm 215	19-Apr	pass
	Smoke			
L1S08	Photo	2nd Floor Corridor by Rm 216	19-Apr	pass
	Smoke			
L1S09	Photo	2nd Floor Stairway 4	19-Apr	pass
L1M05	Pull Station	2nd Floor by Stairway 4	19-Apr	pass
	Smoke			
L1S10	Photo	2nd Floor Corridor by Rm 219	19-Apr	pass
	Smoke			
L1S11	Photo	2nd Floor Corridor by Rm 220	19-Apr	pass
L1M06	Pull Station	2nd Floor Corridor by Stairway 5	19-Apr	pass
	Smoke			
L1S12	Photo	2nd Floor Stairway 5	19-Apr	pass
L2M18	Pull Station	1st Floor Loading Dock	19-Apr	pass
	Smoke			
L2S26	Photo	1st Floor Corridor by Loading Dock	19-Apr	pass
	Smoke			
L2S24	Photo	1st Floor Corridor by Kitchen	19-Apr	pass
	Smoke			
L2S21	Photo	1st Floor Corridor to Gym	19-Apr	pass
L2M14	Pull Station	1st Floor Gym Left Exit	19-Apr	pass

L2M16	Pull Station	1st Floor Gym Right Exit	19-Apr	pass
L2M17	Pull Station	1st Floor Boys Locker Room	19-Apr	pass
	Smoke			
L2S20	Photo	1st Corridor to Gym/ Café	19-Apr	pass
L2M13	Pull Station	1st Floor Corridor to Café	19-Apr	pass
L2M06	Pull Station	1st Floor Corridor to Kindergarten	19-Apr	pass
	Smoke			
L2S14	Photo	1st Floor Corridor to Kindergarten	19-Apr	pass
L2M11	Pull Station	1st Floor Corridor by Rm K-1	19-Apr	pass
	Smoke			
L2S16	Photo	1st Floor Corridor by Rm K-2	19-Apr	pass
L2M12	Pull Station	1st Floor Stairway # 5	19-Apr	pass
	Smoke			
L2S18	Photo	1st Floor Corridor by Room 118	19-Apr	pass
	Smoke			
L2S13	Photo	1st Floor Corridor by Stairway # 4	19-Apr	pass
	Smoke			
L2S11	Photo	1st Floor Corridor By Rm 110	19-Apr	pass
L2M05	Pull Station	1st Floor Elevator Lobby	19-Apr	pass
	Smoke			
L2S10	Photo	1st Floor Corridor by Restroom	19-Apr	pass
L2M01	Pull Station	1st Floor Stairway # 2	19-Apr	pass
	Smoke			
L2S06	Photo	1st Floor Stairway # 2	19-Apr	pass
	Smoke			
L2S04	Photo	1st Floor Corridor by Rm 106	19-Apr	pass
	Smoke			
L2S02	Photo	1st floor Corridor by Rm 101	19-Apr	pass
L2M25	Pull Station	1st floor Main Lobby	19-Apr	pass
	Smoke			
L2S35	Photo	1st floor Main Lobby	19-Apr	pass
L2M24	Pull Station	1st Floor Auditorium Exit	19-Apr	pass
L2M23	Pull Station	1st Floor Auditorium Exit	19-Apr	pass
L2M22	Pull Station	1st Floor Auditorium	19-Apr	pass
L2M19	Pull Station	1st Floor Stage Right	19-Apr	pass
L2M20	Pull Station	1st Floor Stage Left	19-Apr	pass
	Smoke			
L2S31	Photo	1st Floor Corridor by Café	19-Apr	pass
	Smoke			
L2S28	Photo	1st Floor Cafeteria	19-Apr	pass
L2M03	Pull Station	1st Floor Library Entrance	19-Apr	pass
	Smoke			
L2S09	Photo	1st Floor Library	19-Apr	pass
	Smoke			
L2S01	Photo	1st floor Corridor by Office	20-Apr	pass
	Smoke			
L2S03	Photo	1st Floor Corridor by Rm 103	20-Apr	pass
	Smoke			
L2S05	Photo	1st Floor Corridor by Rm 108	20-Apr	pass
L2M04	Pull Station	1st Floor in Room 108	20-Apr	pass
	Smoke			
L2S01	Photo	1st Floor Lobby Elevator Recall	20-Apr	pass
	Smoke			
L1S03	Photo	Elevator Machine Room	20-Apr	pass

L2S12	Smoke Photo	1st Floor by Room 112	20-Apr	pass
L2S17	Smoke Photo	1st Floor Corridor by Room 116	20-Apr	pass
L2S15	Smoke Photo	1st Floor Corridor by Room K-4	20-Apr	pass
L2M07	Pull Station	1st Floor Room K-4	20-Apr	pass
L2M08	Pull Station	1st Floor Room K-3	20-Apr	pass
L2M09	Pull Station	1st Floor in Room K-2	20-Apr	pass
L2M10	Pull Station	1st Floor in Room K-1	20-Apr	pass
L2S19	Smoke Photo	1st Floor Corridor to Café/Gym	20-Apr	pass
L2S23	Smoke Photo	1st Floor Corridor by Custodian-Office	20-Apr	pass
L2S25	Smoke Photo	1st Floor Corridor by Boiler Rm	20-Apr	pass
L2M21	Pull Station	1st Floor Boiler Room	20-Apr	pass
L2S22	Smoke Photo	1st Floor Corridor by Gym	20-Apr	pass
L2S29	Smoke Photo	1st Floor Corridor by Café	20-Apr	pass
L2S30	Photo	1st Floor Cafeteria	20-Apr	pass
L2M27	Module	Remote Zone Kitchen Heats	20-Apr	pass
L2S33	Smoke Photo	1st Floor Corridor By Stage	20-Apr	pass
L2S34	Smoke Photo	1st Floor Corridor by Lobby	20-Apr	pass

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** April 20, 2011

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**FLETCHER MAYNARD ACADEMY**  
**225 Windsor Street**  
**Cambridge, MA 02139**

**Date of test: 3/23/2011**

**FACP – Gamewell FCI**

**Model – 7100**

**Addressable**

**Panel Manufacturer:** Gamewell / FCI **Model Number:** 7100  
**Monitoring Entity:** **Approving Agency:**  
 Cambridge Fire Department  
**Type Transmission:** **Account /Master box #:** 2871

**Circuit Styles:** Class -B, NAC-Style-B  
**Number of Addressable Loops:** 2  
**Number of Conventional Loops:**

**Last Date System Had Any Service preformed:** Testing 2010

**Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
92	4	Photo Electric Smoke
5	4	Heat Detectors
18	4	Manual Stations
4	4	Duct Smoke
1	4	Monitor Module

**Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
2	B	Nac Boosters
0	B	Mini horns
43	B	Electronic Horn/Strobe
11	B	Strobe only
1	B	Exterior Beacon
0	B	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 8  
**Are Circuits Supervised?** Yes

**Main FACU System Power Supply**

Primary: 120 Volts, 20 Amps  
 Over Current Protection: Circuit Breaker  
 Location: Panel in Main Electrical Room  
 Secondary: 2- Storage Batteries, 12-Amp Hour's, 12 Volts DC  
 Calculated to Operate System: in 24 Hours  
 Batteries located: FACP

### Prior to Any Testing

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X	All OK	
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X	OK	
Load Voltage	--	X	OK	
<b>Transient Suppressors</b>	--	--	None Installed	
<b>Remote Annunciator</b> --	--		N/A	
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b>	X	X		Elevator Recall not available

### Initiating and Supervisory Device Tests and Inspections

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 3/23/2011 6:30 pm**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Type	Description	Tested	Pass/Fail
Photo Smoke	Vestibule Recall	23-Mar	Passed
Photo Smoke	Main Entrance Vestibule	23-Mar	Passed
Photo Smoke	Basement Elevator Smoke	23-Mar	Passed
Pull Station	3rd Floor by Room 312	23-Mar	Passed
Photo Smoke	Basement by room 004	23-Mar	Passed
Photo Smoke	Roof Entry by 312	23-Mar	Passed
Photo Smoke	3rd Floor stairs by 312	23-Mar	Passed
Photo Smoke	Basement Room 002	23-Mar	Passed
Photo Smoke	Basement by Stock room	23-Mar	Passed
Photo Smoke	3rd Floor Hall by 313	23-Mar	Passed
Photo Smoke	3rd Floor Hall by 314	23-Mar	Passed
Photo Smoke	Storage Room 313	23-Mar	Passed
Photo Smoke	3rd Floor hall by 307	23-Mar	Passed
Photo Smoke	3rd Floor Stairs by 309	23-Mar	Passed
Pull Station	3rd Floor by room 307	23-Mar	Passed
Photo Smoke	3rd Floor Hall by 306	23-Mar	Passed
Photo Smoke	3rd floor hall by 306	23-Mar	Passed
Photo Smoke	3rd floor hall by room 304	23-Mar	Passed
Photo Smoke	3rd floor hall by room 303	23-Mar	Passed
Photo Smoke	3rd floor hall by room 302	23-Mar	Passed
Photo Smoke	3rd floor elevator recall	23-Mar	Passed
Pull Station	3rd floor by room 303	23-Mar	Passed
Photo Smoke	3rd floor stairs by room 302	23-Mar	Passed
Photo Smoke	3rd floor Hall by room 315	23-Mar	Passed
Photo Smoke	Roof entry by room 301	23-Mar	Passed
Duct Smoke	Exhaust Mechanical Room 316	23-Mar	Passed
Photo Smoke	3rd floor mechanical room 316	23-Mar	Passed
Photo Smoke	3rd floor stairs by 301	23-Mar	Passed
Pull Station	3rd Floor by room 301	23-Mar	Passed
Photo Smoke	2nd Floor Storage Room 213	23-Mar	Passed
Pull Station	2nd Floor by room 212	23-Mar	Passed
Photo Smoke	2nd floor hall by room 211	23-Mar	Passed
Duct Smoke	HV-3 2nd Floor Mechanical Room 214	23-Mar	Passed
Photo Smoke	2nd Floor Storage room 214	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 214	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 210	23-Mar	Passed
Pull Station	2nd Floor by Library	23-Mar	Passed
Photo Smoke	2nd floor hall by room 207	23-Mar	Passed
Photo Smoke	2nd Floor Library right	23-Mar	Passed
Photo Smoke	2nd Floor Library middle	23-Mar	Passed
Photo Smoke	2nd Floor Library left	23-Mar	Passed

Photo Smoke	2nd Floor Library room 206	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 206	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 205	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 204	23-Mar	Passed
Photo Smoke	2nd Floor Hall by room 202	23-Mar	Passed
Pull Station	2nd Floor hall by room 204	23-Mar	Passed
Photo Smoke	2nd Floor Elevator recall	23-Mar	Passed
Photo Smoke	2nd Floor Data Closet	23-Mar	Passed
Photo Smoke	2nd Floor hall by room 219	23-Mar	Passed
Photo Smoke	2nd Floor Stair by room 201	23-Mar	Passed
Photo Smoke	2nd Floor Storage Room 220	23-Mar	Passed
Pull Station	2nd floor by room 219	23-Mar	Passed
Photo Smoke	1st Floor by room 110	23-Mar	Passed
Pull Station	1st Floor by Stage	23-Mar	Passed
Photo Smoke	1st Floor by Stage	23-Mar	Passed
Photo Smoke	1st Floor by Room 112	23-Mar	Passed
Pull Station	1st Floor by room 110	23-Mar	Passed
Photo Smoke	1st Floor by room 108	23-Mar	Passed
Photo Smoke	1st Floor by room 107	23-Mar	Passed
Pull Station	1st Floor by room 107	23-Mar	Passed
Photo Smoke	1st Floor hall by room 105	23-Mar	Passed
Photo Smoke	1st Floor Hall by room 104	23-Mar	Passed
Photo Smoke	1st Floor Hall by room 114	23-Mar	Passed
Photo Smoke	1st Floor room 113	23-Mar	Passed
Photo Smoke	1st Floor storage room 114	23-Mar	Passed
Photo Smoke	1st Floor hall by room 103	23-Mar	Passed
Photo Smoke	1st Floor hall by room 103	23-Mar	Passed
Pull Station	1st Floor by Elevator	23-Mar	Passed
Photo Smoke	1st Floor hall by room 101	23-Mar	Passed
Photo Smoke	1st Floor hall by gym doors	23-Mar	Passed
Photo Smoke	1st Floor hall by room 115	23-Mar	Passed
Photo Smoke	1st Floor Storage Room 115	23-Mar	Passed
Photo Smoke	1st Floor Elevator Recall	23-Mar	Passed
Pull Station	1st Floor hall by room 101	23-Mar	Passed
Heat Det	1st Floor Gym Storage	23-Mar	Passed
Duct Smoke	HV-3 Gym Storage Room	23-Mar	Passed
Photo Smoke	1st Floor Gym Office	23-Mar	Passed
Photo Smoke	1st Floor Gym Storage	23-Mar	Passed
Pull Station	Basement By Room 014	23-Mar	Passed
Duct Smoke	HV-1 Kitchen Mechanical Room	23-Mar	Passed
Photo Smoke	Basement floor by room 015	23-Mar	Passed
Photo Smoke	Basement Floor by room 018	23-Mar	Passed
Photo Smoke	Basement Floor by room 014	23-Mar	Passed
Thermal Dect	Basement Floor Mechanical Room by Kitchen	23-Mar	Passed
Photo Smoke	Basement Floor by room 110	23-Mar	Passed
Photo Smoke	Basement Floor by room 013	23-Mar	Passed
Photo Smoke	Basement Floor by kitchen	23-Mar	Passed
Pull Station	Basement Floor by Kitchen	23-Mar	Passed

Pull Station	Basement Exit by room 008	23-Mar	Passed
Photo Smoke	Basement Floor by art room	23-Mar	Passed
Photo Smoke	Basement Floor Storage Room 009	23-Mar	Passed
Photo Smoke	Basement Floor Cafeteria Right	23-Mar	Passed
Photo Smoke	Basement Floor Cafeteria Left	23-Mar	Passed
Photo Smoke	Basement Floor Cafeteria Stage	23-Mar	Passed
Photo Smoke	Basement Floor Room 008	23-Mar	Passed
Photo Smoke	Basement Floor art Room	23-Mar	Passed
Photo Smoke	Basement Floor Art Room	23-Mar	Passed
Pull Station	Basement Floor Art Room Exit	23-Mar	Passed
Photo Smoke	Basement Floor Cafeteria Right	23-Mar	Passed
Photo Smoke	Basement Floor Art Room Exit	23-Mar	Passed
Photo Smoke	Basement Floor by room 005	23-Mar	Passed
Photo Smoke	Basement Floor by Room 006	23-Mar	Passed
Photo Smoke	Basement Floor by Room 002	23-Mar	Passed
Photo Smoke	Basement Floor Cafeteria Left	23-Mar	Passed
Photo Smoke	Basement Floor Special K Room	23-Mar	Passed
Photo Smoke	Basement Floor Special K Room	23-Mar	Passed
Photo Smoke	Basement Floor by Room 020	23-Mar	Passed
Photo Smoke	Basement Floor Janitor Closet	23-Mar	Passed
Photo Smoke	Basement Floor Teachers Room 001	23-Mar	Passed
Thermal Dect	Basement Floor Mechanical Room by teachers room	23-Mar	Passed
Pull Station	Basement Floor Exit by room 004	23-Mar	Passed
Photo Smoke	Basement Elevator Machine Room	23-Mar	Passed
Photo Smoke	Basement Main Electric Room	23-Mar	Passed
Thermal Dect	Basement Floor Kitchen Area	23-Mar	Passed
Thermal Dect	Basement Floor Kitchen Area	23-Mar	Passed
Photo Smoke	Basement Floor Storage Room 002	23-Mar	Passed
Photo Smoke	1st Floor Room 112	23-Mar	Passed
Photo Smoke	1st Floor Room 112	23-Mar	Passed

**Name of Inspector:** William Tinker, William DiBease

**Organization:** City of Cambridge School Department

**Date:** March 23, 2011

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
Morse Elementary School  
40 Granite Street  
Cambridge, MA 02139**

**Date of test: 9/10/2011**

**FACP – Fire-Lite Alarms Inc**

**Model – MS 9600**

**Addressable**



### Prior to Any Testing

#### Notifications Are Made:

Building Occupants Yes  
Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>		--	-- None Installed
<b>Remote Annunciator</b>	--	--	N/A
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	

### Initiating and Supervisory Device Tests and Inspections

#### On/Off Premises Monitoring:

Notification That Testing Is Complete: 09/10/2011

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
1M001	Pull Station	Pull Station at FACP.	10-Sep	Passed
1M044	Pull Station	Classroom A1	10-Sep	Passed
1M045	Pull Station	Classroom A2	10-Sep	Passed
1D064	Smoke Detector	Corridor by room A1	10-Sep	Passed
1D063	Smoke Detector	Corridor by room A3	10-Sep	Passed
1M043	Pull Station	Classroom A3	10-Sep	Passed
1M046	Pull Station	Classroom A4	10-Sep	Passed
1D062	Smoke Detector	Corridor by room A4	10-Sep	Passed
1M042	Pull Station	Classroom A5	10-Sep	Passed
1M047	Pull Station	Classroom A6	10-Sep	Passed
1D061	Smoke Detector	Corridor by room A5	10-Sep	Passed
1D060	Smoke Detector	Corridor by room A5	10-Sep	Passed
1M014	Pull Station	By Exit Door 4 A wing	10-Sep	Passed
1D059	Smoke Detector	By Exit Door 4 A wing	10-Sep	Passed
1D065	Smoke Detector	Electrical Room A wing	10-Sep	Passed
1D066	Smoke Detector	Internet Closet A7	10-Sep	Passed
1D058	Smoke Detector	Corridor by Closet A7	10-Sep	Passed
1M040	Pull Station	Classroom B7 this should be B6	10-Sep	Passed
1M041	Pull Station	Classroom B6 this should be B7	10-Sep	Passed
1M039	Pull Station	Classroom B8	10-Sep	Passed
1M013	Pull Station	Door 3 B Wing	10-Sep	Passed
1D057	Smoke Detector	By Door # 3 B Wing	10-Sep	Passed
1D056	Smoke Detector	On ramp by Door 3 B Wing	10-Sep	Passed
1D055	Smoke Detector	Corridor by B3 B Wing	10-Sep	Passed
1D054	Smoke Detector	By exit Door 5 B wing	10-Sep	Passed
1M015	Pull Station	Corridor by Door 5 B wing	10-Sep	Passed
		Electrical Room B wing by B9	10-Sep	Failed
2M005	Supervisory Smoke	Tamper Switch in Preschool room D6	10-Sep	Passed
1D053	Smoke Detector	B Wing Corridor by room B9	10-Sep	Passed
1D052	Smoke Detector	B Wing Corridor by room C1	10-Sep	Passed

	Smoke			
1D051	Detector	C Wing Corridor by room C2	10-Sep	Passed
1M048	Pull Station	C wing in classroom C1	10-Sep	Passed
1M038	Pull Station	C wing in classroom C2	10-Sep	Passed
1M049	Pull Station	C wing in classroom C3	10-Sep	Passed
1M037	Pull Station	C wing in classroom C4	10-Sep	Passed
	Smoke			
1D050	Detector	C wing corridor by room C4	10-Sep	Passed
	Smoke			
1D049	Detector	C wing corridor by room C6	10-Sep	Passed
1M050	Pull Station	C wing in classroom C5	10-Sep	Passed
1M036	Pull Station	C wing in classroom C6	10-Sep	Passed
	Smoke			
2D026	Detector	D wing corridor lobby area	10-Sep	Passed
	Smoke			
2D038	Detector	D Wing Electrical Closet D2	10-Sep	Passed
	Smoke			
2D027	Detector	D Wing Corridor by Electrical Closet D2	10-Sep	Passed
	Smoke			
2D028	Detector	D Wing corridor by Room D4	10-Sep	Passed
	Smoke			
2D029	Detector	D Wing corridor by room D5	10-Sep	Passed
	Smoke			
2D030	Detector	D Wing corridor by exterior door #2	10-Sep	Passed
2M012	Pull Station	D Wing corridor by exterior door #2	10-Sep	Passed
2M035	Pull Station	D Wing in classroom D6	10-Sep	Passed
2M017	Pull Station	D Wing in Library Exterior Door Rear	10-Sep	Passed
2M016	Pull Station	D Wing Exterior Door # 6	10-Sep	Passed
	Smoke			
2D033	Detector	D Wing Corridor by Door # 6	10-Sep	Passed
	Smoke			
2D034	Detector	D Wing in Server Room D15	10-Sep	Passed
	Smoke			
2D032	Detector	D Wing corridor by room D9	10-Sep	Passed
	Smoke			
2D031	Detector	D Wing corridor by room D9	10-Sep	Passed
	Smoke			
2D025	Detector	D Wing corridor by room D7	10-Sep	Passed
	Smoke			
2D005	Detector	D Wing Electrical Closet D16	10-Sep	Passed
	Smoke			
2D024	Detector	D Wing Corridor by room D16	10-Sep	Passed
	Smoke			
2D039	Detector	D Wing in Boiler Room	10-Sep	Passed
	Smoke			
2D036	Detector	D Wing in Main Electrical Room D18	10-Sep	Passed
	Smoke			
2D037	Detector	D Wing generator room D19	10-Sep	Passed
2M034	Pull Station	D Wing in Boiler Room	10-Sep	Passed
2M011	Pull Station	D Wing in Generator Room D19	10-Sep	Passed
	Smoke			
2D022	Detector	D Wing in corridor by boiler room	10-Sep	Passed
	Smoke			
2D021	Detector	D Wing in corridor by room D33	10-Sep	Passed

2D020	Smoke Detector	D Wing in corridor by room D33	10-Sep	Passed
2D035	Smoke Detector	D Wing in Main Office room D34	10-Sep	Passed
2D023	Smoke Detector	D Wing in Main Office Nurse's Room	10-Sep	Passed
2D001	Smoke Detector	D Wing in Main Lobby	10-Sep	Passed
2D002	Smoke Detector	D Wing in Main Lobby	10-Sep	Passed
2M018	Pull Station Smoke	Gym Rear Door	10-Sep	Passed
2D003	Smoke Detector	D Wing Main Lobby	10-Sep	Passed
2M053	Pull Station	Side Gym Door	10-Sep	Passed
2M052	Pull Station	Side Gym Door	10-Sep	Passed
2M051	Pull Station Smoke	Gym Wall by Main Lobby	10-Sep	Passed
2D004	Smoke Detector	Main Corridor	10-Sep	Passed
2M007	Pull Station	Main Entrance	10-Sep	Passed
2M023	Pull Station Smoke	Auditorium Sound Room	10-Sep	Passed
2D040	Smoke Detector	Auditorium Sound Room	10-Sep	Passed
2M033	Pull Station	Auditorium Side entrance	10-Sep	Passed
2M024	Pull Station	Auditorium exit	10-Sep	Passed
2M022	Pull Station	Auditorium exit	10-Sep	Passed
2M070	Pull Station Smoke	Rear Auditorium Door	10-Sep	Passed
1D001	Detector	Custodian Room D44 Batteries Tested OK	10-Sep 10-Sep	Passed Passed
1M008	Pull Station	Pull Station by door # 9	10-Sep	Passed
1M009	Pull Station	Pull Station by Door # 7	10-Sep	Passed
1M020	Pull Station Smoke	Rear Cafeteria	10-Sep	Passed
1D005	Smoke Detector	D Wing in corridor by room D38	10-Sep	Passed
1D006	Smoke Detector	D Wing in corridor by room D 39	10-Sep	Passed
1D007	Smoke Detector	D Wing in corridor by room D42	10-Sep	Passed
1D008	Smoke Detector	D Wing in corridor by room D44	10-Sep	Passed
1M021	Pull Station Smoke	D Wing Trash room	10-Sep	Passed
1D017	Smoke Detector	D Wing Trash room	10-Sep	Passed
1D016	Smoke Detector	D Wing Kitchen Area	10-Sep	Passed
1D015	Smoke Detector	D Wing Kitchen Area	10-Sep	Passed
1D009	Smoke Detector	D Wing in corridor by D46	10-Sep	Passed
1D010	Smoke Detector	D Wing in corridor by D46	10-Sep	Passed
1D011	Smoke Detector	D Wing in corridor by D46	10-Sep	Passed
1D013	Smoke	D Wing in corridor by D46	10-Sep	Passed

	Detector			
	Smoke			
1D048	Detector	E Wing in corridor by room E1	10-Sep	Passed
1M031	Pull Station	E Wing in classroom E1	10-Sep	Passed
1M032	Pull Station	E Wing in classroom E2	10-Sep	Passed
1M030	Pull Station	E Wing in classroom E3	10-Sep	Passed
1M029	Pull Station	E Wing in classroom E5	10-Sep	Passed
1M026	Pull Station	E Wing in classroom E7	10-Sep	Passed
1M028	Pull Station	E Wing in classroom E6	10-Sep	Passed
1M027	Pull Station	E Wing in classroom E8	10-Sep	Passed
1M010	Pull Station	E Wing in corridor	10-Sep	Passed
1M011	Pull Station	E Wing in classroom E11	10-Sep	Passed
	Smoke			
1D047	Detector	E Wing in corridor by room E4	10-Sep	Passed
	Smoke			
1D003	Detector	E Wing in Electrical Closet E4	10-Sep	Fail
	Smoke			
1D046	Detector	E Wing in corridor by E4C	10-Sep	Passed
	Smoke			
1D045	Detector	E Wing in corridor by E6	10-Sep	Passed
	Smoke			
1D044	Detector	E Wing in corridor by E5	10-Sep	Passed
	Smoke			
1D043	Detector	E Wing in corridor by E9	10-Sep	Passed
	Smoke			
1D041	Detector	E Wing in corridor by E11	10-Sep	Passed
	Smoke			
1D042	Detector	E Wing in corridor by exit door E9	10-Sep	Passed
	Smoke			
1D002	Detector	E Wing in Internet Data Closet	10-Sep	Passed
		All Fire Doors Tested	10-Sep	Passed
		All Horn / Strobes working properly	10-Sep	Passed
		All Speaker Strobes working properly	10-Sep	Passed
		All Strobe only working properly	10-Sep	Passed
		Sprinkler System Tested	10-Sep	Passed
	Flow			
2M002	Switch	Waterflow Boiler Room Monitor	10-Sep	Passed
		Inspector Test valve E12 inside classroom Magazine Street		
2M002	Monitor	Flow Switch Boiler Room	10-Sep	Passed
		Inspectors Test valve Brookline Street		
2M003	Supervisory	Tamper Switch in boiler room main sprinkler	10-Sep	Passed
		Tamper Switch in boiler room for Brookline St		
2M003	Supervisory	Sprinkler shut off	10-Sep	Passed
		Tamper Switch in Boiler Room for Magazine St		
2M003	Supervisory	shut off	10-Sep	Passed
		Flow Switch Boiler Room For Brookline &		
2M002	Monitor	Magazine Street	10-Sep	Passed

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** September 10, 2011

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**PEABODY ELEMENTARY SCHOOL**  
**70 Rindge Avenue**  
**Cambridge, MA 02139**

**Date of test: 3/25/2011**  
**3/30 & 3/31/2011**

**FACP – AFC**

**Model – 600**

**Addressable**

**Panel Manufacturer:** Notifier / AFC **Model Number:** 600  
**Monitoring Entity:** **Approving Agency:**  
Cambridge Fire Department  
**Type Transmission:** **Account /Master box #:** 7321

**Circuit Styles:** Class -A, NAC-Style-B  
**Number of Addressable Loops:** 2  
**Number of Conventional Loops:**

**Last Date System Had Any Service performed:** Testing 2010

#### **Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
160	4	Photo Electric Smoke
5	4	Heat Detectors
47	4	Manual Stations
4	4	Duct Smoke
35	4	Monitor Module

#### **Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
5	B	Nac Boosters
0	B	Mini horns
0	B	Electronic Horn/Strobe
36	B	Strobe only
3	B	Exterior Beacon
113	A	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 20  
**Are Circuits Supervised?** Yes

#### **Main FACP System Power Supply**

Primary: 120 Volts, 20 Amps  
Over Current Protection: Circuit Breaker  
Location: Panel EP211 CB# 1 in Electrical Room A113  
Secondary: 2- Storage Batteries, 55-Amp Hour's, 12 Volts DC  
Calculated to Operate System: in 24 Hours

Batteries located: FACP

### Prior to Any Testing

#### Notifications Are Made:

Building Occupants Yes  
Building Management Yes

### System Tests and Inspections

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b>	--	--	<b>OK</b>
<b>Notification Appliances</b>			
Audible		--	X Speakers Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	Elevator Recall not available

### Initiating and Supervisory Device Tests and Inspections

#### On/Off Premises Monitoring:

**Notification That Testing Is Complete: 3/31/2011 6:30 pm**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Type	Description	Tested	Pass/Fail
Smoke Photo	Library Doors to D Wing	25-Mar	Pass
Pull Station	Library Exit Corridor	25-Mar	Pass
Smoke Photo	Library Room	25-Mar	Pass
Smoke Photo	Library Corridor by work rooms	25-Mar	Pass
Pull Station	Library by	25-Mar	Pass
Duct Smoke Module	RTU-1 Supply Side	25-Mar	Pass
Module	RTU-1 On	25-Mar	Pass
Module	RTU-1 Off	25-Mar	Pass
MM	Monitoring Module	25-Mar	Pass
Tamper Switch	Monitoring Module	25-Mar	Pass
Flow Switch	Monitoring Module	25-Mar	Pass
Pull Station	Library Corridor to D Wing	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Main Entrance	25-Mar	Pass
Pull Station	Library by Main Entrance Door	25-Mar	Pass
MM	Knox Box Library	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling	25-Mar	Pass
Smoke Photo	Library Ceiling smoke by	25-Mar	Pass
Smoke Photo	Library Ceiling smoke by	25-Mar	Pass
CM	Booster B5	25-Mar	Pass
CM	Booster B4	25-Mar	Pass
GATELY AREA			
Type	Description	Tested	Pass/Fail
Pull Station	Gately 1st Floor Stair # 7 Exit	25-Mar	Pass
Pull Station	Gately 1st Floor Main Entrance	25-Mar	Pass
MM	Knox Box Gately	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor by Game RM 122	25-Mar	Pass
Smoke Photo	Gately 1st Floor by Corridor by Rec RM 123	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor to Computer RES	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor by Stairway # 6	25-Mar	Pass
Smoke Photo	Gately 1st Floor by	25-Mar	Pass
Smoke Photo	Gately 1st Floor by	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor by Elevator Machine RM	25-Mar	Pass
Smoke Photo	Gately 1st Floor by Corridor by TV Rm 135	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor by TV Rm 135	25-Mar	Pass
Smoke Photo	Gately 1st Floor Corridor by TV Rm 135	25-Mar	Pass

Smoke Photo	Gately 1st Floor by Electrical Closet	25-Mar	Pass
Smoke Photo	Gately 1st Floor by Emergency Electrical Rm	25-Mar	Pass
MM	Flow Switch	25-Mar	Pass
MM	Tamper Switch	25-Mar	Pass
CM	Control Module Elevator Recall Secondary	25-Mar	Pass
CM	Control Module Elevator Recall Primary	25-Mar	Pass
Pull Station	Gately 1st Floor Exit by TV Lounge Rm 135	25-Mar	Pass
MM	ATS # 3 Start Control	25-Mar	Pass
MM	Generator	25-Mar	Pass
CM	Booster # 2 B2	25-Mar	Pass
Pull Station	Gately 2nd Floor Gym by Stair #7	25-Mar	Pass
Pull Station	Gately 2nd Floor Gym Exit	25-Mar	Pass
Pull Station	Gately 2nd Floor	25-Mar	Pass
Pull Station	Gately 2nd Floor Gym Entrance	25-Mar	Pass
Pull Station	Gately 2nd Floor Fitness Room by Exit	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Stairway # 7	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Corridor by Kitchen	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Corridor by Stairway # 6	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Stairway # 6	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Corridor by Gym Entrance	25-Mar	Pass
Smoke Photo	Gately 2nd Floor by	25-Mar	Pass
Smoke Photo	Gately 2nd Floor by	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Corridor by Gym Entrance	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Electrical RM G210	25-Mar	Pass
Smoke Photo	Gately 2nd Floor Corridor by Fitness 203	25-Mar	Pass
Duct Smoke	HV-5 Supply	25-Mar	Pass
CM	HV-5 On	25-Mar	Pass
CM	HV-5 OFF	25-Mar	Pass
MM	Flow Switch	25-Mar	Pass
MM	Tamper Switch	25-Mar	Pass
Pull Station	1st Floor B Wing Main Entrance	25-Mar	Pass
	School Area B Basement	30-Mar	
Type	Description	Tested	Pass/Fail
Control Module	CM Booster B1 Basement B Wing	30-Mar	Pass
Monitor Module	Booster B1 Basement B Wing	30-Mar	Pass
Heat Detector	Basement Boiler Room	30-Mar	Pass
Photo Smoke	Basement Boiler Rm Crawl Space Stair # 12	30-Mar	Pass
Photo Smoke	Basement Stairway # 12	30-Mar	Pass
Photo Smoke	Basement Boiler Rm Crawl Space Stair # 12	30-Mar	Pass
Heat Detector	Basement Boiler Room	30-Mar	Pass
Heat Detector	Basement Boiler Room	30-Mar	Pass
Tamper Switch	Tamper Switch Main Riser Basement tot of 7	30-Mar	Pass
Flow Switch	Flow Switch Main Riser Basement tot of 4	30-Mar	Pass
Pull Station	Basement Boiler Room Exit	30-Mar	Pass
	Basement Boiler Room Corridor by Janitor's		
Photo Smoke	Office	30-Mar	Pass
Photo Smoke	Basement Electrical / Generator Room	30-Mar	Pass
Photo Smoke	Basement Electrical / Generator Room	30-Mar	Pass
Photo Smoke	Basement Electrical / Generator Room	30-Mar	Pass
Photo Smoke	Basement Storage Room B04	30-Mar	Pass
Heat Detector	Basement Electrical / Generator Room	30-Mar	Pass

Heat Detector	Basement Electrical / Generator Room	30-Mar	Pass
Pull Station	Basement Electrical / Generator Room	30-Mar	Pass
	School Area B WING 1st Floor		
Type	Description	Tested	Pass/Fail
Control Module	Master Box 7321	30-Mar	Pass
Control Module	Controlling Door Holders B Wing	30-Mar	Pass
Control Module	1st Floor Drill Switch	30-Mar	Pass
Photo Smoke	1st Floor Corridor by Main Office	30-Mar	Pass
Photo Smoke	1st Floor Main Entrance Lobby	30-Mar	Pass
Pull Station	1st Floor Auditorium Entrance	30-Mar	Pass
Photo Smoke	1st Floor Main Entrance Lobby	30-Mar	Pass
Pull Station	1st Floor Main Entrance	30-Mar	Pass
Pull Station	1st Floor Main Entrance	30-Mar	Pass
Pull Station	1st Floor Auditorium Entrance	30-Mar	Pass
Pull Station	1st Floor Auditorium Exit	30-Mar	Pass
Pull Station	1st Floor Auditorium Stage Exit	30-Mar	Pass
Photo Smoke	1st Floor Auditorium Stage	30-Mar	Pass
Photo Smoke	1st Floor Auditorium Stage Storage	30-Mar	Pass
Pull Station	1st Floor Auditorium Stage Loading Dock	30-Mar	Pass
Photo Smoke	1st Floor Auditorium Stage	30-Mar	Pass
Pull Station	1st Floor Auditorium Stage to Music Rm	30-Mar	Pass
Photo Smoke	1st Floor Café Corridor to Music Room	30-Mar	Pass
Photo Smoke	1st Floor Doors A to B Wings	30-Mar	Pass
Photo Smoke	1st Floor Doors B to A Wings	30-Mar	Pass
Photo Smoke	1st Floor Doors B to A Wings	30-Mar	Pass
Photo Smoke	1st Floor Doors A to B Wings	30-Mar	Pass
Photo Smoke	1st Floor A wing Entrance to A Wing	30-Mar	Pass
Photo Smoke	1st Floor A wing Corridor by Stair #3/Cafe	30-Mar	Pass
Pull Station	1st Floor	30-Mar	Pass
Photo Smoke	1st Floor A wing Corridor by Stair # 3 by Café	30-Mar	Pass
Photo Smoke	1st Floor A Wing Corridor A to C wing	30-Mar	Pass
Photo Smoke	1st Floor A wing Corridor by Stair # 3 Ramp DN	30-Mar	Pass
Photo Smoke	1st Floor A wing Door Gym Corridors	30-Mar	Pass
	School Area A WING 1st Floor		
Type	Description	Tested	Pass/Fail
Photo Smoke	1st Floor	30-Mar	Pass
Photo Smoke	1st Floor Cafeteria Corridor by Kitchen	30-Mar	Pass
Photo Smoke	1st Floor Café Corridor by Kitchen Entrance	30-Mar	Pass
Pull Station	1st Floor Café Kitchen Exit	30-Mar	Pass
Pull Station	1st Floor Gym Exit	30-Mar	Pass
Pull Station	1st Floor Gym Lobby	30-Mar	Pass
Photo Smoke	1st Floor GYM Electric Closet 176A	30-Mar	Pass
Photo Smoke	1st Floor Administration Office FACP	30-Mar	Pass
Pull Station	1st Floor Gym Exit to Lobby	30-Mar	Pass
Photo Smoke	1st Floor Gym Lobby	30-Mar	Pass
Photo Smoke	1st Floor Corridor Human Services	30-Mar	Pass
Photo Smoke	1st Floor Corridor b Side Exit HS	30-Mar	Pass
Pull Station	1st Floor Corridor Exit H.S.	30-Mar	Pass
Photo Smoke	1st Floor Corridor by Computer Rm HS	30-Mar	Pass
Photo Smoke	1st Floor Corridor by Common Rm HS	30-Mar	Pass

Pull Station	1st Floor Exit by Family Center	30-Mar	Pass
Photo Smoke	1st Floor Gym Lobby	30-Mar	Pass
Photo Smoke	1st Floor Doors Gym Lobby	30-Mar	Pass
Photo Smoke	1st Floor Gym Door Lobby	30-Mar	Pass
Photo Smoke	1st Floor B wing Corridor by Guidance A110	30-Mar	Pass
Photo Smoke	1st Floor B Wing Corridor Administration Office	30-Mar	Pass
Photo Smoke	Administration Office	30-Mar	Pass
Photo Smoke	1st Floor A Wing Corridor A to C Wing	30-Mar	Pass
Photo Smoke	2nd Floor B Wing Door Stairs # 3	30-Mar	Pass
Photo Smoke	2nd floor B wing stairway #3	30-Mar	Pass
Photo Smoke	2nd floor B wing stairway #3	30-Mar	Pass
Photo Smoke	2nd Floor Bwing Media Room MDF#1	30-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor for Media Center	30-Mar	Pass
Photo Smoke	1st Floor B Wing Electrical Closet	31-Mar	Pass
Photo Smoke	1st Floor B Wing Electrical Closet	31-Mar	Pass
Photo Smoke	2nd floor B wing stairway #3	31-Mar	Pass
Photo Smoke	1st Floor D Wing Electrical Closet	31-Mar	Pass
Photo Smoke	1st Floor B Wing Emergency Electrical Closet	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Doors B to Stairs # 3	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Fan Room	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Corridor by Room A202	31-Mar	Pass
Photo Smoke	2nd Floor Bwing Corridor by Room A201	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Corridor by Room A216	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Corridor by Room A215	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Doors by Room A204	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor by Room A206	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor by Room A205	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor by Room A213	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Electrical Closet	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor by Room A209	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor by Room A211	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Doors Stair # 1	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Doors Stair # 1	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B226	31-Mar	Pass
Photo Smoke	2nd Floor D Wing Corridor D to C Wings	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor C to D Wings	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B228	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B227	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B229	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B230	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Room B231	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Science Storage	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Rear Stairway # 8	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Restroom	31-Mar	Pass
Pull Station	2nd Floor B Wing Corridor by Stair # 3	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Electrical Closet	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Faculty Dining	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor by Work Room B220	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor B to C	31-Mar	Pass
Photo Smoke	2nd Floor C Wing Corridor B to C	31-Mar	Pass

Pull Station	2nd Floor C Wing by Stairway # 8	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Doors Corridor B to C	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Corridor by Art A219	31-Mar	Pass
Pull Station	2nd Floor D Wing Corridor by Stair # 1	31-Mar	Pass
Photo Smoke	2nd Floor B Wing Doors Stair # 3	31-Mar	Pass
Pull Station	2nd Floor D Wing Corridor by Stair # 2	31-Mar	Pass
Pull Station	1st Floor B Wing Alarm Monitor Drill Switch	31-Mar	Pass
Photo Smoke	1st Floor C Wing Vestibule	31-Mar	Pass
Photo Smoke	1st Floor C Wing IDF # 3 Room	31-Mar	Pass
Pull Station	1st Floor C Wing Pre K Room B155	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by IDF # 3	31-Mar	Pass
	1st Floor C Wing Electrical Closet by IDF # 3		
Photo Smoke	Rm	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by Pre K B156	31-Mar	Pass
Pull Station	1st Floor C Wing C Vestibule Entrance	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by IDF # 3 Room	31-Mar	Pass
Photo Smoke	1st Floor C Wing Vestibule	31-Mar	Pass
Pull Station	1st Floor C Wing Kindergarten Room B 157	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by Pre-K B155	31-Mar	Pass
	1st Floor C Wing Corridor by Kindergarten		
Photo Smoke	B157	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor C to D Wings	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor D to C Wings	31-Mar	Pass
Pull Station	1st Floor C Wing Kindergarten Room B 158	31-Mar	Pass
	1st Floor C Wing Corridor by Kindergarten		
Photo Smoke	B158	31-Mar	Pass
Photo Smoke	1st Floor D Wing Doors D to Library	31-Mar	Pass
	1st Floor C Wing Corridor by Kindergarten		
Pull Station	B160	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor D to Library	31-Mar	Pass
Pull Station	1st Floor C Wing Kindergarten Room B 160	31-Mar	Pass
Photo Smoke	1st Floor D Wing Stairway # 14	31-Mar	Pass
Pull Station	1st Floor C Wing Pre K Room B 156	31-Mar	Pass
Photo Smoke	1st Floor D Wing Doors Stair # 1	31-Mar	Pass
	1st Floor C Wing Corridor by Kindergarten B		
Photo Smoke	159	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by C.R. Room A121	31-Mar	Pass
Photo Smoke	1st Floor C Wing Exit Door # 8	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by C.R. Room A120	31-Mar	Pass
Pull Station	1st Floor C Wing Kindergarten Room B 159	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by IDF 2	31-Mar	Pass
Photo Smoke	1st Floor C Stairway # 8	31-Mar	Pass
Photo Smoke	1st Floor D Wing Stairway # 2	31-Mar	Pass
Photo Smoke	1st Floor C Wing Emergency Electrical Room	31-Mar	Pass
Pull Station	1st Floor C Wing Stairway # 8	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor Faculty Room B150	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by ESL Room B 149	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by Room A 124	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor Doors by Room A124	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor Faculty Room B150	31-Mar	Pass
Pull Station	1st Floor C Wing Pre K Room B 156	31-Mar	Pass

Photo Smoke	1st Floor C Wing Corridor by ESL Room B 149	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by Room A 125	31-Mar	Pass
Photo Smoke	1st Floor C Wing Emergency Electrical Room	31-Mar	Pass
Pull Station	1st Floor D Wing Stairway # 1	31-Mar	Pass
Photo Smoke	1st Floor D Wing Corridor by Room A 115	31-Mar	Pass
Photo Smoke	1st Floor C Wing Transformer Room	31-Mar	Pass
Pull Station	1st Floor D Wing Stairway # 2 Exit	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by Electrical Closet	31-Mar	Pass
Photo Smoke	1st Floor B Wing Corridor by Computer A 126	31-Mar	Pass
	1st Floor B Wing Corridor by PTO Conference		
Photo Smoke	Rm A 109	31-Mar	Pass
Photo Smoke	1st Floor C Wing Corridor by Work Room B 146	31-Mar	Pass
	1st Floor B Wing by Corridor Parent Liaison Rm		
Photo Smoke	A 107	31-Mar	Pass

We replaced batteries in all booster Panels and Main FCP 55 Amp Hr.  
 Made list of Doors that need repair  
 We need to clean smoke detectors by air vents

**Name of Inspector:** William Tinker, William DiBease

**Organization:** City of Cambridge School Department

**Date:** March 31, 2011

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**Tobin Elementary School**  
**197 Vassal Lane**  
**Cambridge, MA 02139**

**Date of test: May 3<sup>rd</sup> & 4<sup>th</sup> 2011**

**FACP – F.C.I.**

**Model – 7100**

**Addressable**



**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator--</b>	--	--	N/A
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	No Elevator recall at this time

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 05/4/2011**

Building Occupants Yes  
 Building Management Yes

This Testing Was Done In Accordance With Applicable NFPA Standards.

Address	Type	Description	Tested	Pass/Fail
L2S87	Smoke Photo	3rd Floor Stair C	3-May	Pass
L2M79	Pull Station	3rd Floor Hall -C	3-May	Pass
L1S73	Smoke Photo	3rd Floor foyer by Rm 349	3-May	Pass
L1S72	Smoke Photo	3rd Floor by Rm 341	3-May	Pass
L1S71	Smoke Photo	3rd Floor by Rm 340	3-May	Pass
L2S31	Smoke Photo	3rd Floor by Elevator by RM 347 339	3-May	Pass
L2S32	Smoke Photo	3rd Floor by Elevator	3-May	Pass
L1S70	Smoke Photo	3rd Floor Elevator Recall	3-May	Pass
L2M76	Pull Station	3rd Floor by Elevator	3-May	Pass
L2S97	Smoke Photo	3rd Floor Stair # 2	3-May	Pass
L1S69	Smoke Photo	3rd Floor by Rm 337	3-May	Pass
L2M93	Pull Station	Auditorium Right	3-May	Pass
L2S30	Smoke Photo	3rd Floor by 325	3-May	Pass
L2M94	Pull Station	Auditorium Left Side	3-May	Pass
L2S29	Smoke Photo	3rd Floor by Rm 325	3-May	Pass
L2S83	Smoke Photo	3rd Floor Rm 323	3-May	Pass
L2S84	Smoke Photo	3rd Floor 325	3-May	Pass
L1S68	Smoke Photo	3rd Floor by Rm 323	3-May	Pass
L1S67	Smoke Photo	3rd Floor by Library	3-May	Pass
L2S28	Smoke Photo	3rd Floor by Rm 333	3-May	Pass
L2S36	Thermal Det	3rd Floor Library	3-May	Pass
L2S27	Smoke Photo	3rd Floor by Rm 333	3-May	Pass
L2M75	Pull Station	3rd Floor by Rm 321	3-May	Pass
L1S59	Smoke Photo	Top Stair 1	3-May	Pass
L1S66	Smoke Photo	3rd Floor by Rm 333	3-May	Pass
L2S82	Smoke Photo	3rd Floor rm 318	3-May	Pass
L2S16	Smoke Photo	3rd Floor by Rm 318	3-May	Pass
L2S26	Smoke Photo	3rd Floor by Rm 318	3-May	Pass
L1S65	Smoke Photo	3rd Floor by Rm 309	3-May	Pass
L1S64	Smoke Photo	3rd Floor by Rm 308	3-May	Pass
L1S63	Smoke Photo	3rd Floor Foyer by Rm 301	3-May	Pass
L2M78	Pull Station	3rd Floor Foyer -A	3-May	Pass
L2S94	Smoke Photo	3rd Floor Stair A	3-May	Pass
		2nd Floor Area		
L2M80	Pull Station	3rd Floor Hall A 2nd Floor	3-May	Pass
L1S23	Smoke Photo	2nd Floor Foyer Sec-A	3-May	Pass
L1M24	Pull Station	2nd Floor in Rm 216	3-May	Pass
L2M81	Pull Station	2nd Floor Lobby by Rm 205	3-May	Pass
L1M27	Pull Station	2nd Floor in Rm 206	3-May	Pass
L1S28	Smoke Photo	2nd Floor Sec -A Restroom	3-May	Pass
L2S57	Smoke Photo	2nd Floor Electric Room	3-May	Pass

L2S56	Smoke Photo	2nd Floor Electric Room	3-May	Pass
L1M25	Pull Station	2nd Floor in Room 215	3-May	Pass
L1M26	Pull Station	2nd Floor in Room 204	3-May	Pass
L1S29	Smoke Photo	2nd Floor by Room 213	3-May	Pass
L1M30	Pull Station	2nd Floor in Room 213	3-May	Pass
L1M31	Pull Station	2nd Floor in Room 208	3-May	Pass
L1M34	Pull Station	2nd Floor in Room 209-A	3-May	Pass
L1M37	Pull Station	2nd Floor in Rm 209	3-May	Pass
L1M38	Pull Station	2nd Floor in Room 210	3-May	Pass
L1M32	Pull Station	2nd Floor in Room 212-PS-A	3-May	Pass
L1M33	Pull Station	2nd Floor in Room212-PS-B	3-May	Pass
L1M36	Pull Station	2nd Floor in Room 211	3-May	Pass
L1S35	Smoke Photo	2nd Floor by Room 211	3-May	Pass
L2S14	Smoke Photo	2nd Floor by Room 221	3-May	Pass
L2S06	Smoke Photo	2nd Floor by Room 221	3-May	Pass
L2M89	Pull Station	2nd Floor by Room 239	3-May	Pass
L2S85	Smoke Photo	2nd Floor Electric Room	3-May	Pass
L2M97	Pull Station	2nd Floor Stair 1	3-May	Pass
L1S42	Smoke Photo	2nd Floor in Room 223	3-May	Pass
L2S63	Smoke Photo	2nd Floor Room 249 Back-Rm to science Dept	3-May	Pass
L2M86	Pull Station	Gym Exit door left	3-May	Pass
L1S41	Smoke Photo	2nd Floor in Room 223	3-May	Pass
L1S39	Smoke Photo	2nd Floor Science Dept	3-May	Pass
L1S40	Smoke Photo	2nd Floor by Rm 223	3-May	Pass
L2S55	Smoke Photo	2nd Floor Rm 225	3-May	Pass
L2S05	Smoke Photo	2nd Floor Lobby by Rm 276	3-May	Pass
L2M88	Pull Station	2nd Floor Gym Area	3-May	Pass
L2M87	Pull Station	Gym Hall Right	3-May	Pass
L1M75	Pull Station	Rear Hall by Gym	3-May	Pass
L2S59	Smoke Photo	2nd Floor Office 263	3-May	Pass
L2S61	Smoke Photo	2nd Floor Boys Locker Room	3-May	Pass
L1S74	Smoke Photo	2nd Floor Restroom by Gym	3-May	Pass
L1S43	Smoke Photo	2nd Floor Lobby	3-May	Pass
L1S61	Smoke Photo	Fire Alarm Panel	3-May	Pass
L2S67	Smoke Photo	2nd Floor Right Stairs	3-May	Pass
L2M83	Pull Station	Auditorium Stairs Right Side	3-May	Pass
L2S48	Smoke Photo	2nd Floor Copier Room	3-May	Pass
L2S49	Smoke Photo	2nd Floor by Room 226	3-May	Pass
L2S50	Smoke Photo	2nd Floor Conference Room	3-May	Pass
L2S51	Smoke Photo	2nd Floor in Room 223	3-May	Pass
L2S53	Smoke Photo	2nd Floor Office 238	3-May	Pass
L2S52	Smoke Photo	2nd Floor Office 235	3-May	Pass
L2S54	Smoke Photo	2nd Floor Office 231	3-May	Pass
L1S44	Smoke Photo	2nd Floor Lobby	3-May	Pass
L2M82	Pull Station	Auditorium Stairs Left Side	3-May	Pass
L2S70	Smoke Photo	2nd Floor Right Stairs	3-May	Pass
L1S45	Smoke Photo	2nd Floor Lobby	3-May	Pass
L2M90	Pull Station	2nd Floor Lobby	3-May	Pass
L2M92	Pull Station	Café Exit Right	3-May	Pass
L1M48	Pull Station	2nd Floor in Room 290	3-May	Pass

L1M52	Pull Station	2nd Floor in Rm 289	3-May	Pass
L1M53	Pull Station	2nd Floor in Room 289	3-May	Pass
L1S46	Smoke Photo	2nd Floor Elevator Recall	3-May	Pass
L1M47	Pull Station	2nd Floor in RM 279	3-May	Pass
L2S80	Smoke Photo	2nd Floor Electric Rm - R	3-May	Pass
L2S78	Smoke Photo	2nd Floor Closet by Elevator	3-May	Pass
L1M50	Pull Station	2nd Floor in Room 281	3-May	Pass
L1M51	Pull Station	2nd Floor in Room 281	3-May	Pass
L2S03	Smoke Photo	2nd Floor Corridor by 280	3-May	Pass
L2S02	Smoke Photo	2nd Floor Corridor by 280	3-May	Pass
L1S49	Smoke Photo	2nd Floor by Room 281	3-May	Pass
L1M55	Pull Station	2nd Floor in Rm 288	3-May	Pass
L1S56	Smoke Photo	2nd Floor by Rm 282	3-May	Pass
L1M54	Pull Station	2nd Floor in Room 282	3-May	Pass
L1S57	Smoke Photo	2nd Floor by RM 285	3-May	Pass
L2S80	Smoke Photo	2nd Floor Electric Room Right	3-May	Pass
L2S81	Smoke Photo	2nd Floor Electric Rm - L	3-May	Pass
L1M59	Pull Station	In Room 283	3-May	Pass
L1M60	Pull Station	2nd Floor in Room 284	3-May	Pass
L1S58	Smoke Photo	2nd Floor End Of Hall	3-May	Pass
L1M62	Pull Station	2nd Floor in Room 287	3-May	Pass
L1M61	Pull Station	2nd Floor in Room 286	3-May	Pass
L2M85	Pull Station	2nd Floor by Room 286	3-May	Pass
L2M84	Pull Station	2nd Floor stair - C	3-May	Pass
L2S79	Smoke Photo	2nd Floor in Room 272	3-May	Pass

Continued Testing on May 4, 2011

1st Floor Area				
L2M91	Pull Station	Front Lobby	4-May	Pass
L1S32	Smoke Photo	By Elevator Mechanical Rm	4-May	Pass
L1S06	Smoke Photo	1st Floor Elevator Recall	4-May	Pass
L1M93	Pull Station	1st Floor Hall 100-1	4-May	Pass
L1S05	Smoke Photo	Hall by Room 139	4-May	Pass
L1S53	Smoke Photo	1st Floor Hall by 100B	4-May	Pass
L1S52	Smoke Photo	1st Floor Hall by 100A	4-May	Pass
L1S04	Smoke Photo	Hall by Café Rm 123	4-May	Pass
L1S03	Smoke Photo	Hall by Kitchen Rm 121	4-May	Pass
L1S02	Smoke Photo	Hall by Rm 128	4-May	Pass
L1M98	Pull Station	1st Floor Dock Area	4-May	Pass
L1S09	Smoke Photo	1st Floor by Rm 141	4-May	Pass
L1S08	Smoke Photo	1st Floor by Room 141	4-May	Pass
L1M01	Pull Station	By Loading Dock	4-May	Pass
L1S07	Smoke Photo	1st Floor Disposal Room	4-May	Pass
L1S47	Smoke Photo	1st Floor Rm 128 Preschool	4-May	Pass
L1S36	Thermal Det	1st Floor in Room 128	4-May	Pass
L1S34	Smoke Photo	1st Floor in Room 128 Bathroom	4-May	Pass
L1S37	Smoke Photo	1st Floor in Room 129	4-May	Pass
L1S26	Thermal Det	1st Floor Kitchen Area	4-May	Pass
L1S27	Thermal Det	1st Floor Kitchen Area	4-May	Pass
L1S18	Smoke Photo	Outside Mechanical Room	4-May	Pass
L1S19	Thermal Det	1st Floor Storage Room causes fault	4-May	Pass

L1S20	Thermal Det	1st Floor Storage Room	4-May	Pass
L1S22	Thermal Det	1st Floor Electric Room	4-May	Pass
L1S21	Thermal Det	Main Electric Room	4-May	Pass
L1S60	Smoke Photo Photo Duct	1st Floor Janitor Closet	4-May	Pass
L1S14	Smoke Photo Duct	Mechanical Rm Unit # 1	4-May	Pass
L1S15	Smoke Photo Duct	Mechanical Rm Unit # 2	4-May	Pass
L1S16	Smoke Photo Duct	Mechanical Rm Unit # 3	4-May	Pass
L1S17	Smoke	Mechanical Rm Unit # 4	4-May	Pass
L1S48	Thermal Det	1st Floor in Room 112	4-May	Pass
L1S50	Thermal Det	1st Floor in Room 112	4-May	Pass
L1S31	Thermal Det	1st Floor Kitchen Closet 2	4-May	Pass
L2S11	Smoke Photo	Café left corner	4-May	Pass
L1M96	Pull Station	1st Floor Kitchen Area	4-May	Pass
L2S12	Smoke Photo	Café Middle Area	4-May	Pass
L2S13	Smoke Photo	Café Right Corner	4-May	Pass
L1M95	Pull Station	1st Floor in Café	4-May	Pass
L1M10	Pull Station	1st Floor Café 1st door on left	4-May	Pass
L1M11	Pull Station	1st Floor Café 2nd door on left	4-May	Pass
L1M12	Pull Station	Café 3 <sup>rd</sup> Door on Left	4-May	Pass
L1M13	Pull Station	Café 4 <sup>th</sup> door on left	4-May	Pass
L1M94	Pull Station	1st Floor in Café	4-May	Pass
L1S54	Smoke Photo	1st Floor by Room 107	4-May	Pass
L1S10	Smoke Photo	1st Floor by Room 101	4-May	Pass
L1S11	Thermal Det	Sub Basement Area A	4-May	Pass
L1S51	Thermal Det	Sub Basement Area C	4-May	Pass
L2S93	Thermal Det	3rd Floor Electric Closet Rm-C	4-May	Pass
L2S92	Smoke Photo	3rd Floor Electric Closet Rm-C	4-May	Pass
L2S38	Thermal Det	3rd Floor in Room 337	4-May	Pass
L2S37	Thermal Det	3rd Floor Lobby Sever Room	4-May	Pass
L2S36	Thermal Det	3rd Floor Library	4-May	Pass
L2S34	Thermal Det	Janitor Closet Stair 1	4-May	Pass
L2S96	Smoke Photo	3rd Floor Electric Rm - A	4-May	Pass
L2S95	Smoke Photo	3rd Floor Electric Rm - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S11	Thermal Det	Sub Basement Area - A	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L1S51	Thermal Det	Sub Basement Area - C	4-May	Pass
L2M83	Pull Station	Auditorium Stairs R	4-May	Pass
L2M82	Pull Station	Auditorium Stairs L	4-May	Pass

L2S48	Smoke Photo	2nd Floor Copier Rm	4-May	Pass
L2S49	Smoke Photo	2nd Floor by Rm 226	4-May	Pass
L2S50	Smoke Photo	2nd Floor Conference Rm	4-May	Pass
L2S51	Smoke Photo	2nd Floor Rm 223	4-May	Pass
L2S54	Smoke Photo	2nd Floor Office Rm 231	4-May	Pass
L2S53	Smoke Photo	2nd Floor Office 238	4-May	Pass
L2S52	Smoke Photo	2nd Floor Office 235	4-May	Pass
L2S93	Smoke Photo	Auditorium Right Side	4-May	Pass
L2S19	Thermal Det	Sub Basement Gym	4-May	Pass
L1S62	Smoke Photo	3rd Floor Data Closet	4-May	Pass
L2S33	Thermal Det	Electrical Closet Stair 1 3rd Floor	4-May	Pass
L2S04	Smoke Photo	2nd Floor Lobby by Rm 276	4-May	Pass
L2S71	Smoke Photo	Auditorium	4-May	Pass
L2S72	Smoke Photo	Auditorium	4-May	Pass
		All Fire Doors are ok		Pass
		All Horns / Strobes are ok		Pass
		Batteries are OK NP12-12T 12V 12AH		Pass
		Generator tested		Pass

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** May 4, 2011

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
Solomon Garage & Media  
456 Broadway Street  
Cambridge, MA 02139**

**Date of test: 5/11/2011  
FACP**

**Model – Gamewell**

**Addressable**

**Panel Manufacturer:** Gamewell      **Model Number:** IF602-126R  
**Monitoring Entity:**                      **Approving Agency:**  
    Cambridge Fire Department  
**Type Transmission:**                      **Account /Master box #:** 4821

**Circuit Styles:** Class -A, NAC-Style-B  
**Number of Addressable Loops:** 2  
**Number of Conventional Loops:**

**Last Date System Had Any Service performed:**

**Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
13	6	Photo Electric Smoke
0	6	Heat Detectors
6	6	Manual Stations
3	6	Duct Smoke
2	6	Monitor Module

**Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
0	A	Nac Boosters
0	A	Mini horns
15	A	Electronic Horn/Strobe
6	A	Strobe only
0	A	Exterior Beacon
0	A	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 2  
**Are Circuits Supervised?** Yes

**Main FACP System Power Supply**

Primary: 120 Volts, 20 Amps  
 Over Current Protection: Circuit Breaker  
 Location: Panel in Main Electric Rm  
 Secondary: 2- Storage Batteries, 12-Amp Hour's, 12 Volts DC  
 Calculated to Operate System: in 24 Hours  
 Batteries located: Main Electric Rm

**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b> --	--	--	OK
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	No Elevator Recall at this time

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 3/22/2011**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
12	Pull Station	1st Floor Media Studio Vestibule	22-Mar	Passed
13	Photo Smoke	1st Floor Front entrance vestibule	22-Mar	Passed
	Tamper			
	Switch	Main sprinkler Riser		
	Tamper			
	Switch	Main sprinkler Riser		
	Flow Switch	Main sprinkler Riser		
7	Photo Smoke	1st Floor Data Closet in Technology RM	22-Mar	Passed
14	Photo Smoke	1st Floor Corridor Media Center	22-Mar	Passed
		1st Floor Corridor Media By Staff		
15	Photo Smoke	Bathrooms	22-Mar	Passed
16	Photo Smoke	1st Floor Corridor Media by TV 8 Director	22-Mar	Passed
17	Photo Smoke	1st Floor Corridor by CEA Storage	22-Mar	Passed
18	Photo Smoke	1st Floor Corridor Media by Narration Both	22-Mar	Passed
38	Photo Smoke	In Cable Cast Rm 115A	22-Mar	Passed
19	Pull Station	Side Entrance by Narration Both	22-Mar	Passed
37	Photo Smoke	Dimming Closet in Main TV Studio Media	22-Mar	Passed
	EBU	Front Hall Media ok	22-Mar	Passed
	EBU	Main Lobby OK	22-Mar	Passed
	EBU	by Master Control RM Failed	22-Mar	Failed
	EBU	By CATV Office OK	22-Mar	Passed
	EBU	Staff Bath Men's OK	22-Mar	Passed
	EBU	Staff Bath Women's Head not working	22-Mar	Passed
	EBU	Rear Exit OK	22-Mar	Passed
	EBU	IN TV Studio OK	22-Mar	Passed
	EBU	Technology Class RM OK	22-Mar	Passed
	EBU	TV Studio Control Room OK	22-Mar	Passed
		Garage Area		
4	Pull Station	Garage Entrance to 1st Floor	22-Mar	Passed
2	Pull Station	Garage area 1st Floor by Overhead door	22-Mar	Passed
25	Pull Station	Garage Rear Entrance	22-Mar	Passed
27	Duct Smoke	Duct Smoke Detector Roof Top Unit 2	22-Mar	Passed
	Duct Smoke	Duct Smoke Detector Roof Top Unit 1	22-Mar	Failed
28	Duct Smoke	Duct Smoke Detector Roof Top Unit 3	22-Mar	Passed
35	Photo Smoke	Garage Electrical Closet 1st Floor	22-Mar	Passed
1	Photo Smoke	Garage Electrical Closet 1st Floor	22-Mar	Passed
		Plant Operations Office Area		
6	Photo Smoke	2nd Floor Stairway	22-Mar	Passed
5	Photo Smoke	2nd Floor Corridor	22-Mar	Passed
3	Pull Station	Entrance to 2nd Floor	22-Mar	Passed
		All Horn / Strobes Ok	22-Mar	Passed

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** March 22, 2011

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**War Memorial Building**  
**1640 Cambridge Street**  
**Cambridge, MA 02139**

**Date of test: April 4, 2011**

**FACP – F.C.I.**

**Model – 7100**

**Addressable**



Batteries located: Next to Panel in Arts Building Main Electrical Room

### Prior to Any Testing

#### Notifications Are Made:

Building Occupants Yes  
Building Management Yes

#### System Tests and Inspections

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X		All OK
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X		OK
Load Voltage	--	X		OK
<b>Transient Suppressors</b>		--	--	None Installed
<b>Remote Annunciator</b>	--	--		OK
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b>	X	X		Elevator Recall Passed

#### Initiating and Supervisory Device Tests and Inspections

#### On/Off Premises Monitoring:

**Notification That Testing Is Complete: 04/04/2011**

Building Occupants    Yes  
Building Management    Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

See Attached Print Out

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** April 4, 2011

OFF-NORMAL:	Municipal Ckt			14:06:40	04/04/11
TRBL ACKD:				14:07:00	04/04/11
OFF-NORMAL:	NAC 1			14:07:42	04/04/11
OFF-NORMAL:	NAC 2			14:07:42	04/04/11
MLT EVENTS:				14:07:44	04/04/11
OFF-NORMAL:			L1	14:08:04	04/04/11
OFF-NORMAL RSTRD:			L1	14:08:04	04/04/11
ACTION:	FLR1 STAIR 1	Photo Detector	L1S05	14:30:30	04/04/11
ALRM ACKD:				14:30:34	04/04/11
ACTION:	SMOKE ELEC RM 101A	Photo Detector	L1S01	14:31:52	04/04/11
ALRM ACKD:				14:31:52	04/04/11
ACTION:	SMOKE VESTIBULE 101	Photo Detector	L1S02	14:32:36	04/04/11
ALRM ACKD:				14:32:36	04/04/11
ACTION:	SMOKE RECPTION 101A	Photo Detector	L1S03	14:32:58	04/04/11
ALRM ACKD:				14:33:02	04/04/11
ACTION:	CORRIDOR BY STAIR1	Photo Detector	L1S04	14:33:28	04/04/11
ALRM ACKD:				14:33:32	04/04/11
ACTION:	DATA RM 105	Photo Detector	L1S22	14:34:32	04/04/11
ALRM ACKD:				14:34:40	04/04/11
ACTION:	VESTIBULE 101	Manual Station	L1M30	14:36:38	04/04/11
ALRM ACKD:				14:36:50	04/04/11
ACTION:	CORRIDOR BY RM 146	Photo Detector	L1S06	14:37:34	04/04/11
ALRM ACKD:				14:37:40	04/04/11
ACTION:	CORRIDOR BY RM 145	Photo Detector	L1S18	14:38:12	04/04/11
ALRM ACKD:				14:38:12	04/04/11
ACTION:	CORRIDOR BY STAIR2	Photo Detector	L1S08	14:38:40	04/04/11
ALRM ACKD:				14:38:44	04/04/11
ACTION:	CORRIDOR BY RM 151	Photo Detector	L1S07	14:39:12	04/04/11
ALRM ACKD:				14:39:12	04/04/11
ACTION:	CORRIDOR BY RM 145	Photo Detector	L1S19	14:39:26	04/04/11
ALRM ACKD:				14:39:26	04/04/11
ACTION:	FIELD HSE EXIT20	Manual Station	L1M26	14:39:46	04/04/11
ALRM ACKD:				14:39:50	04/04/11
ACTION:	CORRIDOR BY RM 114	Photo Detector	L1S20	14:39:50	04/04/11
ALRM ACKD:				14:40:02	04/04/11
ACTION:	CORRIDOR BY RM 151	Photo Detector	L1S09	14:40:06	04/04/11
ALRM ACKD:				14:40:06	04/04/11

ACTION:	CORRIDOR BY RM 141	Photo Detector	L1S21	14:40:06	04/04/11
ALRM ACKD:				14:40:26	04/04/11
ACTION:	FIELD HSE EXIT20	Manual Station	L1M25	14:40:36	04/04/11
ACTION:	CORRIDOR BY F. H.	Photo Detector	L1S11	14:40:46	04/04/11
ALRM ACKD:				14:40:50	04/04/11
ALRM ACKD:				14:40:50	04/04/11
ACTION:	FIELD HSE EXIT19	Manual Station	L1M24	14:41:04	04/04/11
ALRM ACKD:				14:41:16	04/04/11
ACTION:	FLR1 STAIR 2	Photo Detector	L1S52	14:41:42	04/04/11
ALRM ACKD:				14:41:42	04/04/11
ACTION:	FIELD HSE EXIT19	Manual Station	L1M23	14:41:50	04/04/11
ALRM ACKD:				14:41:50	04/04/11
ACTION:	FLR1 REC LOBBY	Photo Detector	L1S56	14:42:18	04/04/11
ALRM ACKD:				14:42:18	04/04/11
ACTION:	FIELD HSE EXIT18	Manual Station	L1M22	14:42:46	04/04/11
ALRM ACKD:				14:42:52	04/04/11
ACTION:	FLR1 STAIR 3	Photo Detector	L1S55	14:42:54	04/04/11
ALRM ACKD:				14:43:06	04/04/11
ACTION:	CORRIDOR BY RM 125	Photo Detector	L1S41	14:43:36	04/04/11
ALRM ACKD:				14:43:46	04/04/11
ACTION:	FIELD HSE VESTIBULE	Manual Station	L1M33	14:43:54	04/04/11
ALRM ACKD:				14:43:58	04/04/11
RESET:				14:46:34	04/04/11
OFF-NORMAL:	NAC 1			14:46:50	04/04/11
OFF-NORMAL:	NAC 2			14:46:50	04/04/11
OFF-NORMAL:	Municipal Ckt			14:46:52	04/04/11
MLT EVENTS:				14:46:54	04/04/11
ACTION:	CORRIDOR BY RM 125	Photo Detector	L1S41	14:48:10	04/04/11
ALRM ACKD:				14:48:10	04/04/11
ACTION:	CORRIDOR BY RM141	Manual Station	L1M31	14:49:12	04/04/11
ALRM ACKD:				14:49:30	04/04/11
ACTION:	FIELD HSE VESTIBULE	Manual Station	L1M33	14:50:10	04/04/11
ALRM ACKD:				14:50:18	04/04/11
ACTION:	POOL BRAWL SPACE	Manual Station	L1M86	14:50:34	04/04/11
ALRM ACKD:				14:50:44	04/04/11
ACTION:	CORRIDOR BY STAIR6	Manual Station	L1M32	14:50:46	04/04/11
ALRM ACKD:				14:50:46	04/04/11
ACTION:	FLR1 STAIR 6	Manual Station	L1M28	14:51:10	04/04/11
ALRM ACKD:				14:51:14	04/04/11
ACTION:	FL1 VESTIBULE 117	Manual Station	L1M35	14:52:26	04/04/11
ALRM ACKD:				14:52:28	04/04/11
ACTION:	FLR 1 STAIR 5	Manual Station	L1M29	14:52:36	04/04/11
ALRM ACKD:				14:52:44	04/04/11
ACTION:	FLR1 STAIR 5	Photo Detector	L1S44	14:52:44	04/04/11
ACTION:	CORR. BY FIR PMP 120	Photo Detector	L1S45	14:53:14	04/04/11
ALRM ACKD:				14:54:00	04/04/11
ALRM ACKD:				14:54:06	04/04/11
ACTION:	FIRE PMP RM 120	Photo Detector	L1S47	14:54:28	04/04/11
ALRM ACKD:				14:54:34	04/04/11
ACTION:	CHEM STOR RM 121A	Photo Detector	L1S46	14:55:44	04/04/11
ALRM ACKD:				14:55:44	04/04/11
ACTION:	FLR1 REC PL STOR132	Photo Detector	L1S60	14:57:48	04/04/11
ALRM ACKD:				14:57:56	04/04/11
ACTION:	FLR1 STAIR 6	Photo Detector	L1S27	15:00:04	04/04/11
ALRM ACKD:				15:00:04	04/04/11
ACTION:	FLR1 HPEA AQU STOR	Photo Detector	L1S61	15:00:10	04/04/11
ALRM ACKD:				15:00:10	04/04/11
ACTION:	ORR. BY CUST RM140	Photo Detector	L1S35	15:02:12	04/04/11
ALRM ACKD:				15:02:28	04/04/11
ACTION:	FLR1 CORR. STAIR 3	Photo Detector	L1S31	15:02:36	04/04/11
ALRM ACKD:				15:02:38	04/04/11
ACTION:	CORRIDOR BY RM 135A	Photo Detector	L1S30	15:02:56	04/04/11
ALRM ACKD:				15:02:56	04/04/11
ACTION:	CORRIDOR BY RM 135	Photo Detector	L1S29	15:03:22	04/04/11
ALRM ACKD:				15:03:22	04/04/11

ALRM ACKD:				15:03:46	04/04/11
ACTION:	FEILD HSE VEST 100B	Photo Detector	L1S36	15:04:10	04/04/11
ALRM ACKD:				15:04:10	04/04/11
ACTION:	ELECTRIC RM 133A	Photo Detector	L1S32	15:04:30	04/04/11
ALRM ACKD:				15:04:36	04/04/11
ACTION:	STORE RM 135A	Photo Detector	L1S34	15:05:08	04/04/11
ALRM ACKD:				15:05:14	04/04/11
ACTION:	STORE RM 134	Photo Detector	L1S28	15:05:40	04/04/11
ALRM ACKD:				15:05:44	04/04/11
RESET:				15:08:00	04/04/11
OFF-NORMAL:	NAC 1			15:08:14	04/04/11
OFF-NORMAL:	NAC 2			15:08:14	04/04/11
MLT EVENTS:				15:08:16	04/04/11
OFF-NORMAL:	Municipal Ckt			15:08:16	04/04/11
TRBL ACKD:				15:08:16	04/04/11
ACTION:	ELECTRIC RM 102	Photo Detector	L1S48	15:09:08	04/04/11
ALRM ACKD:				15:09:08	04/04/11
ACTION:	ELECTRIC RM 103	Photo Detector	L1S49	15:09:24	04/04/11
ALRM ACKD:				15:09:24	04/04/11
ACTION:	SDRE RM 104	Photo Detector	L1S50	15:11:12	04/04/11
ALRM ACKD:				15:11:16	04/04/11
ACTION:	STGOR RM FH105	Photo Detector	L1S51	15:11:16	04/04/11
ALRM ACKD:				15:11:22	04/04/11
ACTION:	STORE ROOM 100G	Photo Detector	L1S10	15:13:40	04/04/11
ALRM ACKD:				15:13:50	04/04/11
RESET:				15:15:46	04/04/11
OFF-NORMAL:	NAC 1			15:15:58	04/04/11
OFF-NORMAL:	NAC 2			15:15:58	04/04/11
OFF-NORMAL:	Municipal Ckt			15:16:00	04/04/11
MLT EVENTS:				15:16:00	04/04/11
ACTION:	STAIR 1	Photo Detector	L2S25	15:20:46	04/04/11
ALRM ACKD:				15:20:48	04/04/11
ACTION:	CORRIDOR BY STAIR1	Photo Detector	L2S12	15:21:18	04/04/11
ALRM ACKD:				15:21:24	04/04/11
ACTION:	FLR2 BY STAIR 1	Manual Station	L2M13	15:21:34	04/04/11
ALRM ACKD:				15:21:52	04/04/11
ACTION:	FLR2 STAIR 5	Photo Detector	L2S06	15:22:10	04/04/11
ALRM ACKD:				15:22:18	04/04/11
ACTION:	CORRIDOR BY RM 215	Photo Detector	L2S07	15:22:48	04/04/11
ALRM ACKD:				15:22:58	04/04/11
ACTION:	CORRIDOR BY GYM218	Photo Detector	L2S11	15:23:32	04/04/11
ALRM ACKD:				15:23:38	04/04/11
ACTION:	CORRIDOR BY GYM218	Photo Detector	L2S10	15:23:50	04/04/11
ALRM ACKD:				15:24:02	04/04/11
ACTION:	FLR2 BY STAIR 5	Manual Station	L2M12	15:24:26	04/04/11
ACTION:	CORR. BY GYM 218	Photo Detector	L2S29	15:24:26	04/04/11
ALRM ACKD:				15:24:46	04/04/11
ALRM ACKD:				15:24:46	04/04/11
ACTION:	CORRIDOR BY GYM218	Photo Detector	L2S09	15:25:00	04/04/11
ALRM ACKD:				15:25:04	04/04/11
ACTION:	CORRIDOR BY STAIR3	Photo Detector	L2S08	15:25:20	04/04/11
ALRM ACKD:				15:25:28	04/04/11
ACTION:	STORE RM 215A	Photo Detector	L2S40	15:25:36	04/04/11
ALRM ACKD:				15:25:38	04/04/11
ACTION:	CORRIDOR BY RM 202	Photo Detector	L2S13	15:26:28	04/04/11
ACTION:	CORRIDOR BY STAIR3	Photo Detector	L2S05	15:27:22	04/04/11
ALRM ACKD:				15:27:22	04/04/11
ALRM ACKD:				15:27:22	04/04/11
ACTION:	CORRIDOR BY RM 204	Photo Detector	L2S14	15:27:32	04/04/11
ALRM ACKD:				15:27:34	04/04/11
ACTION:	CORRIDOR BY RM 205	Photo Detector	L2S15	15:27:44	04/04/11
ALRM ACKD:				15:28:12	04/04/11
ACTION:	CORRIDOR BY RM 213	Photo Detector	L2S16	15:28:22	04/04/11
ALRM ACKD:				15:28:22	04/04/11
ACTION:	CORRIDOR BY STAIR 2	Photo Detector	L2S39	15:28:34	04/04/11

ACTION:	STAIR 3	Photo Detector	L2S04	15:31:04	04/04/11
ALRM ACKD:				15:31:04	04/04/11
ACTION:	CORRIDOR BY STAIR 2	Photo Detector	L2S18	15:32:50	04/04/11
ALRM ACKD:				15:32:50	04/04/11
ACTION:	CORR. BY FIELD BALC	Photo Detector	L2S19	15:32:58	04/04/11
ALRM ACKD:				15:32:58	04/04/11
ACTION:	CORR. BY FIELD BALC	Photo Detector	L2S20	15:33:38	04/04/11
ALRM ACKD:				15:33:42	04/04/11
ACTION:	CORR. BY FIELD BALC	Photo Detector	L2S21	15:33:58	04/04/11
ALRM ACKD:				15:33:58	04/04/11
ACTION:	CORR. BY FIELD BALC	Photo Detector	L2S22	15:34:10	04/04/11
ALRM ACKD:				15:34:10	04/04/11
ACTION:	FLR2 BY STAIR 6	Manual Station	L2M15	15:34:48	04/04/11
ALRM ACKD:				15:34:52	04/04/11
ACTION:	CORRIDOR BY STAIR 6	Photo Detector	L2S23	15:35:14	04/04/11
ALRM ACKD:				15:35:14	04/04/11
ACTION:	STAIR 5	Photo Detector	L2S24	15:35:34	04/04/11
ALRM ACKD:				15:35:34	04/04/11
ACTION:	FLR2 SPECT SEATING	Manual Station	L2M01	15:37:16	04/04/11
ACTION:	FLR2 SPECT SEATING	Manual Station	L2M02	15:37:16	04/04/11
ALRM ACKD:				15:37:24	04/04/11
ALRM ACKD:				15:37:24	04/04/11
ACTION:	CORRIDOR BY STAIR4	Photo Detector	L2S03	15:39:28	04/04/11
ALRM ACKD:				15:39:38	04/04/11
ACTION:	STAIR 4	Photo Detector	L2S02	15:39:50	04/04/11
ALRM ACKD:				15:39:52	04/04/11
RESET:				15:41:44	04/04/11
OFF-NORMAL:	NAC 1			15:42:02	04/04/11
OFF-NORMAL:	NAC 2			15:42:02	04/04/11
OFF-NORMAL:	Municipal Ckt			15:42:04	04/04/11
MLT EVENTS:				15:42:04	04/04/11
ACTION:	STORE RM 214A	Photo Detector	L2S28	15:43:56	04/04/11
ALRM ACKD:				15:43:56	04/04/11
ACTION:	CORRIDOR BY STAIR4	Photo Detector	L2S03	15:44:44	04/04/11
ALRM ACKD:				15:44:52	04/04/11
ACTION:	STAIR 4	Photo Detector	L2S02	15:45:28	04/04/11
ALRM ACKD:				15:45:28	04/04/11
ACTION:	STORE RM 219B	Photo Detector	L2S37	15:46:52	04/04/11
ALRM ACKD:				15:46:52	04/04/11
ACTION:	STORE RM 219B	Photo Detector	L2S36	15:48:18	04/04/11
ALRM ACKD:				15:48:24	04/04/11
ACTION:	STORE RM 218A	Photo Detector	L2S35	15:49:16	04/04/11
ALRM ACKD:				15:49:16	04/04/11
ACTION:	STORE RM 218F	Photo Detector	L2S34	15:52:20	04/04/11
ALRM ACKD:				15:52:24	04/04/11
ACTION:	STORE RM 218E	Photo Detector	L2S33	15:53:44	04/04/11
ALRM ACKD:				15:53:52	04/04/11
ACTION:	STORE RM 218E	Photo Detector	L2S32	15:54:36	04/04/11
ALRM ACKD:				15:54:50	04/04/11
RESET:				16:02:44	04/04/11
OFF-NORMAL:	NAC 1			16:02:44	04/04/11
OFF-NORMAL:	NAC 2			16:02:44	04/04/11
OFF-NORMAL:	Municipal Ckt			16:03:06	04/04/11
MLT EVENTS:				16:03:08	04/04/11
OFF-NORMAL:	MAIN HOUSE SIDE	Tamper Sw	L1M44	16:14:50	04/04/11
TRBL ACKD:				16:15:02	04/04/11
OFF-NORMAL:	MAIN CITY SIDE	Tamper Sw	L1M45	16:15:02	04/04/11
TRBL ACKD:				16:15:02	04/04/11
OFF-NORMAL:	FIRE PMF SUC SIDE	Tamper Sw	L1M50	16:15:30	04/04/11
TRBL ACKD:				16:15:40	04/04/11
OFF-NORMAL:	FIRE PUMP TRBL	Tamper Sw	L1M59	16:15:52	04/04/11
TRBL ACKD:				16:16:10	04/04/11
RESET:				16:22:04	04/04/11
OFF-NORMAL:	NAC 1			16:22:04	04/04/11
OFF-NORMAL:	NAC 2			16:22:04	04/04/11

MLT EVENTS#				16:22:30	04/04/11	
OFF-NORMAL#	RSTRD#	NAC 1		16:48:12	04/04/11	
OFF-NORMAL#	RSTRD#	NAC 2		16:48:12	04/04/11	
OFF-NORMAL#	RSTRD#	Municipal Ckt		16:49:02	04/04/11	
OFF-NORMAL#		Municipal Ckt		14:05:10	04/05/11	
TRBL ACKD#				14:05:14	04/05/11	
OFF-NORMAL#		NAC 1		14:05:22	04/05/11	
OFF-NORMAL#		NAC 2		14:05:22	04/05/11	
MLT EVENTS#				14:05:26	04/05/11	
OFF-NORMAL#		FIRE PMP PRES SIDE	Tamper Sw	L1M47	14:41:34	04/05/11
OFF-NORMAL#		MAIN HOUSE SIDE	Tamper Sw	L1M44	14:42:22	04/05/11
OFF-NORMAL#		MAIN CITY SIDE	Tamper Sw	L1M45	14:42:26	04/05/11
OFF-NORMAL#		PARKING GARAGE	Tamper Sw	L1M41	14:42:46	04/05/11
MLT EVENTS#				14:45:56	04/05/11	
RESET#				14:55:24	04/05/11	
OFF-NORMAL#		NAC 1		14:55:36	04/05/11	
OFF-NORMAL#		NAC 2		14:55:36	04/05/11	
MLT EVENTS#				14:55:36	04/05/11	
OFF-NORMAL#		Municipal Ckt		14:55:38	04/05/11	
TRBL ACKD#				14:55:40	04/05/11	
OFF-NORMAL#		FIELD HSE STAIR6	Tamper Sw	L1M75	15:05:46	04/05/11
OFF-NORMAL#		FIELD HSE STANDP	Tamper Sw	L1M73	15:07:40	04/05/11
OFF-NORMAL#		STAIR 6 STANDPIPE	Tamper Sw	L1M72	15:08:10	04/05/11
OFF-NORMAL#		FL2 STAIR 5 WAR MEM	Tamper Sw	L2M06	15:15:20	04/05/11
OFF-NORMAL#		STAIR 5 PENT.	Tamper Sw	L2M08	15:15:34	04/05/11
MLT EVENTS#				15:19:12	04/05/11	
OFF-NORMAL#		PARKING GARAGE	Tamper Sw	L1M15	15:27:50	04/05/11
TRBL ACKD#				15:29:40	04/05/11	
ACTION#		PARK GARAGE ENT	Manual Station	L1M17	15:30:48	04/05/11
ALRM ACKD#				15:31:06	04/05/11	
ACTION#		PARK GARAGE EXIT	Manual Station	L1M18	15:31:26	04/05/11
ALRM ACKD#				15:31:32	04/05/11	
ACTION#		PARK GAR REAR EXIT	Manual Station	L1M19	15:32:28	04/05/11
ALRM ACKD#				15:32:30	04/05/11	
RESET#				15:36:48	04/05/11	
OFF-NORMAL#		NAC 1		15:37:02	04/05/11	
OFF-NORMAL#		NAC 2		15:37:02	04/05/11	
OFF-NORMAL#		Municipal Ckt		15:37:02	04/05/11	
MLT EVENTS#				15:37:10	04/05/11	
FAULT#		NAC 1		15:37:24	04/05/11	
FAULT#		NAC 2		15:37:24	04/05/11	
FAULT RSTRD#		NAC 1		15:37:36	04/05/11	
FAULT RSTRD#		NAC 2		15:37:36	04/05/11	
FAULT#		NAC 1		15:45:08	04/05/11	
FAULT#		NAC 2		15:45:08	04/05/11	
FAULT RSTRD#		NAC 1		15:45:20	04/05/11	
FAULT RSTRD#		NAC 2		15:45:20	04/05/11	
FAULT#		NAC 2		15:45:32	04/05/11	
FAULT#		NAC 1		15:45:32	04/05/11	
FAULT RSTRD#		NAC 1		15:45:44	04/05/11	
FAULT RSTRD#		NAC 2		15:45:44	04/05/11	
FAULT#		NAC 2		15:50:16	04/05/11	
FAULT#		NAC 1		15:50:16	04/05/11	
FAULT RSTRD#		NAC 1		15:50:24	04/05/11	
FAULT RSTRD#		NAC 2		15:50:24	04/05/11	
FAULT#		NAC 1		15:54:36	04/05/11	
FAULT#		NAC 2		15:54:36	04/05/11	
FAULT RSTRD#		NAC 1		15:54:46	04/05/11	
FAULT RSTRD#		NAC 2		15:54:48	04/05/11	
ACTION#		CHILLER PENT 303	Manual Station	L2M67	15:58:44	04/05/11
ALRM ACKD#				15:58:56	04/05/11	
ACTION#		CHILLER PENT 303	Manual Station	L2M48	15:59:10	04/05/11
ALRM ACKD#				15:59:14	04/05/11	
ACTION#		MECH PENT RM 302	Manual Station	L2M47	15:59:40	04/05/11
ALRM ACKD#				15:59:44	04/05/11	

ALRM ACKD:				16:00:14	04/05/11
ALARM:	AHU-1 RETURN RM 302	Photo Duct Det	L2870	16:00:28	04/05/11
ALRM ACKD:				16:00:28	04/05/11
ALARM:	AHU-1 EXHAUT RM 302	Photo Duct Det	L2873	16:00:28	04/05/11
ALRM ACKD:				16:00:50	04/05/11
ALARM:	AHU-2 SUPPLY RM 302	Photo Duct Det	L2859	16:01:04	04/05/11
ALRM ACKD:				16:01:10	04/05/11
ALARM:	AHU-2 RETURN RM 302	Photo Duct Det	L2871	16:01:22	04/05/11
ALRM ACKD:				16:01:28	04/05/11
ALARM:	AHU-3 SUPPLY RM 302	Photo Duct Det	L2860	16:01:28	04/05/11
ALRM ACKD:				16:01:40	04/05/11
ALARM:	AHU-3 RETURN RM 302	Photo Duct Det	L2872	16:01:48	04/05/11
ALRM ACKD:				16:01:48	04/05/11
RESET:				16:02:46	04/05/11
OFF-NORMAL:	NAC 1			16:03:00	04/05/11
OFF-NORMAL:	NAC 2			16:03:00	04/05/11
OFF-NORMAL:	Municipal Ckt			16:03:02	04/05/11
MLT EVENTS:				16:03:02	04/05/11
FAULT:	Battery			16:04:36	04/05/11
TRBL ACKD:				16:04:36	04/05/11
FAULT RSTRD:	Battery			16:04:56	04/05/11
FAULT:	EVAX TROUBLE	N.O. Contacts	L1M01	16:06:08	04/05/11
TRBL ACKD:				16:06:16	04/05/11
FAULT RSTRD:	EVAX TROUBLE	N.O. Contacts	L1M01	16:06:38	04/05/11
FAULT:	NAC 1			16:24:10	04/05/11
FAULT:	NAC 2			16:24:10	04/05/11
FAULT RSTRD:	NAC 1			16:27:42	04/05/11
FAULT RSTRD:	NAC 2			16:27:42	04/05/11
FAULT:	NAC 1			16:27:54	04/05/11
FAULT:	NAC 2			16:27:54	04/05/11
FAULT RSTRD:	NAC 1			16:36:26	04/05/11
FAULT RSTRD:	NAC 2			16:36:34	04/05/11
ACCESS:	Access Failed			16:38:14	04/05/11
RESET:				16:39:14	04/05/11
OFF-NORMAL:	NAC 1			16:39:26	04/05/11
OFF-NORMAL:	NAC 2			16:39:26	04/05/11
OFF-NORMAL:	Municipal Ckt			16:39:28	04/05/11
MLT EVENTS:				16:39:28	04/05/11
OFF-NORMAL RSTRD:	NAC 1			16:49:52	04/05/11
OFF-NORMAL RSTRD:	NAC 2			16:49:52	04/05/11
OFF-NORMAL RSTRD:	Municipal Ckt			16:49:58	04/05/11
OFF-NORMAL:	Municipal Ckt			06:36:22	04/06/11
TRBL ACKD:				06:36:22	04/06/11
OFF-NORMAL:	NAC 1			06:36:40	04/06/11
OFF-NORMAL:	NAC 2			06:36:40	04/06/11
MLT EVENTS:				06:36:40	04/06/11
ACTION:	EMRG DIST RM119C	Photo Detector	L1842	06:39:42	04/06/11
ALRM ACKD:				06:39:42	04/06/11
RESET:				06:40:52	04/06/11
OFF-NORMAL:	NAC 1			06:41:06	04/06/11
OFF-NORMAL:	NAC 2			06:41:06	04/06/11
MLT EVENTS:				06:41:06	04/06/11
OFF-NORMAL:	Municipal Ckt			06:41:08	04/06/11
TRBL ACKD:				06:41:10	04/06/11
ACTION:	STORE RM 143B	Photo Detector	L1817	06:42:20	04/06/11
ALRM ACKD:				06:42:24	04/06/11
ACTION:	STORE RM 139A	Photo Detector	L1823	06:43:58	04/06/11
ALRM ACKD:				06:43:58	04/06/11
ACTION:	STORE RM 150A	Photo Detector	L1816	06:45:42	04/06/11
ALRM ACKD:				06:45:46	04/06/11
ACTION:	CORRIDOR BY RM 148	Photo Detector	L1815	06:46:32	04/06/11
ALRM ACKD:				06:46:34	04/06/11
ACTION:	STORE RM 147A	Photo Detector	L1812	06:46:54	04/06/11
ALRM ACKD:				06:46:56	04/06/11
ACTION:	STORE RM 148A	Photo Detector	L1814	06:48:00	04/06/11

ACTION#:	STORE RM 149A	Photo Detector	L1S13	06:48:50	04/06/11
ALRM ACKD#:				06:48:50	04/06/11
RESET#:				06:50:14	04/06/11
OFF-NORMAL#:	NAC 1			06:50:14	04/06/11
OFF-NORMAL#:	NAC 2			06:50:14	04/06/11
MLT EVENTS#:				06:50:28	04/06/11
OFF-NORMAL#:	Municipal Ckt			06:50:28	04/06/11
TRBL ACKD#:				06:50:28	04/06/11
ACTION#:	CUSTODIAN RM 140	Photo Detector	L1S40	06:51:24	04/06/11
ALRM ACKD#:				06:51:32	04/06/11
ACTION#:	STORE RM 139A	Photo Detector	L1S23	06:52:06	04/06/11
ALRM ACKD#:				06:52:08	04/06/11
ACTION#:	CORRIDOR BY RM 127A	Photo Detector	L1S37	06:54:12	04/06/11
ALRM ACKD#:				06:54:22	04/06/11
ACTION#:	CORRIDOR BY RM 127D	Photo Detector	L1S38	06:54:44	04/06/11
ALRM ACKD#:				06:54:48	04/06/11
ACTION#:	CORRIDOR BY RM 126	Photo Detector	L1S39	06:55:06	04/06/11
ALRM ACKD#:				06:55:16	04/06/11
RESET#:				06:57:10	04/06/11
OFF-NORMAL#:	NAC 1			06:57:40	04/06/11
OFF-NORMAL#:	NAC 2			06:57:40	04/06/11
MLT EVENTS#:				06:57:42	04/06/11
OFF-NORMAL#:	Municipal Ckt			06:57:42	04/06/11
TRBL ACKD#:				06:57:42	04/06/11
OFF-NORMAL RSTRD#:	NAC 1			06:59:06	04/06/11
OFF-NORMAL RSTRD#:	NAC 2			06:59:06	04/06/11
OFF-NORMAL RSTRD#:	Municipal Ckt			06:59:26	04/06/11
OFF-NORMAL#:	Municipal Ckt			06:37:58	04/20/11
TRBL ACKD#:				06:37:58	04/20/11
OFF-NORMAL#:	NAC 1			06:38:14	04/20/11
OFF-NORMAL#:	NAC 2			06:38:14	04/20/11
MLT EVENTS#:				06:38:18	04/20/11
OFF-NORMAL#:	FIRE PUMP TRBL	Tamper Sw	L1M59	06:52:10	04/20/11
TRBL ACKD#:				06:55:46	04/20/11
OFF-NORMAL RSTRD#:	NAC 1			13:46:40	04/20/11
OFF-NORMAL RSTRD#:	NAC 2			13:46:40	04/20/11
RESET#:				13:46:48	04/20/11
OFF-NORMAL#:	Municipal Ckt			13:47:02	04/20/11
TRBL ACKD#:				13:47:04	04/20/11
OFF-NORMAL RSTRD#:	Municipal Ckt			13:47:06	04/20/11
OFF-NORMAL#:	Municipal Ckt			06:37:56	05/07/11
TRBL ACKD#:				06:37:56	05/07/11
OFF-NORMAL#:	NAC 1			06:38:20	05/07/11
OFF-NORMAL#:	NAC 2			06:38:20	05/07/11
MLT EVENTS#:				06:38:32	05/07/11
OFF-NORMAL#:	PARKING GARAGE	Tamper Sw	L1M15	06:49:00	05/07/11
TRBL ACKD#:				06:51:32	05/07/11
OFF-NORMAL RSTRD#:	NAC 1			06:51:44	05/07/11
OFF-NORMAL RSTRD#:	NAC 2			06:51:44	05/07/11
RESET#:				07:44:56	05/07/11
OFF-NORMAL#:	Municipal Ckt			07:45:08	05/07/11
TRBL ACKD#:				07:45:14	05/07/11
OFF-NORMAL RSTRD#:	Municipal Ckt			07:45:14	05/07/11
OFF-NORMAL#:	NAC 1			17:38:00	06/02/11
OFF-NORMAL#:	NAC 2			17:38:00	06/02/11
MLT EVENTS#:				17:38:02	06/02/11
OFF-NORMAL#:	Municipal Ckt			17:38:04	06/02/11
TRBL ACKD#:				17:38:04	06/02/11
OFF-NORMAL RSTRD#:	NAC 1			20:23:52	06/02/11
OFF-NORMAL RSTRD#:	NAC 2			20:23:52	06/02/11
OFF-NORMAL RSTRD#:	Municipal Ckt			20:24:02	06/02/11
OFF-NORMAL#:	FIRE PUMP TRBL	Tamper Sw	L1M59	06:37:46	07/27/11
OFF-NORMAL#:	FIELD HSE	Tamper Sw	L1M38	06:38:24	07/27/11
MLT EVENTS#:				06:39:26	07/27/11
OFF-NORMAL#:	NAC 1			06:47:06	07/27/11

**City of Cambridge**  
**Cambridge Public Schools**

*456 Broadway Street*  
*Cambridge, MA 02138*  
*617-349-6855*

**Test report for:**

**City of Cambridge**  
**Cambridge School Department**  
**RUSSELL FIELD ATHLETIC FACILITY**

**Cambridge, MA 02139**

**Date of test: 3/7/2011**

**FACP – Edwards System**

**Model – EST 2**

**Addressable**

**Panel Manufacturer:** EST 2

**Model Number:** EST 2

**Monitoring Entity:**

**Approving Agency:**

Cambridge Fire Department

**Type Transmission:**

**Account /Master box #:** 7535

**Circuit Styles:** Class -A, NAC-Style-A

**Number of Addressable Loops:** 1

**Number of Conventional Loops:**

**Last Date System Had Any Service performed:** Do not know

#### **Alarm Initiating Devices and Circuit Information**

<u>Quantity of Devices</u>	<u>Circuit Style</u>	<u>Devices</u>
24	4	Photo Electric Smoke
1	4	Heat Detectors
7	4	Manual Stations
1	4	Duct Smoke
2	4	Monitor Module

#### **Alarm Indicating Appliances and Circuit Information**

<u>Quantity of</u>	<u>Circuit Style</u>	<u>Device</u>
0	B	Nac Boosters
0	B	Mini horns
12	A	Electronic Horn/Strobe
5	A	Strobe only
0	B	Exterior Beacon
0	B	Speaker/ Strobes

**Number of Notification Appliance Circuits:** 4

**Are Circuits Supervised?** Yes

#### **Main FACU System Power Supply**

Primary: 120 Volts, 20 Amps

Over Current Protection: Circuit Breaker

Location: Main Electrical Room in PNL#1 CB# 39

Secondary: 2- Storage Batteries, 7-Amp Hour's, 12 Volts DC

Calculated to Operate System: in 24 Hours

Batteries located: Storage Room behind FACP

**Prior to Any Testing**

**Notifications Are Made:**

Building Occupants Yes  
 Building Management Yes

**System Tests and Inspections**

Type	Visual	Functional	Comments
Control Unit	X	X	OK
Interface Equipment	--	--	
Lamps/LED's	X	X	All OK
Fuses	X	X	All OK
Primary Power Supply		X	X OK
Trouble Signal's		X	X All OK
Disconnect Switches	X	X	All OK
Ground Fault Monitoring		X	X All OK
<b>Secondary Power</b>			
Battery Condition	X	X	OK
Load Voltage	--	X	OK
<b>Transient Suppressors</b>	--	--	None Installed
<b>Remote Annunciator</b> --	--	--	N/A
<b>Notification Appliances</b>			
Audible		--	X Horns Operate
Visible	X	X	Strobes Lights Operate
<b>Interface Equipment</b>	X	X	Elevator Recall passed

**Initiating and Supervisory Device Tests and Inspections**

**On/Off Premises Monitoring:**

**Notification That Testing Is Complete: 3/ 7/2011 2:00 pm**

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Address	Type	Description	Tested	Pass/Fail
M002				
0218	Pull Station	1st Floor Pull Locker Room 2	7-Mar	Pass
M002	Photo			
0122	Smoke	1st Floor Smoke Locker Room 2	7-Mar	Pass
M004	Photo			
0125	Smoke	1st Floor Smoke Corridor by Locker Rm 2	7-Mar	Pass
M005	Photo			
0126	Smoke	1st Floor Smoke Corridor by Sprinkler Rm	7-Mar	Pass
M006	Photo			
0131	Smoke	1st Floor Smoke Sprinkler Rm	7-Mar	Pass
M007	Photo			
0132	Smoke	1st Floor Smoke Main Electric Rm	7-Mar	Pass
M008	Photo			
0120	Smoke	1st Floor Smoke Main Lobby Entrance	7-Mar	Pass
M009				
0215	Pull Station	1st Floor Pull Main Lobby Field side	7-Mar	Pass
M010				
0228	Pull Station	1st Floor Pull Main Lobby Street Side	7-Mar	Pass
M011	Smoke			
0111	Photo	1st Floor Smoke Coridor by Util-1	7-Mar	Pass
M012	Smoke			
0112	Photo	1st Floor Smoke Corridor by Elevator	7-Mar	Pass
M013				
0212	Pull Station	1st Floor Pull Corridor by Elevator	7-Mar	Pass
M014	Smoke			
0115	Photo	1st Floor Smoke Elevator Lobby	7-Mar	Pass
M015	Smoke			
0117	Photo	1st Floor Smoke Elevator Machine Rm	7-Mar	Pass
M016	Smoke			
0114	Photo	1st Floor Smoke Corridor in Locker Rm 1	7-Mar	Pass
M017	Smoke			
0113	Photo	1st Floor Smoke Locker Room 1	7-Mar	Pass
M018				
0208	Pull Station	1st Floor Pull Locker Room 1	7-Mar	Pass
M019	Smoke			
0118	Photo	1st Floor Smoke Stairway A	7-Mar	Pass
M020	Smoke			
0106	Photo	2nd Floor Smoke Stairway A	7-Mar	Pass
	Smoke			
M021 018	Photo	2nd Floor Smoke Elevator Lobby	7-Mar	Pass
M022				
0206	Duct Smoke	2nd Floor Duct Smoke Mechanical Rm F4	7-Mar	Pass
M023	Smoke			
0109	Photo	2nd Floor Smoke Mechanical Room	7-Mar	Pass
M024	Smoke			
0104	Photo	2nd Floor Smoke Exercise Room	7-Mar	Pass

M025	Smoke				
0103	Photo	2nd Floor Smoke Exercise Room	7-Mar	Pass	
M026	Smoke				
0102	Photo	2nd Floor Smoke Exercise Room	7-Mar	Pass	
M027					
0203	Pull Station	2nd Floor Pull Stairway B	7-Mar	Pass	
M028					
0205	Pull Station	2nd Floor Pull Stairway A	7-Mar	Pass	
M029	Smoke				
0101	Photo	2nd Floor Smoke Stairway B	7-Mar	Pass	
M030	Smoke				
0124	Photo	1st Floor Smoke Stairway B	7-Mar	Pass	
M031	Smoke				
0121	Photo	1st Floor Smoke Outside Storage Rm 2	7-Mar	Pass	
M032	Smoke				
0123	Photo	1st Floor Smoke Outside Storage Rm 1	7-Mar	Pass	
M033	Smoke				
0116	Photo	1st Floor Smoke Outside LL Storage Rm 3	7-Mar	Pass	
	Tamper	Supervisory 1 st Floor Tamper Sprinkler			
M02 0222	Switch	Riser	7-Mar	Pass	
	Tamper				
M02 0221	Switch	1st Floor Tamper Sprinkler Riser	7-Mar	Pass	

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** March 7, 2011

**City of Cambridge  
Cambridge Public Schools**

*456 Broadway Street  
Cambridge, MA 02138  
617-349-6855*

**Test report for:**

**City of Cambridge  
Cambridge School Department  
High School 9<sup>th</sup> Grade Campus  
359 Broadway  
Cambridge, MA 02139**

**Date of test: March 19, 2011**

**FACP – Silent Knight**

**Model – 5207**



### Prior to Any Testing

#### Notifications Are Made:

Building Occupants Yes  
Building Management Yes

#### System Tests and Inspections

Type	Visual	Functional	Comments	
Control Unit	X	X	OK	
Interface Equipment	--	--		
Lamps/LED's	X	X	All OK	
Fuses	X	X	All OK	
Primary Power Supply		X	X	OK
Trouble Signal's		X	X	All OK
Disconnect Switches	X	X		All OK
Ground Fault Monitoring		X	X	All OK
<b>Secondary Power</b>				
Battery Condition	X	X		OK
Load Voltage	--	X		OK
<b>Transient Suppressors</b>		--	--	None Installed
<b>Remote Annunciator</b>	--	--		<b>OK</b>
<b>Notification Appliances</b>				
Audible		--	X	Horns Operate
Visible	X	X		Strobes Lights Operate
<b>Interface Equipment</b>	X	X		No Elevator Recall at this time

#### Initiating and Supervisory Device Tests and Inspections

#### On/Off Premises Monitoring:

Notification That Testing Is Complete: 03/19/2011

Building Occupants Yes  
 Building Management Yes

**This Testing Was Done In Accordance With Applicable NFPA Standards.**

Type	Description	Tested	Pass/Fail
Pull Station	Pull Station Basement by RM LO25	19-Mar	pass
Photo Smoke	Smoke Detector # 303 exit stairway top	19-Mar	Pass
Photo Smoke	Smoke Detector L201 301	19-Mar	Pass
Photo Smoke	1st Floor Stairway Smoke Detector # 206	19-Mar	pass
Photo Smoke	Smoke Detector # 200 1st floor main office	19-Mar	pass
Photo Smoke	Smoke Detector # 302 Rm L201	19-Mar	pass
Photo Smoke	Main Corridor Smoke # 205 by rm L103	19-Mar	pass
Photo Smoke	Corridor Smoke by L201	19-Mar	Pass
Photo Smoke	Corridor Smoke by Rm L203	19-Mar	Pass
Photo Smoke	Main Office Smoke in office Rm L103D	19-Mar	Pass
Photo Smoke	Staff Bathroom Smoke	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L203	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L204	19-Mar	Pass
Photo Smoke	2nd Floor Corridor by Rm L205	19-Mar	Pass
Photo Smoke	2nd Floor Corridor by Rm L207	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L207	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L206	19-Mar	Pass
Photo Smoke	2nd Floor end of Corridor by Rm L213	19-Mar	Pass
Photo Smoke	1st Floor Smoke in Rm L105	19-Mar	Pass
Photo Smoke	2nd Floor Corridor by Rm L211	19-Mar	Pass
Photo Smoke	2nd Floor Smoke in room L211	19-Mar	Pass
Photo Smoke	2nd Floor Smoke in room L213	19-Mar	Pass
Photo Smoke	2nd Floor in Room 208	19-Mar	Pass
Photo Smoke	2nd Floor in Room 212 Utility	19-Mar	Pass
Photo Smoke	2nd Floor Corridor by Rm L214	19-Mar	Pass
Photo Smoke	2nd Floor Girls Bathroom	19-Mar	Pass
Photo Smoke	2nd Floor Utility Closet in L214	19-Mar	Pass
Photo Smoke	2nd Floor in classroom L218	19-Mar	Pass
Photo Smoke	1st Floor in classroom L102	19-Mar	Pass
Photo Smoke	1st Floor in Classroom L104	19-Mar	Pass
Photo Smoke	1st Floor Corridor by Rm L107	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L205	19-Mar	Pass
Photo Smoke	1st Floor corridor by Rm L104A	19-Mar	Pass
Photo Smoke	1st Floor in Room L104A	19-Mar	Pass
Photo Smoke	1st Floor in classroom L109	19-Mar	Pass
Photo Smoke	1st Floor Smoke in Rm L108	19-Mar	Pass
Photo Smoke	1st Floor Corridor by Rm L115	19-Mar	Pass
Photo Smoke	1st Floor Stairway by Rm L109	19-Mar	Pass
Photo Smoke	1st Floor in classroom L113	19-Mar	Pass
Photo Smoke	1st Floor smoke in classroom 115	19-Mar	Pass
Photo Smoke	1st Floor smoke in staff bathroom Rm L112	19-Mar	Pass
Photo Smoke	1st Floor Corridor by Rm L114	19-Mar	Pass
Photo Smoke	1st Floor in internet closet Rm L114	19-Mar	Pass

Photo Smoke	1st Floor Girls Bathroom	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom 215	19-Mar	Pass
Photo Smoke	2nd Floor Corridor by Room L217	19-Mar	Pass
Photo Smoke	2nd Floor in classroom L217	19-Mar	Pass
Photo Smoke	2nd Floor in corridor top of stairs by Rm L218	19-Mar	Pass
Photo Smoke	2nd Floor in corridor by Rm L219	19-Mar	Pass
Photo Smoke	1st Floor in classroom L117	19-Mar	Pass
Photo Smoke	1st Floor in classroom L118	19-Mar	Pass
Photo Smoke	1st Floor in corridor by RM L118	19-Mar	Pass
Photo Smoke	1st Floor in corridor stairway by Rm L118	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L219	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L222	19-Mar	Pass
Photo Smoke	2nd Floor in Corridor by Boy's Room	19-Mar	Pass
Photo Smoke	2nd Floor in Boy's Room	19-Mar	Pass
Photo Smoke	2nd Floor in Staff Bathroom	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L221	19-Mar	Pass
Photo Smoke	2nd floor in Corridor end of corridor by Fayette st	19-Mar	Pass
Photo Smoke	2nd Floor in Classroom L223	19-Mar	Pass
Photo Smoke	2nd Floor in Corridor by Rm L227A	19-Mar	Pass
	2nd Floor in Room L227A	19-Mar	Pass
Photo Smoke	1st Floor in Room L119	19-Mar	Pass
Photo Smoke	1st Floor in Staff Bathroom in Nurse's Room	19-Mar	Pass
Photo Smoke	1st Floor in Office L119B	19-Mar	Pass
Photo Smoke	1st Floor on Office L119C	19-Mar	Pass
Photo Smoke	1st Floor in Corridor by RM L119	19-Mar	Pass
Photo Smoke	1st Floor in Room 121	19-Mar	Pass
Photo Smoke	1st Floor in Room L124	19-Mar	Pass
Photo Smoke	1st Floor in Corridor by L124	19-Mar	Pass
Photo Smoke	1st Floor in Boy's Room	19-Mar	Pass
Photo Smoke	1st Floor in Staff Bathroom in Boy's Rm		
Photo Smoke	1st Floor in Classroom L123	19-Mar	Pass
Photo Smoke	1st Floor Corridor into Gym	19-Mar	Pass
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	Smoke in Gym	19-Mar	
Photo Smoke	In Corridor by gym office L128B	19-Mar	Pass
Photo Smoke	Stairway going up L128B	19-Mar	Pass
Photo Smoke	1st Floor off of gym in Rm L128A	19-Mar	Pass
Photo Smoke	1st Floor in Room L130 near gym store	19-Mar	Pass
Photo Smoke	1st Floor Storage Room in Gym L129	19-Mar	Pass
Photo Smoke	1st Floor Vestibule Entrance to Gym	19-Mar	Pass
Photo Smoke	1st Floor in Corridor by L128	19-Mar	Pass
Photo Smoke	1st Floor in Classroom L125	19-Mar	Pass
Photo Smoke	1st Floor Stairway #9 landing Fayette St	19-Mar	Pass
Pull Station	2nd Floor top of stairs b Fayette St	19-Mar	Pass
Pull Station	2nd Floor Stairway going down to Court Yard	19-Mar	Pass
Pull Station	2nd Floor Stairway going to Interim St	19-Mar	Pass

Pull Station	2nd Floor Stairway going to Broadway St	19-Mar	Pass
Pull Station	1st Floor by Main Office	19-Mar	Pass
Pull Station	1st Floor exit to Interium St	19-Mar	Pass
Pull Station	1st Floor Corridor to court yard	19-Mar	Pass
Pull Station	1st Floor exit to Interium St	19-Mar	Pass
Pull Station	1st Floor exit to Fayette St	19-Mar	Pass
	Basement by Stairway going up towards court yard		
Photo Smoke	Basement in L003 Room	19-Mar	Pass
Photo Smoke	Basement in L003 Room	19-Mar	Pass
Photo Smoke	Basement Floor corridor by Rm L003	19-Mar	Pass
Photo Smoke	Basement Floor in room L003 Bathroom	19-Mar	Pass
Photo Smoke	Basement in Classroom L004B	19-Mar	Pass
Photo Smoke	Basement Corridor by room L004B	19-Mar	Pass
Photo Smoke	Basement in Classroom L006	19-Mar	Pass
Photo Smoke	Basement in Classroom L004B Bathroom	19-Mar	Pass
Pull Station	Basement by Classroom L006	19-Mar	Pass
Photo Smoke	Basement by Classroom L006	19-Mar	Pass
Photo Smoke	Basement in Classroom L006 Bathroom	19-Mar	Pass
Photo Smoke	Basement Corridor by room L005	19-Mar	Pass
Photo Smoke	Basement in Classroom L005	19-Mar	Pass
Photo Smoke	Basement in Classroom L005	19-Mar	Pass
Photo Smoke	Basement Corridor by Room L007	19-Mar	Pass
Photo Smoke	Basement in Classroom L007	19-Mar	Pass
Photo Smoke	Basement in Office L011A	19-Mar	Pass
Photo Smoke	Basement by Room L011	19-Mar	Pass
Pull Station	Basement Exit to Anturium St Stair 11	19-Mar	Pass
Photo Smoke	Basement Corridor by exit 11 tp antrium St	19-Mar	Pass
Photo Smoke	Basement in Classroom L011	19-Mar	Pass
Photo Smoke	Basement in Classroom L011	19-Mar	Pass
Photo Smoke	Basement in Office L011B	19-Mar	Pass
Photo Smoke	Basement Corridor by Stairway 10 to parking lot	19-Mar	Pass
	Basement Exit door by stairway 10 towards parking lot		
Pull Station	Basement Exit door by stairway 10 towards parking lot	19-Mar	Pass
Photo Smoke	Basement Corridor by Room L012	19-Mar	Pass
Photo Smoke	Basement in Elevator Machine room L012	19-Mar	Pass
Photo Smoke	Basement Girl's Room	19-Mar	Pass
Photo Smoke	Basement in Storage Room L015	19-Mar	Pass
Photo Smoke	Basement in Storage Room L015	19-Mar	Pass
Photo Smoke	Basement in Classroom L018	19-Mar	Pass
Heat Detector	Basement Boiler Room		
Heat Detector	Basement Boiler Room		
Heat Detector	Basement Boiler Room		
Heat Detector	Basement Boiler Room		
Photo Smoke	Basement Corridor by L019	19-Mar	Pass
Photo Smoke	Basement Corridor by room L020	19-Mar	Pass
Pull Station	Basement Corridor by Room L012	19-Mar	Pass
Photo Smoke	Basement Corridor by Room L021	19-Mar	Pass
Photo Smoke	Basement in room L021 needs to be relocated	19-Mar	Pass
Photo Smoke	Basement in Classroom L020	19-Mar	Pass
Photo Smoke	Basement Main Electric Room	19-Mar	Pass

Photo Smoke	Basement Main Electric Room	19-Mar	Pass
Photo Smoke	Basement Corridor by Boy's Room	19-Mar	Pass
Photo Smoke	Basement Staff Bathroom	19-Mar	Pass
Photo Smoke	Basement Boy's Room	19-Mar	Pass
Photo Smoke	Basement Men's Staff	19-Mar	Pass
Photo Smoke	Basement in Classroom L025	19-Mar	Pass
Photo Smoke	Basement in Classroom I026	19-Mar	Pass
Photo Smoke	Basement corridor by room L025	19-Mar	Pass
Pull Station	Basement exit to Fayette st exit 9	19-Mar	Pass
Photo Smoke	Basement Stairs exit to Fayette St	19-Mar	Pass
Photo Smoke	Basement Corridor by cafeteria	19-Mar	Pass
Photo Smoke	Basement In Kitchen area	19-Mar	Pass
Photo Smoke	Kitchen Storage Room	19-Mar	Pass
	KITCHEN ANSOL SYS		
Photo Smoke	Basement in daycare Rm L031	19-Mar	Pass
Photo Smoke	Basement in daycare Rm L031	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Basement in corridor by cafeteria	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Basement in Cafeteria	19-Mar	Pass
Photo Smoke	Storage room by Cafeteria	19-Mar	Pass
Photo Smoke	Storage room by Cafeteria	19-Mar	Pass
Photo Smoke	Office off of Cafeteria	19-Mar	Pass
	Teachers Lounge L035	19-Mar	Pass
	Teachers Lounge L035	19-Mar	Pass
	Teacher Bah room I035	19-Mar	Pass
Pull Station	Basement stair to court yard #6	19-Mar	Pass
Pull Station	Basement in Cafeteria by door #5	19-Mar	Pass
Photo Smoke	Basement in cafeteria by stairway #5 exit	19-Mar	Pass
	ALL Battery units on 2nd Floor work	19-Mar	pass
	two Battery unit on 1st floor failed	19-Mar	FAILED
	Batteries 2-18amp Hr	19-Mar	Pass

**Name of Inspector:** William Tinker  
**Organization:** City of Cambridge School Department  
**Date:** March 19, 2011