



City of Cambridge

Purchasing Department

Cynthia H. Griffin
Purchasing Agent

TO: All Bidders
FROM: City of Cambridge
DATE: May 31, 2013
RE: File No. 6089 –Huron B (Contract 8B) Sewer Separation and Surface Improvements Project-
Addendum No. 3

I. GENERAL

The attention of bidders submitting proposals for the above referenced project is called to the following Addendum. The items set forth herein, whether of omission, addition, substitution, or clarification are all included in the proposed work. This addendum consists of 2 pages, numbered Pages 1 of 2 through 2 of 2.

This addendum is comprised of the following:
Response to Bidder Questions
Extension of Bid Opening Date

The Bid Opening Date for the Huron B (Contract 8B) Sewer Separation and Surface Improvements Project has been postponed.

The revised Bid Opening date is scheduled for THURSDAY, JUNE 13, 2013 at 2:00 PM, City of Cambridge Purchasing Department, City Hall, 795 Massachusetts Avenue, Room 303.

Inclusion of this Addendum must be acknowledged by inserting its number on page 00300-1 of the Bid Proposal. Failure to acknowledge any or all addenda in the above-specified bid may be cause for rejection of the bid by the Owner on the grounds that it is not responsive.

II. RESPONSE TO BIDDER QUESTIONS

1. Question received on 5/23/13:

Q: Plan view of drawings C-3A and C-4A of addenda 1 show 10" PVC from new DMH at approx. STA 2114+34 of Huron Ave to DMH at approx. STA 2116+5; the profile depicts 12" PVC. Please clarify.



A: The correct pipe size for the above referenced section shall be 12" PVC. The quantities on the Form for General Bid as part of addendum No. 1 include this quantity for 12" PVC. The conformed plans will be revised with the corrected pipe size.

Q: Addenda 1, Part IV, Modifications to Drawings para CC. Modification to R-3A, details changing Huron Ave. to full depth. Drawings R-1A, R-2A, & R4A-R-8A have not been modified to reflect full depth excavation on Huron Ave. Please confirm whether the revision listed for drawing R-3A refers to all drawings R1A through R-8A as well.

A: Yes – Full depth construction is required at all areas on Huron Ave as shown on SK-1 issued with addendum No.1 except for mill & overlay at the tie-ins at the east and west project limits. Sheet R-3A was issued with addendum No.1 because of changes at the intersection with Lakeview Ave. Sheets R-1A through R-8A will be revised and reissued as part of the conformed set.

All questions and answers are closed.



CYNTHIA H. GRIFFIN
PURCHASING AGENT

Addendum No. 3