



City of Cambridge

Purchasing Department

Cynthia H. Griffin
Purchasing Agent

TO: All Bidders
FROM: City of Cambridge
DATE: July 2, 2013
RE: File No. 6140 – Fire Department Reservoir Access Project - Addendum No. 1

Please note the attached Addendum No. 1 which includes a question that was submitted and the attached sign in sheet for the Pre-bid meeting.

The following questions was submitted and answered.

Q: Would Drivable Grass be an approved alternative product to Grasspave2 listed in Section 02795 of the specifications and shown on Sheets L-2 and L-3?

A: Drivable Grass is not an approved alternative product. Plastic reinforced turf rings (such as Grasspave2) were chosen to match existing materials in the vicinity of the project, and is the only acceptable material.

All other details remain the same.


CYNTHIA H. GRIFFIN
PURCHASING AGENT

Addendum No. 1



