



# City of Cambridge

## Purchasing Department

Michele A. Kincaid  
Acting Purchasing Agent

**TO:** All Bidders  
**FROM:** City of Cambridge  
**DATE:** May 15, 2014  
**RE:** File No. 6334 –Audio Visual Improvements for City Hall- Addendum No. 2

---

The following question was submitted and answered:

**Question:** I am trying to confirm the location of the hardwood flooring. Sheet C-A100 has marked room 101 to be wood. Am I to assume that all shaded areas are to be wood flooring? What about C-A101 will the gallery also be wood? What type of flooring is going on the non shaded area?

**Answer:** All shaded areas indicate existing construction, as stated in Demolition Notes and General Notes on each sheet. The project scope is delineated in keynotes on the plans and in the keynote legend on each sheet. The Sullivan chamber has an existing hardwood floor, there is no scope to refinish or alter this floor beyond that which is necessary to execute MEP work. Keynote 5.0 on sheet CA-101 states: "TYPE CPT-1 Carpet". The white area shown is new carpet over the existing hardwood floor. There is no scope associated with the existing flooring in the Gallery.

All other details remain the same.

**MICHELE A. KINCAID**  
**ACTING PURCHASING AGENT**

Addendum No. 2

