



# City of Cambridge

## PURCHASING DEPARTMENT

795 Massachusetts Ave. • Cambridge, Massachusetts 02139-3219

Amy L. Witts  
Purchasing Agent


**TO:** All Bidders  
**FROM:** City of Cambridge  
**DATE:** August 19, 2016  
**RE:** File No. 7305 – Kingsley Park Overlook Restoration- Addendum No. 1

---

This addendum is comprised of:

1. Pre-bid Meeting Agenda (attached)
2. Sign in sheet from the pre-bid Meeting (attached)
3. Questions and answers (attached)

All other details remain the same.

  
\_\_\_\_\_

Amy L. Witts  
Purchasing Agent

Addendum No. 1



## agenda

Cambridge Water Department

Fresh Pond Reservation

**Pre-Bid Conference for the Kingsley Park Overlook Restoration**

17 August 2016, 2pm

---

### Items:

1. Introductions and Project History – David Kaplan, CWD  
Charlie Sullivan, Cambridge Historical Commission
  
2. Project Overview – Duke Bitsko, Chester Engineers
  - a. Contract value - \$33k
  - b. Schedule
    - i. Bid opening Thursday August 25<sup>th</sup>, 2pm
    - ii. Questions due Thursday August 18<sup>th</sup>, 4pm
    - iii. Project completion October 28<sup>th</sup>, 2016
  - c. Project Requirements
    - i. Work hours 7am to 4pm, weekdays
    - ii. Site protection – paving, benches, fencing, and vegetation
    - iii. Samples and submittals – stone, mortar, grout, sample panels
    - iv. Scope of restoration work
    - v. Exclusions – grading and stabilization below overlooks (by others)
    - vi. Warranty period – 1 year
  
3. Coordination Issues
  - a. Site access and staging
  - b. Water supply
  - c. Traffic and pedestrian management
  
4. Questions





## Contractor Questions

Cambridge Water Department

***Fresh Pond Reservation***

***Kingsley Park Overlook Restoration Project***

Pre-Bid Conference – 17 August 2016

---

One Contractor attended this morning's Pre-Bid Meeting and through our discussion came several questions which warrant documentation:

1. Question: Is there a source of electrical power to the overlooks, and if not, can a gas-powered generator be used?

Answer: There are no sources of electrical power at the overlooks. Generators can be used but must be removed from the overlooks at the end of each working day. Due to the proximity to the Class A Drinking Water Supply (Fresh Pond), an emergency spill control plan must be submitted by the Contractor and approved by the City prior to use.

2. Question: Can the Base Loop Trail be used for delivery of materials?

Answer: Yes, but vehicles are required to move to the main parking lot after drop-off of materials.